
## DRAWING GUIDE - Smart - UPS On-line

Sheet No.	Component /Detail	Description
1	Drawing Guide	Smart-UPS-Online SRT1500XLA+SRT48BP 120VAC Drawing Guide
2	UPS Isometric View	Smart-UPS-Online SRT1500XLA+SRT48BP 120VAC UPS Isometric View
3	UPS General Arrangement	Smart-UPS-Online SRT1500XLA+SRT48BP 120VAC UPS General Arrangement
4	Battery Isometric View	Smart-UPS-Online SRT1500XLA+SRT48BP 120VAC UPS Isometric View
5	Battery General Arrangement	Smart-UPS-Online SRT1500XLA+SRT48BP 120VAC Battery General Arrangement
6	Solution Isometric View	Smart-UPS-Online SRT1500XLA+SRT48BP 120VAC Solution Isometric View
7	Solution General Arrangement	Smart-UPS-Online SRT1500XLA+SRT48BP 120VAC Solution General Arrangement
8	System One Line Diagram	Smart-UPS-Online SRT1500XLA+SRT48BP 120VAC System One Line Diagram

	LEGEND			
SYMBOL	DESCRIPTION	SYMBOL	DESCRIPTION	
	CIRCUIT BREAKER		AC-DC CONVERTER	
-0 0-	RELAY		DC-AC CONVERTER	
	TERMINATOR		(INVERTER)	
	DC-DC CONVERTER	<u></u>	BATTERY	




THIS DRAWING AND SPECIFICATIONS HEREIN ARE THE PROPERTY OF SCHNEIDER ELECTRIC AND SHALL NOT BE COPIED, REPRODUCED OR USED IN WHOLE OR IN PART, AS THE BASIS FOR THE MANUFACTURE OR SALE OF ITEMS WITHOUT WRITTEN PERMISSION FROM SCHNEIDER ELECTRIC. THIS DRAWING IS BASED UPON LATEST AVAILABLE INFORMATION AND IS SUBJECT TO CHANGE WITHOUT NOTICE.


Schneider Electric

TITLESmart-UPS Online (SRT) SRT1500XLA+SRT48BP
Input: 120VAC, (L+N+G), 50/60Hz, 1PH UPS Output: 120VAC, (L+N+G), 50/60Hz, 1PH, (6)NEMA 5-15
TOWER UPS AND EXTERNAL BATTERY PACK

	DWG NO: S	RT150	)OXLA
R	DRAWN BY:	JAYAPRAKASH	27-MAR-17

THIRD ANGLE ENGINEER: INDRA PRAKASH/SANTHOSH 30-MAR-17 S KATTIGE 30-MAR-17 PROJECTION PROJECT: DRAWINGS SHEET 2 OF 8 APPROVED BY:








## DISPLAY INTERFACE:

- 1. POWER "ON/OFF" BUTTON.
- 2. LOAD ICON, DISABLE/ MUTE AUDIBLE ALARM ICON.
- 3. UPS STATUS INFORMATION.
- 4. OPERATION MODE ICONS.
- 5. "ESCAPE" BUTTON.

- 6. "OK" BUTTON.
- 7. "UP/DOWN" BUTTONS.
- 8. CONTROLLABLE OUTLET GROUP STATUS ICONS.
- 9. BATTERY STATUS ICONS.







- NOTES:

  1. INSTALLATION SHALL COMPLY WITH ALL APPLICABLE NATIONAL,
- STATE AND LOCAL CODES.
- 2. REFER TO PRODUCT DOCUMENTATION FOR ADDITIONAL DETAILS PRIOR TO INSTALLATION AND SITE PREPARATION WORK.
- 3. ALL DIMENSIONS ARE IN INCHES [MILLIMETERS]
- 4. CABLE ENTRY IS FROM REAR OF UNIT. 5. WEIGHT OF UNIT IS 48.5 lb [22 kg].

THIS DRAWING AND SPECIFICATIONS HEREIN ARE THE PROPERTY OF SCHNEIDER ELECTRIC AND SHALL NOT BE COPIED, REPRODUCED OR USED IN WHOLE OR IN PART, AS THE BASIS FOR THE MANUFACTURE OR SALE OF ITEMS WITHOUT WRITTEN PERMISSION FROM SCHNEIDER ELECTRIC. THIS DRAWING IS BASED UPON LATEST AVAILABLE INFORMATION AND IS SUBJECT TO CHANGE WITHOUT NOTICE.




	TITLESmart-UPS Online (SRT) SRT1500XLA+SRT48BP
	Input: 120VAC, (L+N+G), 50/60Hz, 1PH
•	UPS Output: 120VAC, (L+N+G), 50/60Hz, 1PH, (6)NEMA 5-15R
	TOWER UPS AND EXTERNAL BATTERY PACK
•	LIDS_CENEDAL ADDANICEMENT

PROJECT: DRAWINGS SHEET 3 OF 8 APPROVED BY:

	DWG NO: S	RT150	)OXLA	REV.
5R	DRAWN BY:	JAYAPRAKASH	27-MAR-17	THIE
	ENGINEER: INDR	A PRAKASH/SANTHOSH	30-MAR-17	TANG

S KATTIGE 30-MAR-17



NOTES:

STATE AND LOCAL CODES.

2. REFER TO PRODUCT DOCUMENTATION FOR ADDITIONAL DETAILS PRIOR TO INSTALLATION AND SITE PREPARATION WORK.

THIS DRAWING AND SPECIFICATIONS HEREIN ARE THE PROPERTY OF SCHNEIDER ELECTRIC AND SHALL NOT BE COPIED, REPRODUCED OR USED IN WHOLE OR IN PART, AS THE BASIS FOR THE MANUFACTURE OR SALE OF ITEMS WITHOUT WRITTEN PERMISSION FROM SCHNEIDER ELECTRIC. THIS DRAWING IS BASED UPON LATEST AVAILABLE INFORMATION AND IS SUBJECT TO CHANGE WITHOUT NOTICE.


# Schneider Electric


	Smart-UPS Online (SRT) SRT1500XLA+SRT48BP
	Input: 120VAC, (L+N+G), 50/60Hz, 1PH
t	UPS Output: 120VAC, (L+N+G), 50/60Hz, 1PH, (6)NEMA 5-15R
	TOWER UPS AND EXTERNAL BATTERY PACK
٠.	BATTERY ISOMETRIC VIEW

	DWG NO: S	RT150	OXLA	REV.
15R	DRAWN BY:	JAYAPRAKASH	27-MAR-17	THIRD

PROJECT: DRAWINGS SHEET 4 OF 8 APPROVED BY:

ANGLE ENGINEER: INDRA PRAKASH/SANTHOSH 30-MAR-17 S KATTIGE 30-MAR-17 PROJECTION





### NOTES:

- 1. INSTALLATION SHALL COMPLY WITH ALL APPLICABLE NATIONAL, STATE AND LOCAL CODES.
- 2. REFER TO PRODUCT DOCUMENTATION FOR ADDITIONAL DETAILS PRIOR TO INSTALLATION AND SITE PREPARATION WORK.
- 3. ALL DIMENSIONS ARE IN INCHES [MILLIMETERS].
- 4. WEIGHT OF UNIT 69 lb [31.3kg].


THIS DRAWING AND SPECIFICATIONS HEREIN ARE THE PROPERTY OF SCHNEIDER ELECTRIC AND SHALL NOT BE COPIED, REPRODUCED OR USED IN WHOLE OR IN PART, AS THE BASIS FOR THE MANUFACTURE OR SALE OF ITEMS WITHOUT WRITTEN PERMISSION FROM SCHNEIDER ELECTRIC. THIS DRAWING IS BASED UPON LATEST AVAILABLE INFORMATION AND IS SUBJECT TO CHANGE WITHOUT NOTICE.

## Schneider Electric

	TITLESmart-UPS Online (SRT) SRT1500XLA+SRT48BP
	Input: 120VAC, (L+N+G), 50/60Hz, 1PH
2	UPS Output: 120VAC, (L+N+G), 50/60Hz, 1PH, (6)NEMA 5-15R
	TOWER UPS AND EXTERNAL BATTERY PACK
•	BATTERY AND CATRIDGE GENERAL ARRANGEMENT

	DWG NO: S	RT15C	OXLA	REV.
К	DRAWN BY-	IVAVDDVKVCH	27-MAR-17	THIRN

UPS OUTDUTE 120WG, (LHHG), SU/KOHZ, 1PH, (K)REMA 5-15K DRAWN BY: JAYAPRAKASH 27-MAR-17 THRD TOWN UPS AND EXTERNAL BATTERY PACK
BATTERY AND CATRIDGE GENERAL ARRANGEMENT ENGINEER: INDRA PRAKASH/SANTHOSH 30-MAR-17 ANGLE
PROJECT: DRAWING SHEET 5 OF 8 APPROVED BY: SKATTIGE 30-MAR-17 PROJECTION



INSTALLATION SHALL COMPLY WITH ALL APPLICABLE NATIONAL, STATE AND LOCAL CODES.
 REFER TO PRODUCT DOCUMENTATION FOR ADDITIONAL DETAILS PRIOR TO INSTALLATION AND SITE PREPARATION WORK.
 THIS DRAWING SCHNEIDER EL


THIS DRAWING AND SPECIFICATIONS HEREIN ARE THE PROPERTY OF SCHNEIDER ELECTRIC AND SHALL NOT BE COPIED, REPRODUCED OR USED IN WHOLE OR IN PART, AS THE BASIS FOR THE MANUFACTURE OR SALE OF ITEMS WITHOUT WRITTEN PERMISSION FROM SCHNEIDER ELECTRIC. THIS DRAWING IS BASED UPON LATEST AVAILABLE INFORMATION AND IS SUBJECT TO CHANGE WITHOUT NOTICE.

# Schneider **Electric**


TITLESmart-UPS Online (SRT) SRT1500XLA+SRT48BP
Input: 120VAC, (L+N+G), 50/60Hz, 1PH
UPS Output: 120VAC, (L+N+G), 50/60Hz, 1PH, (6)NEMA 5-15R
TOWER UPS AND EXTERNAL BATTERY PACK
 COLUTION ICONETRIO MEM

	DWG NO: SRT1500XLA			
iR	DRAWN BY:	JAYAPRAKASH	27-MAR-17	THIR

THIRD ANGLE SOLUTION-ISOMETRIC VIEW ENGINEER: INDRA PRAKASH/SANTHOSH 30-MAR-17 S KATTIGE 30-MAR-17 PROJECTION PROJECT: DRAWINGS SHEET 6 OF 8 APPROVED BY:



- 1. INSTALLATION SHALL COMPLY WITH ALL APPLICABLE NATIONAL, STATE AND LOCAL CODES.
- 2. REFER TO PRODUCT DOCUMENTATION FOR ADDITIONAL DETAILS PRIOR TO INSTALLATION AND SITE PREPARATION WORK.
- 3. ALL DIMENSIONS ARE IN INCHES [MILLIMETERS]
- △ 4. CONNECT EXTERNAL BATTERY POWER AND COMMUNICATION CABLE TO EXTERNAL BATTERY POWER AND COMMUNICATION CONNECTOR OF UPS.



USED IN WHOLE OR IN PART, AS THE BASIS FOR THE MANUFACTURE OR SALE OF ITEMS WITHOUT WRITTEN PERMISSION FROM SCHNEIDER ELECTRIC. THIS DRAWING IS BASED UPON LATEST AVAILABLE INFORMATION AND IS SUBJECT TO CHANGE WITHOUT NOTICE.

Schneider **Electric** 

TITLEsmart-UPS Online (SRI) SRT1500XLA+SRT488P input: 120VAC, (L+N+G), 50/60Hz, 1PH UPS Output: 120VAC, (L+N+G), 50/60Hz, 1PH, (6)NEMA 5-15R TOWER UPS AND EXTERNAL BATTERY PACK SOLUTION- GENERAL ARRANGEMENT

SRT1500XLA

REV. DRAWN BY: JAYAPRAKASH 27-MAR-17 THIRD ENGINEER: INDRA PRAKASH/SANTHOSH 30-MAR-17 ANGLE PROJECT: DRAWINGS SHEET 7 OF 8 APPROVED BY: S KATTIGE 30-MAR-17 PROJECTION

