



# **DIMENSIONS:**

|   |                        |
|---|------------------------|
| A | 3.75" ±0.063           |
| B | 1.35" REF.             |
| C | 3.25" ±0.063           |
| D | 3.00" ±0.063           |
| E | 0.87" MIN.             |
| F | 2.87" REF.             |
| G | 0.219" X 0.435" ±0.015 |



NOTE: ALL LEADS 24" OUT MIN.



## **ELECTRICAL DATA:**

| TESTS           | CONDITIONS            | ACCEPTANCE CRITERIA |
|-----------------|-----------------------|---------------------|
| I <sub>ex</sub> | @ 1V, 60Hz, WHT - BLK | 180mA Max.          |
| DCR             | @ 20°C, WHT - BLK =   | 0.024 Ω ±20%        |
| HIPOT           | WINDING - GROUND      | 2500V, 60Hz, 1 SEC  |
|                 | WINDING - WINDOW      | 4000V, 60Hz, 1 SEC  |

| REV.# | REVISION       | DATE     | <div> <b>HAMMOND MANUFACTURING</b>™ </div>                                                    |                         |                            |                |
|-------|----------------|----------|-----------------------------------------------------------------------------------------------|-------------------------|----------------------------|----------------|
| 0     | RELEASED. C.I. | 03/10/20 | <div> <b>ELECTRONIC DIVISION</b><br/> 52 RANKIN PLACE,<br/> WATERLOO, ONTARIO, N2J 3Z5 </div> |                         |                            |                |
|       |                |          | DWG. BY: C. ILIE                                                                              | CHK'D BY:               | TITLE: CURRENT TRANSFORMER | DWG. NO. CT60A |
|       |                |          | DATE: 03/10/20                                                                                | APP'D. BY:              |                            |                |
|       |                |          |                                                                                               | DIMENSIONS: IN(X) MM( ) |                            |                |

PH # (519) 886-6181  
FAX # (519) 886-9540