









#### **Model Number**

NJ30+U4+W

#### **Features**

- 30 mm non-flush
- 2-wire AC
- Limit switch style housing
- Metal base 1/2" NPT

### **Accessories**

MHW 01

Modular mounting bracket

### **Technical Data**

#### General specifications Switching element function Rated operating distance

Installation non-flush Output polarity AC Assured operating distance Reduction factor r<sub>Al</sub> 0 ... 24.3 mm 0.45 Reduction factor r<sub>Cu</sub> 0.4 Reduction factor r<sub>304</sub> 0.8

Nominal ratings

20 ... 253 V <sup>1)</sup> Operating voltage AC 0 ... 20 Hz Switching frequency 1 ... 10 typ. 5 % Hysteresis Voltage drop  $U_d$ ≤5 V

Momentary current (20 ms, 0.1 Hz) 0 ... 3000 mA Operating current
Off-state current 8 ... 500 mA

Operating voltage indicator Switching state indicator

Functional safety related parameters

 $\mathsf{MTTF}_\mathsf{d}$ 653 a Mission Time (T<sub>M</sub>)
Diagnostic Coverage (DC) 20 a 0 %

Ambient conditions

Ambient temperature -25 ... 70 °C (-13 ... 158 °F) -25 ... 85 °C (-13 ... 185 °F) Storage temperature

Mechanical specifications

Connection type screw terminals Core cross-section  $\leq 2.5 \text{ mm}^2$ Housing material PBT/metal PBT Sensing face

Degree of protection

IP68

1) In the temperature range below 0 °C, permissible operating voltage U<sub>b</sub> 80...253 V

0.5 ... 1.95 mA typ. 1.2 mA

LED, green

LED, yellow

NO/NC

30 mm

 $s_n$ 

Safety fuse  $\leq$  2 A (quick-blow) according to IEC 60127-2 Sheet 1 Recommendation: after a short circuit, check that the device is

functioning correctly.

General information Supplementary information Connection selectable as normally open or normally closed opera-

Only wire one output per device.

Compliance with standards and directives

Standard conformity


Standards EN 60947-5-2:2007 IEC 60947-5-2:2007

Approvals and certificates

**UL** approval cULus Listed, General Purpose cCSAus Listed, General Purpose CSA approval

CCC approval Certified by China Compulsory Certification (CCC)

## **Dimensions**



# **Electrical Connection**

