XAWG100EX

control station - XAW-G - plastic - 1 NO - green - Start



Main

| Range of product | Harmony XAW |
|-----------------------------|---|
| Product or component type | Complete control station |
| Device short name | XAWG |
| Control station application | Start function |
| Material | Glass fibre reinforced |
| Control station composition | 1 flush push-button, green spring return 1 NO |

Complementary

| Colour of base of enclosure | Black | |
|--------------------------------|---|--|
| Colour of cover | Black | |
| Cable entry | 1 entry for ISO M20 cable gland | |
| Width | 85 mm | |
| Depth | 70 mm | |
| Height | 146 mm | |
| Marking | Ex tb IIIC T85°C Db IP65 | |
| Mechanical durability | 5000000 cycles | |
| Short-circuit protection | 10 A cartridge fuse type gG | |
| [le] rated operational current | 3 A at 240 V AC-15, A600 conforming to EN/IEC 60947-5-1 6 A at 120 V AC-15, A600 conforming to EN/IEC 60947-5-1 0.1 A at 600 V DC-13, Q600 conforming to EN/IEC 60947-5-1 0.27 A at 250 V DC-13, Q600 conforming to EN/IEC 60947-5-1 0.55 A at 125 V DC-13, Q600 conforming to EN/IEC 60947-5-1 1.2 A at 600 V AC-15, A600 conforming to EN/IEC 60947-5-1 | |

Environment

| ambient air temperature for operation | -2060 °C | |
|---------------------------------------|--|--|
| overvoltage category | II conforming to IEC 60536 | |
| IP degree of protection | IP65 IEC 60529 | |
| standards | EN/IEC 60947-5-1 EN/IEC 60947-1 EN 61000-6-2 EN 60079-0 : 2009 EN 60079-31 : 2009 IEC 60079-0 : 2007 IEC 60079-31 : 2008 EN 60947-5-4 | |
| directives | 94/9/EC - ATEX directive | |
| dust zone | Zone 21 - 22 | |
| product certifications | INERIS 04ATEX0023X | |
| | | |

Contractual warranty

| Warranty period | 18 months | |
|------------------|-------------|--|
| Trainanty polica | TO INIONINO | |