

Please be informed that the data shown in this PDF Document is generated from our Online Catalog. Please find the complete data in the user's documentation. Our General Terms of Use for Downloads are valid (http://phoenixcontact.com/download)



Marshalling patchboard, without actuation lever, nom. voltage: 500 V, nominal current: 17.5 A, cross section: 0.14 mm² - 2.5 mm², AWG: 14 - 26, connection method: Push-in connection, number of positions: 1, number of connections: 6, width: 11 mm, length: 12.2 mm, color: gray, color of connection elements: white, mounting: for snapping onto a DIN rail adapter, for snapping onto a cover flange

Your advantages

- ☑ Color configuration possible according to VDE 0812, VDE 0815, DIN 47100 or unlimited.
- ☑ Individual color assignment of cable and terminal point to ensure error-free, safe operation
- High contact quality thanks to push-in technology as a replacement for Wire-Wrap®, TERMI-POINT®, etc.
- Suitable for DIN rail mounting and panel cutouts with corresponding accessories
- ☑ Individual setup thanks to modular principle



Key Commercial Data

Packing unit	10 pc
Minimum order quantity	10 pc
GTIN	4 055626 058504
GTIN	4055626058504
Weight per Piece (excluding packing)	4.190 g
Custom tariff number	85369010
Country of origin	Poland
Note	Made to Order (non-returnable)

Technical data

General

Number of positions	1
Number of levels	1
Number of connections	6
Nominal cross section	1.5 mm²
Color	gray



Technical data

General

Color of connection elements	white
Insulating material	PA
Flammability rating according to UL 94	V0
Rated surge voltage	6 kV
Degree of pollution	3
Overvoltage category	III
Insulating material group	I
Maximum power dissipation for nominal condition	0.56 W
Ambient temperature (operation)	-60 85 ()
Ambient temperature (storage/transport)	-25 55
Ambient temperature (assembly)	-5 70
Ambient temperature (actuation)	-5 70
Maximum load current	24 A (in case of a 2.5 mm² conductor cross section, the maximum load current must not be exceeded by the total current of all connected conductors.)
Nominal current I _N	17.5 A
Nominal voltage U _N	500 V
Open side panel	No
Shock protection test specification	DIN EN 50274 (VDE 0660-514):2002-11
Back of the hand protection	guaranteed
Finger protection	guaranteed
Result of surge voltage test	Test passed
Surge voltage test setpoint	7.3 kV
Result of power-frequency withstand voltage test	Test passed
Power frequency withstand voltage setpoint	1.89 kV
Result of the test for mechanical stability of terminal points (5 x conductor connection)	Test passed
Result of bending test	Test passed
Bending test rotation speed	10 rpm
Bending test turns	135
Bending test conductor cross section/weight	0.14 mm² / 0.2 kg
	1.5 mm² / 0.4 kg
	2.5 mm² / 0.7 kg
Tensile test result	Test passed
Conductor cross section tensile test	0.14 mm²
Tractive force setpoint	10 N
Conductor cross section tensile test	1.5 mm²
Tractive force setpoint	40 N
Conductor cross section tensile test	2.5 mm ²
Tractive force setpoint	50 N
Result of tight fit on support	Test passed



Technical data

General

Setpoint 1 N Result of voltage-drop test Test passed Requirements, voltage drop < 3.2 mV	Tight fit on carrier	NS 35
Requirements, voltage drop < 3.2 mV	Setpoint	1 N
Result of temperature-rise test	Result of voltage-drop test	Test passed
Short circuit stability result Test passed Conductor cross section short circuit testing 1.5 mm² Short-time current 0.18 kA Conductor cross section short circuit testing 2.5 mm² Short-time current 0.3 kA Result of thermal test Test passed Ageing test for screwless modular terminal block temperature cycles 192 Proof of thermal characteristics (needle flame) effective duration 30 s Result of aging test Test passed Oscillation, broadband noise test result Test passed Test specification, oscillation, broadband noise test result Test passed Test specification, oscillation, broadband noise DIN EN 50156 (VDE 0115-200):2008-03 Test steps frequency f ₁ = 5 Hz to f ₂ = 150 Hz ASD level 0.964 (m/s²)²/Hz Acceleration 0.58 g Test duration per axis 5 h Test directions X, Y and Z-axis Shock form Helf-sine Acceleration 5g Shock form Helf-sine Acceleration 3 Shock duration 30 ms	Requirements, voltage drop	≤ 3.2 mV
Conductor cross section short circuit testing 1.5 mm² Short-time current 0.18 kA Conductor cross section short circuit testing 2.5 mm² Short-time current 0.3 kA Result of thermal test Test passed Ageing test for screwless modular terminal block temperature cycles 192 Proof of thermal characteristics (needle flame) effective duration 30 s Result of aging test Test passed Oscillation, broadband noise test result Test passed Sellation, proadband noise test result Test passed Test specification, oscillation, broadband noise DIN EN 50155 (VDE 0115-200):2008-03 Test specification, oscillation, broadband noise DIN EN 50155 (VDE 0115-200):2008-03 Test specification, socillation, broadband noise DIN EN 50155 (VDE 0115-200):2008-03 Test specification 5.5 ASD level 0.984 (m/s²)²/Hz Acceleration 0.58 g Test directions X-, Y- and Z-axis Test directions X-, Y- and Z-axis Shock fresult Test passed Test specification, shock test DIN EN 50155 (VDE 0115-200):2008-03	Result of temperature-rise test	Test passed
Short-time current 0.18 kA Conductor cross section short circuit testing 2.5 mm² Short-time current 0.3 kA Result for thermal test Test passed Ageing test for screwless modular terminal block temperature cycles 192 Proof of thermal characteristics (needle flame) effective duration 30 s Result of aging test Test passed Oscillation, broadband noise test result Test passed Test specification, oscillation, broadband noise DIN EN 50155 (VDE 0115-200):2008-03 Test specification, oscillation, broadband noise DIN EN 50155 (VDE 0115-200):2008-03 Test specification, oscillation, broadband noise DIN EN 50155 (VDE 0115-200):2008-03 Test specification, oscillation, broadband noise DIN EN 50155 (VDE 0115-200):2008-03 Test sfrequency f; = 5 Hz to f; = 150 Hz Acceleration 0.58 g Test directions X. Y. and Z-axis Shock test seutit Test specification, shock test DIN EN 50155 (VDE 0115-200):2008-03 Test specification, shock test Shock form Half-sine Acceleration 5g Shock form Shock duration present servi	Short circuit stability result	Test passed
Conductor cross section short circuit testing 2.5 mm² Short-time current 0.3 kA Result of thermal test Test passed Ageing test for screwless modular terminal block temperature cycles 192 Proof of thermal characteristics (needle flame) effective duration 30 s Result of aging test Test passed Oscillation, broadband noise test result Test passed Test specification, oscillation, broadband noise DIN EN 50155 (VDE 0115-200) 2008-03 Test specification, oscillation, broadband noise Service life test category 1, class B, body mounted Test specification, oscillation, broadband noise Service life test category 1, class B, body mounted Test specification oscillation broadband noise Service life test category 1, class B, body mounted Test specification oscillation broadband noise 0.964 (m/s³)*/Hz ASD level 0.964 (m/s³)*/Hz Acceleration 5.5 Test duration per axis 5.5 Test directions X., Y- and Z-axis Shock test result Test passed Test directions, shock test DIN EN 50155 (VDE 0115-200) 2008-03 Shock duration 30 ms N	Conductor cross section short circuit testing	1.5 mm ²
Short-time current 0.3 kA Result of thermal test Test passed Ageing test for screwless modular terminal block temperature cycles 192 Proof of thermal characteristics (needle flame) effective duration 30 s Result of aging test Test passed Oscillation, broadband noise test result Test passed Test specification, oscillation, broadband noise DIN EN 50155 (VDE 0115-200):2008-03 Test spectrum Service life test category 1, class B, body mounted Test frequency f, = 5 Hz to f, = 150 Hz Asc level 0.984 (m/s² /Hz Acceleration 0.58 g Test duration per axis 5 h Test specification, shock test Test passed Nock form Half-sine Acceleration 5g Shock form Half-sine Acceleration 30 ms Number of shocks per direction 3 Test directions X, Y- and Z-axis (pos. and neg.) Relative insulation material temperature index (Elec., UL 746 B) 130 °C Temperature index of insulation material (DIN EN 60216-1 (VDE 0.2 Leas I) 125 °C S	Short-time current	0.18 kA
Result of thermal test Test passed Ageing test for screwless modular terminal block temperature cycles 192 Proof of thermal characteristics (needle flame) effective duration 30 s Result of aging test Test passed Oscillation, broadband noise test result Test passed Test specification, oscillation, broadband noise DIN EN 50155 (VDE 0115-200):2008-03 Test spectrum Service life test category 1, class B, body mounted Test spectrum 0.964 (m/s³)²/Hz ASD level 0.964 (m/s³)²/Hz Acceleration 0.58 g Test duration per axis 5 h Test directions X-, Y and Z-axis Shock test result Test passed Test specification, shock test DIN EN 50155 (VDE 0115-200):2008-03 Shock duration Bolts (VDE 0115-200):2008-03 Acceleration 5g Acceleration 30 ms Acceleration 30 ms Acceleration 30 ms Number of shocks per direction 3 Relative insulation material temperature index (Elec, UL 746 B) 130 °C Test directions X-, Y	Conductor cross section short circuit testing	2.5 mm²
Ageing test for screwless modular terminal block temperature cycles Proof of thermal characteristics (needle flame) effective duration Result of aging test Oscillation, broadband noise test result Test passed Oscillation, broadband noise test result Test spassed DIN EN 50155 (VDE 0115-200):2008-03 Test spectrum Service life test category 1, class B, body mounted fi = 5 Hz to f₂ = 150 Hz ASD level ASD le	Short-time current	0.3 kA
Proof of thermal characteristics (needle flame) effective duration 30 s Result of aging test Test passed Oscillation, broadband noise test result Test passed Test specification, oscillation, broadband noise DIN EN 50155 (VDE 0115-200):2008-03 Test specification, oscillation, broadband noise DIN EN 50155 (VDE 0115-200):2008-03 Test specification, oscillation, broadband noise Service life test category 1, class B, body mounted Test specification 0.964 (m/s²)²/Hz ASD level 0.964 (m/s²)²/Hz Acceleration 0.58 g Test duration per axis 5 h Test directions X., Y- and Z-axis Shock test result Test passed Test specification, shock test DIN EN 50155 (VDE 0115-200):2008-03 Shock form Half-sine Acceleration 5g Shock duration 30 ms Number of shocks per direction 3 Relative insulation material temperature index (Elec., UL 746 B) 130 °C Temperature index of insulation material (DIN EN 60216-1 (VDE 0.042 m) 125 °C Static insulating material application in cold -60 °C <	Result of thermal test	Test passed
Result of aging test Test passed Oscillation, broadband noise test result Test passed Test specification, oscillation, broadband noise DIN EN 50155 (VDE 0115-200):2008-03 Test specification, oscillation, broadband noise DIN EN 50155 (VDE 0115-200):2008-03 Test spectrum Service life test category 1, class B, body mounted Test frequency f, = 5 Hz to f ₂ = 150 Hz ASD level 0.964 (m/s³)²/Hz Acceleration 0.58 g Test duration per axis 5 h Test directions X., Y- and Z-axis Shock test result Test passed Test specification, shock test DIN EN 50155 (VDE 0115-200):2008-03 Shock form Half-sine Acceleration 5g Shock duration 30 ms Number of shocks per direction 3 Test directions X., Y- and Z-axis (pos. and neg.) Relative insulation material temperature index (Elec., UL 746 B) 130 °C Temperature index of insulation material (DIN EN 60216-1 (VDE 030-2) 125 °C Static insulating material application in cold -60 °C Behavior in fire for rail vehicles (DIN 5510-2) <td>Ageing test for screwless modular terminal block temperature cycles</td> <td>192</td>	Ageing test for screwless modular terminal block temperature cycles	192
Oscillation, broadband noise test result Test passed Test specification, oscillation, broadband noise DIN EN 50155 (VDE 0115-200):2008-03 Test spectrum Service life test category 1, class B, body mounted Test frequency f, = 5 Hz to f₂ = 150 Hz ASD level 0.964 (m/s²)²/Hz Acceleration 0.58 g Test duration per axis 5 h Test duration per axis 5 h Shock test result Test passed Test specification, shock test DIN EN 50155 (VDE 0115-200):2008-03 Shock form Half-sine Acceleration 5g Shock duration 30 ms Number of shocks per direction 3 Test directions X-, Y- and Z-axis (pos. and neg.) Relative insulation material temperature index (Elec., UL 746 B) 130 °C Relative insulation material application in cold -60 °C Behavior in fire for rail vehicles (DIN EN 60695-11-10) V0 Oxygen index (DIN EN 180 4589-2) >32 % NF F16-101, NF F10-102 Class F 2 Surface flammability NFPA 130 (ASTM E 162) passed Specific optical density of smoke NFPA 130 (ASTM E 662) passed	Proof of thermal characteristics (needle flame) effective duration	30 s
Test specification, oscillation, broadband noise DIN EN 50155 (VDE 0115-200):2008-03 Test spectrum Service life test category 1, class B, body mounted Test frequency $f_1 = 5$ Hz to $f_2 = 150$ Hz ASD level 0.964 (m/s³)²/Hz Acceleration 0.58 g Test duration per axis 5 h Test duration per axis 5 h Test directions X , Y- and Z-axis Shock test result Test passed Test specification, shock test DIN EN 50155 (VDE 0115-200):2008-03 Shock form Half-sine Acceleration 5 g Shock duration 30 ms Number of shocks per direction 3 ms Test directions X , Y- and Z-axis (pos. and neg.) Relative insulation material temperature index (Elec., UL 746 B) 130 °C Temperature index of insulation material (DIN EN 60216-1 (VDE 0304-21)) 125 °C Static insulating material application in cold -60 °C Behavior in fire for rail vehicles (DIN 5510-2) Test passed Flame test method (DIN EN 60695-11-10) V0 Oxygen index (DIN EN 160695-11-10) V0 Oxygen index (DIN EN 160695-11-10)	Result of aging test	Test passed
Test spectrum Service life test category 1, class B, body mounted Test frequency f₁ = 5 Hz to f₂ = 150 Hz ASD level 0.964 (m/s²²²/Hz Acceleration 0.58 g Test duration per axis 5 h Test directions X-, Y- and Z-axis Shock test result Test passed Test specification, shock test DIN EN 50155 (VDE 0115-200):2008-03 Shock form Half-sine Acceleration 5g Shock duration 30 ms Number of shocks per direction 3 Test directions X-, Y- and Z-axis (pos. and neg.) Relative insulation material temperature index (Elec., UL 746 B) 130 °C Temperature index of insulation material (DIN EN 60216-1 (VDE 0304-21)) 125 °C Static insulating material application in cold -60 °C Behavior in fire for rail vehicles (DIN 5510-2) Test passed Flame test method (DIN EN 6089-11-10) V0 Oxygen index (DIN EN 6089-11-10) V0 Oxygen index (DIN EN 150 4589-2) >32 % NF F16-101, NF F10-102 Class I 2 Surface flammability NFPA 130 (ASTM E 162) </td <td>Oscillation, broadband noise test result</td> <td>Test passed</td>	Oscillation, broadband noise test result	Test passed
Test frequency f, = 5 Hz to f, = 150 Hz ASD level 0.964 (m/s²)²/Hz Acceleration 0.58 g Test duration per axis 5 h Test directions X-, Y- and Z-axis Shock test result Test passed Test specification, shock test DIN EN 50155 (VDE 0115-200):2008-03 Shock form Half-sine Acceleration 5g Shock duration 30 ms Number of shocks per direction 3 Relative insulation material temperature index (Elec., UL 746 B) 130 °C Temperature index of insulation material (DIN EN 60216-1 (VDE 0304-21)) 125 °C Static insulating material application in cold -60 °C Behavior in fire for rail vehicles (DIN 5510-2) Test passed Flame test method (DIN EN 60695-11-10) V0 Oxygen index (DIN EN ISO 4589-2) >32 % NF F16-101, NF F10-102 Class I 2 Surface flammability NFPA 130 (ASTM E 162) passed Specific optical density of smoke NFPA 130 (ASTM E 662) passed	Test specification, oscillation, broadband noise	DIN EN 50155 (VDE 0115-200):2008-03
ASD level 0.964 (m/s²)²/Hz Acceleration 0.58 g Test duration per axis 5 h Test directions X-, Y- and Z-axis Shock test result Test spassed Test specification, shock test DIN EN 50155 (VDE 0115-200):2008-03 Shock form Half-sine Acceleration 5g Shock duration 30 ms Number of shocks per direction 30 ms Number of shocks per direction 3. X-, Y- and Z-axis (pos. and neg.) Relative insulation material temperature index (Elec., UL 746 B) 130 °C Temperature index of insulation material (DIN EN 60216-1 (VDE 0304-21)) Static insulating material application in cold 60 °C Behavior in fire for rail vehicles (DIN 5510-2) Test passed Flame test method (DIN EN 60695-11-10) V0 Oxygen index (DIN EN 180 4589-2) >32 % NF F16-101, NF F10-102 Class I 2 Surface flammability NFPA 130 (ASTM E 162) passed Specific optical density of smoke NFPA 130 (ASTM E 662) passed	Test spectrum	Service life test category 1, class B, body mounted
Acceleration 0.58 g Test duration per axis 5 h Test directions X-, Y- and Z-axis Shock test result Test passed Test specification, shock test DIN EN 50155 (VDE 0115-200):2008-03 Shock form Half-sine Acceleration 5g Shock duration 30 ms Number of shocks per direction 3 Test directions X-, Y- and Z-axis (pos. and neg.) Relative insulation material temperature index (Elec., UL 746 B) 130 °C Temperature index of insulation material (DIN EN 60216-1 (VDE 0304-21)) 125 °C Static insulating material application in cold -60 °C Behavior in fire for rail vehicles (DIN 5510-2) Test passed Flame test method (DIN EN 60695-11-10) V0 Oxygen index (DIN EN ISO 4589-2) >32 % NF F16-101, NF F10-102 Class I 2 Surface flammability NFPA 130 (ASTM E 162) passed Specific optical density of smoke NFPA 130 (ASTM E 662) passed	Test frequency	$f_1 = 5 \text{ Hz to } f_2 = 150 \text{ Hz}$
Test duration per axis Test directions X-, Y- and Z-axis Shock test result Test specification, shock test DIN EN 50155 (VDE 0115-200):2008-03 Shock form Half-sine Acceleration Shock duration Shock sper direction 30 ms Number of shocks per direction Relative insulation material temperature index (Elec., UL 746 B) Temperature index of insulation material (DIN EN 60216-1 (VDE 0304-21)) Static insulating material application in cold Behavior in fire for rail vehicles (DIN 5510-2) Flame test method (DIN EN 60695-11-10) Oxygen index (DIN EN ISO 4589-2) NF F16-101, NF F10-102 Class I Surface flammability NFPA 130 (ASTM E 162) Specific optical density of smoke NFPA 130 (ASTM E 662) Passed DIN EN 50155 (VDE 0115-200):2008-03 Test passed JN F S16-101, NF F10-102 Class F Specific optical density of smoke NFPA 130 (ASTM E 662) passed	ASD level	0.964 (m/s²)²/Hz
Test directions X-, Y- and Z-axis Shock test result Test passed Test specification, shock test DIN EN 50155 (VDE 0115-200):2008-03 Shock form Half-sine Acceleration 5g Shock duration 30 ms Number of shocks per direction 3 Test directions X-, Y- and Z-axis (pos. and neg.) Relative insulation material temperature index (Elec., UL 746 B) 130 °C Temperature index of insulation material (DIN EN 60216-1 (VDE 0304-21)) 125 °C Static insulating material application in cold -60 °C Behavior in fire for rail vehicles (DIN 5510-2) Test passed Flame test method (DIN EN 60695-11-10) V0 Oxygen index (DIN EN ISO 4589-2) >32 % NF F16-101, NF F10-102 Class I 2 NF F16-101, NF F10-102 Class F 2 Surface flammability NFPA 130 (ASTM E 162) passed Specific optical density of smoke NFPA 130 (ASTM E 662) passed	Acceleration	0.58 g
Shock test resultTest passedTest specification, shock testDIN EN 50155 (VDE 0115-200):2008-03Shock formHalf-sineAcceleration5gShock duration30 msNumber of shocks per direction3 msTest directionsX-, Y- and Z-axis (pos. and neg.)Relative insulation material temperature index (Elec., UL 746 B)130 °CTemperature index of insulation material (DIN EN 60216-1 (VDE 0304-21))125 °CStatic insulating material application in cold-60 °CBehavior in fire for rail vehicles (DIN 5510-2)Test passedFlame test method (DIN EN 60695-11-10)V0Oxygen index (DIN EN ISO 4589-2)>32 %NF F16-101, NF F10-102 Class I2Surface flammability NFPA 130 (ASTM E 162)passedSpecific optical density of smoke NFPA 130 (ASTM E 662)passed	Test duration per axis	5 h
Test specification, shock test DIN EN 50155 (VDE 0115-200):2008-03 Shock form Half-sine Acceleration 5g Shock duration 30 ms Number of shocks per direction Test directions Relative insulation material temperature index (Elec., UL 746 B) Temperature index of insulation material (DIN EN 60216-1 (VDE 0304-21)) Static insulating material application in cold Behavior in fire for rail vehicles (DIN 5510-2) Flame test method (DIN EN 60695-11-10) Oxygen index (DIN EN 60695-12 NF F16-101, NF F10-102 Class I Sufface flammability NFPA 130 (ASTM E 162) Specific optical density of smoke NFPA 130 (ASTM E 662) DIN EN 50155 (VDE 0115-200):2008-03 Malf-sine 5g Specific optical density of smoke NFPA 130 (ASTM E 662)	Test directions	X-, Y- and Z-axis
Shock formHalf-sineAcceleration5gShock duration30 msNumber of shocks per direction3Test directionsX-, Y- and Z-axis (pos. and neg.)Relative insulation material temperature index (Elec., UL 746 B)130 °CTemperature index of insulation material (DIN EN 60216-1 (VDE 0304-21))125 °CStatic insulating material application in cold-60 °CBehavior in fire for rail vehicles (DIN 5510-2)Test passedFlame test method (DIN EN 60695-11-10)V0Oxygen index (DIN EN ISO 4589-2)>32 %NF F16-101, NF F10-102 Class I2NF F16-101, NF F10-102 Class F2Surface flammability NFPA 130 (ASTM E 162)passedSpecific optical density of smoke NFPA 130 (ASTM E 662)passed	Shock test result	Test passed
Acceleration 5g Shock duration 30 ms Number of shocks per direction 3 Test directions X-, Y- and Z-axis (pos. and neg.) Relative insulation material temperature index (Elec., UL 746 B) 130 °C Temperature index of insulation material (DIN EN 60216-1 (VDE 0304-21)) Static insulating material application in cold -60 °C Behavior in fire for rail vehicles (DIN 5510-2) Test passed Flame test method (DIN EN 60695-11-10) V0 Oxygen index (DIN EN 180 4589-2) >32 % NF F16-101, NF F10-102 Class I 2 Surface flammability NFPA 130 (ASTM E 162) passed Specific optical density of smoke NFPA 130 (ASTM E 662) passed	Test specification, shock test	DIN EN 50155 (VDE 0115-200):2008-03
Shock duration30 msNumber of shocks per direction3Test directionsX-, Y- and Z-axis (pos. and neg.)Relative insulation material temperature index (Elec., UL 746 B)130 °CTemperature index of insulation material (DIN EN 60216-1 (VDE 0304-21))125 °CStatic insulating material application in cold-60 °CBehavior in fire for rail vehicles (DIN 5510-2)Test passedFlame test method (DIN EN 60695-11-10)V0Oxygen index (DIN EN ISO 4589-2)>32 %NF F16-101, NF F10-102 Class I2NF F16-101, NF F10-102 Class F2Surface flammability NFPA 130 (ASTM E 162)passedSpecific optical density of smoke NFPA 130 (ASTM E 662)passed	Shock form	Half-sine
Number of shocks per direction Test directions X-, Y- and Z-axis (pos. and neg.) Relative insulation material temperature index (Elec., UL 746 B) 130 °C Temperature index of insulation material (DIN EN 60216-1 (VDE 0304-21)) Static insulating material application in cold 54 cho °C Behavior in fire for rail vehicles (DIN 5510-2) Flame test method (DIN EN 60695-11-10) Coxygen index (DIN EN ISO 4589-2) NF F16-101, NF F10-102 Class I NF F16-101, NF F10-102 Class F Surface flammability NFPA 130 (ASTM E 162) Specific optical density of smoke NFPA 130 (ASTM E 662) passed	Acceleration	5g
Test directions X-, Y- and Z-axis (pos. and neg.) Relative insulation material temperature index (Elec., UL 746 B) 130 °C Temperature index of insulation material (DIN EN 60216-1 (VDE 0304-21)) Static insulating material application in cold -60 °C Behavior in fire for rail vehicles (DIN 5510-2) Test passed Flame test method (DIN EN 60695-11-10) V0 Oxygen index (DIN EN ISO 4589-2) >32 % NF F16-101, NF F10-102 Class I 2 NF F16-101, NF F10-102 Class F 2 Surface flammability NFPA 130 (ASTM E 162) passed Specific optical density of smoke NFPA 130 (ASTM E 662) passed	Shock duration	30 ms
Relative insulation material temperature index (Elec., UL 746 B) Temperature index of insulation material (DIN EN 60216-1 (VDE 0304-21)) Static insulating material application in cold 60 °C Behavior in fire for rail vehicles (DIN 5510-2) Flame test method (DIN EN 60695-11-10) Oxygen index (DIN EN ISO 4589-2) NF F16-101, NF F10-102 Class I Surface flammability NFPA 130 (ASTM E 162) Specific optical density of smoke NFPA 130 (ASTM E 662) 125 °C 125	Number of shocks per direction	3
Temperature index of insulation material (DIN EN 60216-1 (VDE 0304-21)) Static insulating material application in cold Behavior in fire for rail vehicles (DIN 5510-2) Flame test method (DIN EN 60695-11-10) Oxygen index (DIN EN ISO 4589-2) NF F16-101, NF F10-102 Class I NF F16-101, NF F10-102 Class F Surface flammability NFPA 130 (ASTM E 162) Specific optical density of smoke NFPA 130 (ASTM E 662) 125 °C 125 °	Test directions	X-, Y- and Z-axis (pos. and neg.)
Static insulating material application in cold Static insulating material application in cold Flame test method (DIN EN 60695-11-10) Oxygen index (DIN EN ISO 4589-2) NF F16-101, NF F10-102 Class I Surface flammability NFPA 130 (ASTM E 162) Specific optical density of smoke NFPA 130 (ASTM E 662) Static insulating material application in cold -60 °C Test passed V0 2 2 Suppose the passed 2 Suppose the passed passed passed	Relative insulation material temperature index (Elec., UL 746 B)	130 °C
Behavior in fire for rail vehicles (DIN 5510-2) Flame test method (DIN EN 60695-11-10) Oxygen index (DIN EN ISO 4589-2) NF F16-101, NF F10-102 Class I NF F16-101, NF F10-102 Class F 2 Surface flammability NFPA 130 (ASTM E 162) Specific optical density of smoke NFPA 130 (ASTM E 662) Test passed 2 2 32 % Passed 2 Surface flammability NFPA 130 (ASTM E 162) passed		125 °C
Flame test method (DIN EN 60695-11-10) Oxygen index (DIN EN ISO 4589-2) NF F16-101, NF F10-102 Class I NF F16-101, NF F10-102 Class F 2 Surface flammability NFPA 130 (ASTM E 162) Specific optical density of smoke NFPA 130 (ASTM E 662) passed passed	Static insulating material application in cold	-60 °C
Oxygen index (DIN EN ISO 4589-2) NF F16-101, NF F10-102 Class I NF F16-101, NF F10-102 Class F 2 Surface flammability NFPA 130 (ASTM E 162) Specific optical density of smoke NFPA 130 (ASTM E 662) passed passed	Behavior in fire for rail vehicles (DIN 5510-2)	Test passed
NF F16-101, NF F10-102 Class I 2 NF F16-101, NF F10-102 Class F 2 Surface flammability NFPA 130 (ASTM E 162) passed Specific optical density of smoke NFPA 130 (ASTM E 662) passed	Flame test method (DIN EN 60695-11-10)	V0
NF F16-101, NF F10-102 Class F 2 Surface flammability NFPA 130 (ASTM E 162) passed Specific optical density of smoke NFPA 130 (ASTM E 662) passed	Oxygen index (DIN EN ISO 4589-2)	>32 %
Surface flammability NFPA 130 (ASTM E 162) passed Specific optical density of smoke NFPA 130 (ASTM E 662) passed	NF F16-101, NF F10-102 Class I	2
Specific optical density of smoke NFPA 130 (ASTM E 662) passed	NF F16-101, NF F10-102 Class F	2
· · · · · · · · · · · · · · · · · · ·	Surface flammability NFPA 130 (ASTM E 162)	passed
Smoke gas toxicity NFPA 130 (SMP 800C) passed	Specific optical density of smoke NFPA 130 (ASTM E 662)	passed
, , , , , , , , , , , , , , , , , , , ,	Smoke gas toxicity NFPA 130 (SMP 800C)	passed



Technical data

General

Calorimetric heat release NFPA 130 (ASTM E 1354)	27,5 MJ/kg
Fire protection for rail vehicles (DIN EN 45545-2) R22	HL 1 - HL 3
Fire protection for rail vehicles (DIN EN 45545-2) R23	HL 1 - HL 3
Fire protection for rail vehicles (DIN EN 45545-2) R24	HL 1 - HL 3
Fire protection for rail vehicles (DIN EN 45545-2) R26	HL 1 - HL 3

Dimensions

Width	11 mm
Length	12.2 mm
Height	30 mm

Connection data

Connection method	Push-in connection
Stripping length	8 mm 10 mm
Connection in acc. with standard	IEC 60947-7-1
Conductor cross section solid min.	0.14 mm²
Conductor cross section solid max.	2.5 mm²
Conductor cross section AWG min.	26
Conductor cross section AWG max.	14
Conductor cross section flexible min.	0.14 mm²
Conductor cross section flexible max.	1.5 mm²
Min. AWG conductor cross section, flexible	26
Max. AWG conductor cross section, flexible	14
Conductor cross section flexible, with ferrule without plastic sleeve min.	0.14 mm²
Conductor cross section flexible, with ferrule without plastic sleeve max.	1.5 mm²
Conductor cross section flexible, with ferrule with plastic sleeve min.	0.14 mm²
Conductor cross section flexible, with ferrule with plastic sleeve max.	1.5 mm²
Internal cylindrical gage	A1

Standards and Regulations

Connection in acc. with standard	IEC 60947-7-1
Flammability rating according to UL 94	V0


Environmental Product Compliance

China RoHS	Environmentally friendly use period: unlimited = EFUP-e
	No hazardous substances above threshold values

Drawings



Circuit diagram



Classifications

eCl@ss

eCI@ss 4.0	27141100
eCl@ss 4.1	27141100
eCl@ss 5.0	27141100
eCl@ss 5.1	27141100
eCl@ss 6.0	27141100
eCl@ss 7.0	27141120
eCl@ss 8.0	27141120
eCl@ss 9.0	27141120

ETIM

ETIM 5.0	EC000897
ETIM 6.0	EC000897
ETIM 7.0	EC000897

UNSPSC

UNSPSC 13.2	39121410
UNSPSC 18.0	39121410
UNSPSC 19.0	39121410
UNSPSC 20.0	39121410
UNSPSC 21.0	39121410

Approvals

Approvals

Approvals

CSA / UL Recognized / cUL Recognized / EAC / EAC / cULus Recognized

Ex Approvals

Approval details



Approvals

CSA	http://www.csagroup.org/services-industries/product-listing/ 13631			
	В	С		D
Nominal voltage UN	300 V	3	300 V	300 V
Nominal current IN	10 A	1	0 A	10 A
mm²/AWG/kcmil	24-16	2	24-16	24-16

UL Recognized	http://database.ul.com/cgi-bin/XYV/template/LISEXT/1FRAME/index.htm FILE E 60425	
	В	С
Nominal voltage UN	300 V	300 V
Nominal current IN	10 A	10 A
mm²/AWG/kcmil	24-16	24-16

cUL Recognized	http://database.ul.com/cgi-bin/XYV/template/LISEXT/1FRAME/index.htm FILE E 60425	
	В	С
Nominal voltage UN	300 V	300 V
Nominal current IN	10 A	10 A
mm²/AWG/kcmil	24-16	24-16

EAC	EAC	RU C- DE.A*30.B.01742
EAC	EAC	RU C- DE.BL08.B.00682

Accessories

Accessories

Insulating sleeve



Accessories

Insulating sleeve - MPS-IH WH - 0201663

Insulating sleeve, color: white



Insulating sleeve - MPS-IH RD - 0201676

Insulating sleeve, color: red



Insulating sleeve - MPS-IH BU - 0201689

Insulating sleeve, color: blue



Insulating sleeve - MPS-IH YE - 0201692

Insulating sleeve, color: yellow



Insulating sleeve - MPS-IH GN - 0201702

Insulating sleeve, color: green





Accessories

Insulating sleeve - MPS-IH GY - 0201728

Insulating sleeve, color: gray



Insulating sleeve - MPS-IH BK - 0201731

Insulating sleeve, color: black



Labeled terminal marker

Zack marker strip - ZB 10 CUS - 0824941



Zack marker strip, can be ordered: Strip, white, labeled according to customer specifications, mounting type: snap into tall marker groove, for terminal block width: 10.2 mm, lettering field size: 10.15 x 10.5 mm, Number of individual labels: 10

Zack marker strip - ZB10,LGS:FORTL.ZAHLEN - 1053014



Zack marker strip, Strip, white, labeled, can be labeled with: CMS-P1-PLOTTER, printed horizontally: consecutive numbers 1 ... 10, 11 ... 20, etc. up to 91 ... 100, mounting type: snap into tall marker groove, for terminal block width: 10.2 mm, lettering field size: 10.15 x 10.5 mm, Number of individual labels: 10

Zack marker strip - ZB10,QR:FORTL.ZAHLEN - 1053027



Zack marker strip, Strip, white, labeled, can be labeled with: CMS-P1-PLOTTER, Printed vertically: consecutive numbers 1 ... 10, 11 ... 20, etc. up to 91 ... 100, mounting type: snap into tall marker groove, for terminal block width: 10.2 mm, lettering field size: 10.15 x 10.5 mm, Number of individual labels: 10



Accessories

Marker for terminal blocks - ZB10,LGS:L1-N,PE - 1053412



Marker for terminal blocks, Strip, white, labeled, can be labeled with: CMS-P1-PLOTTER, Horizontal: L1, L2, L3, N, PE, L1, L2, L3, N, PE, mounting type: snap into tall marker groove, for terminal block width: 10.2 mm, lettering field size: 10.15 x 10.5 mm, Number of individual labels: 10

Marker for terminal blocks - ZB10,LGS:U-N - 1053438



Marker for terminal blocks, Strip, white, labeled, can be labeled with: CMS-P1-PLOTTER, Horizontal: U, V, W, N, GND, U, V, W, N, GND, mounting type: snap into tall marker groove, for terminal block width: 10.2 mm, lettering field size: 10.15 x 10.5 mm, Number of individual labels: 10

Marker for terminal blocks - UC-TM 10 CUS - 0824605



Marker for terminal blocks, can be ordered: by sheet, white, labeled according to customer specifications, mounting type: snap into tall marker groove, for terminal block width: 10.2 mm, lettering field size: 9.6 x 10.5 mm, Number of individual labels: 48

Marker for terminal blocks - UCT-TM 10 CUS - 0829623



Marker for terminal blocks, can be ordered: by sheet, white, labeled according to customer specifications, mounting type: snap into tall marker groove, for terminal block width: 10.2 mm, lettering field size: 8.9 x 9.6 mm, Number of individual labels: 36

Zack Marker strip, flat - ZBF10 CUS - 0825031



Zack Marker strip, flat, can be ordered: Strip, white, labeled according to customer specifications, mounting type: snap into flat marker groove, for terminal block width: 10 mm, lettering field size: 5.15 x 10 mm, Number of individual labels: 10



Accessories

Zack Marker strip, flat - ZBF10,LGS:FORTL.ZAHLEN - 0810009



Zack Marker strip, flat, Strip, white, labeled, printed horizontally: consecutive numbers 1 ... 10, 11 ... 20, etc. up to 91 ... 100, mounting type: snap into flat marker groove, for terminal block width: 10 mm, lettering field size: 5.15 x 10 mm, Number of individual labels: 10

Zack Marker strip, flat - ZBF10,QR:FORTL.ZAHLEN - 0810025



Zack Marker strip, flat, Strip, white, labeled, Printed vertically: consecutive numbers 1 ... 10, 11 ... 20, etc. up to 91 ... 100, mounting type: snap into flat marker groove, for terminal block width: 10 mm, lettering field size: 5.15 x 10 mm, Number of individual labels: 10

Marker for terminal blocks - UC-TMF 10 CUS - 0824662



Marker for terminal blocks, can be ordered: by sheet, white, labeled according to customer specifications, mounting type: snap into flat marker groove, for terminal block width: 10.2 mm, lettering field size: 9.6 x 5.1 mm, Number of individual labels: 48

Marker for terminal blocks - UCT-TMF 10 CUS - 0829679



Marker for terminal blocks, can be ordered: by sheet, white, labeled according to customer specifications, mounting type: snap into flat marker groove, for terminal block width: 10.2 mm, lettering field size: 9.4 x 4.7 mm, Number of individual labels: 36

Marker for terminal blocks - TMT 10 R CUS - 0824500



Marker for terminal blocks, can be ordered: by line, white, labeled according to customer specifications, mounting type: snap into universal marker groove, snap into flat marker groove, for terminal block width: 10.2 mm, lettering field size: 6.35 x 10.15 mm

Mounting material



Accessories

Flange cover - DF-PTMC-O - 3270400



Flange cover, for direct mounting on top and for accommodating the marking, length: 30 mm, width: 22 mm, height: 13 mm, color: gray

Flange cover - DF-PTMC-U - 3270401



Flange cover, for direct mounting below, length: 29.1 mm, width: 22 mm, height: 12.8 mm, color: gray

Adapter - DF-PTMC-NS - 3270403



Adapter, for mounting on a DIN rail, length: 64 mm, width: 22 mm, color: gray

Marker adapter - DF-PTMC-ZB - 3270410



Marker adapter, for direct mounting on top and for accommodating the marking, length: 30 mm, width: 11 mm, height: 13 mm, color: gray

Screwdriver tools

Screwdriver - SZF 0-0,4X2,5 - 1204504



Actuation tool, for ST terminal blocks, also suitable for use as a bladed screwdriver, size: $0.4 \times 2.5 \times 75$ mm, 2-component grip, with non-slip grip



Accessories

Actuation tool - ST-BW 0 - 1200135



Actuation tool, for all 1.5 mm² spring cages from PT 1,5/S and FT 1,5/S

Terminal marking

Zack marker strip - ZB 10:UNBEDRUCKT - 1053001



Zack marker strip, Strip, white, unlabeled, can be labeled with: PLOTMARK, CMS-P1-PLOTTER, mounting type: snap into tall marker groove, for terminal block width: 10.2 mm, lettering field size: 10.5 x 10.15 mm, Number of individual labels: 10

Marker for terminal blocks - UC-TM 10 - 0818069



Marker for terminal blocks, Sheet, white, unlabeled, can be labeled with: BLUEMARK ID COLOR, BLUEMARK ID, BLUEMARK CLED, PLOTMARK, CMS-P1-PLOTTER, mounting type: snap into tall marker groove, for terminal block width: 10.2 mm, lettering field size: 9.6 x 10.5 mm, Number of individual labels: 48

Marker for terminal blocks - UCT-TM 10 - 0829142



Marker for terminal blocks, Sheet, white, unlabeled, can be labeled with: TOPMARK NEO, TOPMARK LASER, BLUEMARK ID COLOR, BLUEMARK ID, BLUEMARK CLED, THERMOMARK PRIME, THERMOMARK CARD 2.0, THERMOMARK CARD, mounting type: snap into tall marker groove, for terminal block width: 10.2 mm, lettering field size: 8.9 x 9.6 mm, Number of individual labels: 36

Zack Marker strip, flat - ZBF10:UNBEDRUCKT - 0809997



Zack Marker strip, flat, Strip, white, unlabeled, can be labeled with: CMS-P1-PLOTTER, PLOTMARK, mounting type: snap into flat marker groove, for terminal block width: 10 mm, lettering field size: 5.15 x 10 mm, Number of individual labels: 10



Accessories

Marker for terminal blocks - UC-TMF 10 - 0818124



Marker for terminal blocks, Sheet, white, unlabeled, can be labeled with: BLUEMARK ID COLOR, BLUEMARK ID, BLUEMARK CLED, PLOTMARK, CMS-P1-PLOTTER, mounting type: snap into flat marker groove, for terminal block width: 10.2 mm, lettering field size: 9.6 x 5.1 mm, Number of individual labels: 48

Marker for terminal blocks - UCT-TMF 10 - 0829204



Marker for terminal blocks, Sheet, white, unlabeled, can be labeled with: TOPMARK NEO, TOPMARK LASER, BLUEMARK ID COLOR, BLUEMARK ID, BLUEMARK CLED, THERMOMARK PRIME, THERMOMARK CARD 2.0, THERMOMARK CARD, mounting type: snap into flat marker groove, for terminal block width: 10.2 mm, lettering field size: 9.4 x 4.7 mm, Number of individual labels: 36

Marker for terminal blocks - TMT 10 R - 0816210



Marker for terminal blocks, Roll, white, unlabeled, can be labeled with: THERMOMARK ROLL 2.0, THERMOMARK ROLL, THERMOMARK ROLL X1, THERMOMARK ROLLMASTER 300/600, THERMOMARK X1.2, THERMOMARK S1.1, perforated, mounting type: snap into universal marker groove, snap into flat marker groove, for terminal block width: 10.2 mm, lettering field size: 6.35 x 10.15 mm, Number of individual labels: 10000

Test plug terminal block

Reducing plug - RPS - 0201647



Reducing plug, color: gray

Test plugs - MPS-MT - 0201744



Test plugs, with solder connection up to 1 mm² conductor cross section, color: gray

Phoenix Contact 2020 © - all rights reserved http://www.phoenixcontact.com