#### **DATASHEET - VHI20-PKZ0**



## Auxiliary contact, operates as an early-make contact, 2N/O early

Powering Business Worldwide\*

Part no. VHI20-PKZ0
Catalog No. 203595
Alternate Catalog XTPAXFAEM20

No.

EL-Nummer 0004315166

(Norway)

## **Delivery program**

Product range	Accessories
Accessories	Auxiliary contacts, early-make
	For the premature voltage application of the U-release, e.g. in EMERGENCY STOP circuits according to EN 60204.
Contacts	
N/O = Normally open	2 N/O
Contact sequence	3.13 3.23 1 3.14 3.24
For use with	PKZ0(4) early-make auxiliary contacts
For use with	PKZM0 PKZM0-T PKM0 PKZM4
Notes Can be fitted to the front of: Motor protective circuit-breaker Cannot be combined with: PKZ0-X(R)H(-M),MSC and PKZM0-XM12	

# **Technical data**

$U_{imp}$	V AC	4000
		III/3
U <sub>e</sub>	V	
U <sub>e</sub>	V AC	440
U <sub>e</sub>	V DC	250
	V AC	690
l <sub>e</sub>	Α	
l <sub>e</sub>	Α	1
I <sub>e</sub>	Α	2
	S	
Operations	x 10 <sup>6</sup>	> 0.1
Operations	x 10 <sup>6</sup>	0.1
Failure rate	λ	$<10^{-8}, <$ one failure at 100 million operations (at Ue = 24 V DC, Umin = 17 V, Imin = 5.4 mA)
	A gG/gL	10
	mm <sup>2</sup>	0,75 - 1,5
	AWG	18 - 16
		E150
	U <sub>e</sub> U <sub>e</sub> U <sub>e</sub> U <sub>e</sub> I <sub>e</sub> I <sub>e</sub> Operations Operations	U <sub>e</sub> V U <sub>e</sub> V AC U <sub>e</sub> V DC  V AC I <sub>e</sub> A  I <sub>e</sub> A  Operations x 10 <sup>6</sup> Failure rate λ  A gG/gL  mm <sup>2</sup>

AC	V	300
AC	Α	0.5

# Design verification as per IEC/EN 61439

Dooign for moderon do por 120, 211 or 100			
Technical data for design verification			
Rated operational current for specified heat dissipation	In	Α	1
Heat dissipation per pole, current-dependent	P <sub>vid</sub>	W	0.03
Equipment heat dissipation, current-dependent	P <sub>vid</sub>	W	0
Static heat dissipation, non-current-dependent	P <sub>vs</sub>	W	0
Heat dissipation capacity	P <sub>diss</sub>	W	0
Operating ambient temperature min.	uiss	°C	-25
Operating ambient temperature max.		°C	55
IEC/EN 61439 design verification			
10.2 Strength of materials and parts			
10.2.2 Corrosion resistance			Meets the product standard's requirements.
10.2.3.1 Verification of thermal stability of enclosures			Meets the product standard's requirements.
10.2.3.2 Verification of resistance of insulating materials to normal heat			Meets the product standard's requirements.
10.2.3.3 Verification of resistance of insulating materials to abnormal heat and fire due to internal electric effects			Meets the product standard's requirements.
10.2.4 Resistance to ultra-violet (UV) radiation			Meets the product standard's requirements.
10.2.5 Lifting			Does not apply, since the entire switchgear needs to be evaluated.
10.2.6 Mechanical impact			Does not apply, since the entire switchgear needs to be evaluated.
10.2.7 Inscriptions			Meets the product standard's requirements.
10.3 Degree of protection of ASSEMBLIES			Does not apply, since the entire switchgear needs to be evaluated.
10.4 Clearances and creepage distances			Meets the product standard's requirements.
10.5 Protection against electric shock			Does not apply, since the entire switchgear needs to be evaluated.
10.6 Incorporation of switching devices and components			Does not apply, since the entire switchgear needs to be evaluated.
10.7 Internal electrical circuits and connections			Is the panel builder's responsibility.
10.8 Connections for external conductors			Is the panel builder's responsibility.
10.9 Insulation properties			
10.9.2 Power-frequency electric strength			Is the panel builder's responsibility.
10.9.3 Impulse withstand voltage			Is the panel builder's responsibility.
10.9.4 Testing of enclosures made of insulating material			Is the panel builder's responsibility.
10.10 Temperature rise			The panel builder is responsible for the temperature rise calculation. Eaton will provide heat dissipation data for the devices.
10.11 Short-circuit rating			Is the panel builder's responsibility. The specifications for the switchgear must be observed.
10.12 Electromagnetic compatibility			Is the panel builder's responsibility. The specifications for the switch gear must be observed. $\label{eq:specification}$
10.13 Mechanical function			The device meets the requirements, provided the information in the instruction leaflet (IL) is observed.
			observed.  The device meets the requirements, provided the information in the instruc

# Technical data ETIM 7.0

Low-voltage industrial components (EG000017) / Auxiliary contact block (EC000041)			
Electric engineering, automation, process control engineering / Low-voltage switch technology / Component for low-voltage switching technology / Auxiliary switch block (ecl@ss10.0.1-27-37-13-02 [AKN342013])			
Number of contacts as change-over contact			0
Number of contacts as normally open contact			2
Number of contacts as normally closed contact			0
Number of fault-signal switches			0
Rated operation current le at AC-15, 230 V		Α	1
Type of electric connection			Screw connection
Model			Top mounting
Mounting method			Front fastening
Lamp holder			None

# Approvals Product Standards UL 508; CSA-C22.2 No. 14; IEC60947-4-1; CE marking UL File No. E36332 UL Category Control No. NLRV CSA File No. 165628 CSA Class No. 3211-05


UL listed, CSA certified

No

## **Dimensions**

North America Certification

Specially designed for North America



## **Additional product information (links)**

IL03402033Z (AWA1210-1659) Early-make auxiliary contact		
IL03402033Z (AWA1210-1659) Early-make auxiliary contact	ftp://ftp.moeller.net/DOCUMENTATION/AWA_INSTRUCTIONS/IL03402033Z2018_05.pdf	
Motor starters and "Special Purpose Ratings" for the North American market	http://www.eaton.eu/ecm/groups/public/@pub/@europe/@electrical/documents/content/pct_3258146.pdf	
Busbar Component Adapters for modern Industrial control panels	http://www.moeller.net/binary/ver_techpapers/ver960en.pdf	