Main switch, T5, 100 A, rear mounting, 4 contact unit(s), 6 pole, 1 N/O, 1 N/C, Emergency switching off function, With red rotary handle and yellow locking ring, Lockable in the 0 (Off) position



Part no. T5-4-15682/V/SVB 207415

eneral specifications	
Product name	Eaton Moeller® series T5 Main switch
Part no.	T5-4-15682/V/SVB
EAN	4015082074159
Product Length/Depth	188 millimetre
Product height	88 millimetre
Product width	88 millimetre
Product weight	0.795 kilogram
Certifications	IEC/EN 60947 IEC/EN 60204 VDE 0660 IEC/EN 60947-3
Product Tradename	Т5
Product Type	Main switch
Product Sub Type	None
Catalog Notes	Rated Short-time Withstand Current (Icw) for a time of 1 second
eatures & Functions	
Features	Version as maintenance-/service switch Version as main switch Version as emergency stop installation
Fitted with:	Red rotary handle and yellow locking ring
Functions	Interlockable Emergency switching off function
Locking facility	Lockable in the 0 (Off) position
Number of poles	6
eneral information	
Degree of protection	NEMA 12
Degree of protection (front side)	IP65
Lifespan, mechanical	500,000 Operations
Mounting method	Rear mounting
Mounting position	As required
Number of contact units	4
Operating frequency	1200 Operations/h
Overvoltage category	III
Pollution degree	3
Rated impulse withstand voltage (Uimp)	6000 V AC
Safe isolation	440 V AC, Between the contacts, According to EN 61140
Safety parameter (EN ISO 13849-1)	B10d values as per EN ISO 13849-1, table C.1
Shock resistance	15 g, Mechanical, According to IEC/EN 60068-2-27, Half-sinusoidal shock 20 ms
Suitable for	Intermediate mounting Ground mounting
Switching angle	90 °
limatic environmental conditions	
Ambient operating temperature - min	-25 °C
Ambient operating temperature - max	50 °C
Ambient operating temperature (enclosed) - min	-25 °C
Ambient operating temperature (enclosed) - max	40 °C
Climatic proofing	Damp heat, constant, to IEC 60068-2-78 Damp heat, cyclic, to IEC 60068-2-30
Ferminal capacities	53mp 11584 5 1 5 1 5 1 5 1 5 1 5 1 5 1 5 1 5 1 5

Terminal capacity	1 x (2.5 - 35) mm², solid or stranded 2 x (2.5 - 16) mm², solid or stranded 1 x (1 - 25) mm², flexible with ferrules to DIN 46228 2 x (1.5 - 10) mm², flexible with ferrule to DIN 46228
Screw size	M6, Terminal screw
Tightening torque	35.4 lb-in, Screw terminals 4 Nm, Screw terminals
Electrical rating	
Rated breaking capacity at 220/230 V (cos phi to IEC 60947-3)	760 A
Rated breaking capacity at 400/415 V (cos phi to IEC 60947-3)	740 A
Rated breaking capacity at 500 V (cos phi to IEC 60947-3)	590 A
Rated breaking capacity at 660/690 V (cos phi to IEC 60947-3)	420 A
Rated operational current (le) at AC-3, 220 V, 230 V, 240 V	71 A
Rated operational current (le) at AC-3, 380 V, 400 V, 415 V	55 A
Rated operational current (le) at AC-3, 500 V	44 A
Rated operational current (le) at AC-3, 660 V, 690 V	17 A
Rated operational current (le) at AC-21, 440 V	100 A
Rated operational current (Ie) at AC-23A, 230 V	100 A
Rated operational current (le) at AC-23A, 400 V, 415 V	100 A
Rated operational current (le) at AC-23A, 500 V	55 A
Rated operational current (le) at AC-23A, 690 V	32 A
Rated operational current (le) at DC-1, load-break switches I/r = 1 ms	80 A
Rated operational current (le) star-delta at AC-3, 220/230 V	100 A
Rated operational current (le) star-delta at AC-3, 380/400 V	95.3 A
Rated operational current (le) star-delta at AC-3, 500 V	76.2 A
Rated operational current (le) star-delta at AC-3, 690 V	29.4 A
Rated operational power at AC-3, 380/400 V, 50 Hz	30 kW
Rated operational power at AC-3, 415 V, 50 Hz	30 kW
Rated operational power at AC-3, 500 V, 50 Hz	30 kW
Rated operational power at AC-3, 690 V, 50 Hz	15 kW
Rated operational power at AC-23A, 220/230 V, 50 Hz	30 kW
Rated operational power at AC-23A, 400 V, 50 Hz	55 kW
Rated operational power at AC-23A, 500 V, 50 Hz	37 kW
Rated operational power at AC-23A, 690 V, 50 Hz	30 kW
Rated operational power star-delta at 220/230 V, 50 Hz	30 kW
Rated operational power star-delta at 380/400 V, 50 Hz	45 kW
Rated operational power star-delta at 500 V, 50 Hz	45 kW
Rated operational power star-delta at 690 V, 50 Hz	22 kW
Rated uninterrupted current (Iu)	100 A
Uninterrupted current	Rated uninterrupted current lu is specified for max. cross-section.
Short-circuit rating	
Rated conditional short-circuit current (Ig)	2 kA
Rated short-time withstand current (Icw)	1,7 kA, Contacts, 1 second 1.7 kA
Short-circuit protection rating	100 A gG/gL, Fuse, Contacts
Switching capacity	
Load rating	2 x I# (with intermittent operation class 12, 25 % duty factor) 1.6 x I# (with intermittent operation class 12, 40 % duty factor) 1.3 x I# (with intermittent operation class 12, 60 % duty factor)
Switching capacity (main contacts, general use)	63 A, Rated uninterrupted current max. (UL/CSA)
Rated making capacity up to 690 V (cos phi to IEC/EN 60947-3)	950 A
Voltage per contact pair in series	60 V
Contacts	
Control circuit reliability	1 failure per 100,000 switching operations statistically determined, at 24 V DC, 10 mA)
Number of auxiliary contacts (change-over contacts)	0
Number of auxiliary contacts (normally closed contacts)	1
Number of auxiliary contacts (normally open contacts)	1

observed.	Actuator	
Design verification Equipment heat dissipation, current-dependent Pvid 7.5 W Heat dissipation capacity Pdiss 0W Heat dissipation capacity Pdiss 0W Heat dissipation per pole, current-dependent Pvid 7.5 W Heat dissipation per pole, current-dependent Pvid 7.5 W Rated operational current for specified heat dissipation (In) 100 A Static heat dissipation, non-current-dependent Pvs 0W 10.22 Corrosion resistance 10.23.1 Verification of thermal stability of enclosures Meets the product standard's requirements. 10.23.2 Verification of tremal stability of enclosures Meets the product standard's requirements. 10.23.3 Verification of resistance of line sulating materials to normal heat Meets the product standard's requirements. 10.24.4 Resistance to ultra-violet (IV)? radiation W/ resistance environments. 10.24.8 Resistance to ultra-violet (IV)? radiation W/ resistance only in connection with protective shield. 10.25 Lifting Does not apply, since the entire switchgear needs to be evaluated. 10.27 Inscriptions Meets the product standard's requirements. 10.3 Degree of protection of assemblies Does not apply, since the entire switchgear needs to be evaluated. 10.4 Clearances and creepage distances Meets the product standard's requirements. 10.5 Protection against electric shock Does not apply, since the entire switchgear needs to be evaluated. 10.6 Incorporation of switching devices and components Does not apply, since the entire switchgear needs to be evaluated. 10.7 Internal electrical circuits and connections Is the panel builder's responsibility. 10.9 Power-frequency electric strength Is the panel builder's responsibility. 10.9 Power-frequency electric strength Is the panel builder's responsibility. 10.9 Power-frequency electric strength Is the panel builder's responsibility. 10.9 Power-frequency electric strength Is the panel builder's responsibility. 10.9 Power-frequency electric strength Is the panel builder's responsibility. 10.9 Power-frequency electric strength Is the panel builder's responsibility. 10.9 Power-frequ	Actuator color	Red
Equipment heat dissipation, current-dependent Pvid Heat dissipation capacity Pdiss 0 W Rated operational current for specified heat dissipation (In) Static heat dissipation, non-current-dependent Pvid Rated operational current for specified heat dissipation (In) 100 A Static heat dissipation, non-current-dependent Pvs 102.2 Corrosion resistance Meets the product standard's requirements. 102.3.1 Verification of thermal stability of enclosures Meets the product standard's requirements. 102.3.2 Verification of resistance of insulating materials to normal heat 102.3.3 Resist. of insul. mat. to abnormal heat/fire by internal elect. effects Meets the product standard's requirements. 102.4 Resistance to ultra-violet (UV) radiation 102.5 Liffing Does not apply, since the entire switchgear needs to be evaluated. 102.5 Internal stability of account of assemblies 102.4 Rechanical impact 102.6 Mechanical impact 103.0 Degree of protection of assemblies 104.0 Colorances and creepage distances Meets the product standard's requirements. 105.1 Protection against electric shock 106.1 Incorporation of switching devices and components 107.1 Internal electrical circuits and connections Is the panel builder's responsibility. 108.2 Power-frequency electric strength 109.4 Testing of enclosures made of insulating material 109.4 Testing of enclosures made of insulating material 109.5 Testing of enclosures made of insulating material 109.6 Testing of enclosures made of insulating material 109.6 Testing of enclosures made of insulating material 109.7 Testing of enclosures made of insulating material 109.8 Testing of enclosures made of insulating material 109.9 Testing of enclosures made of insulating material 109.1 Testing of enclosures made of insulating material 109.1 Testing of enclosures made of insulating material 109.2 Fower-frequency electric strength 109.3 Testing of enclosures made of insulating material 109.4 Testing of enclosures made of insulating material 109.5 Testing of enclosures m	Actuator type	Door coupling rotary drive
Heat dissipation capacity Pdiss Heat dissipation per pole, current-dependent Pvid 7.5 W Rated operational current for specified heat dissipation (In) 100 A Static heat dissipation, non-current-dependent Pvs 0 W Meets the product standard's requirements. 10.2.3.1 Verification of thermal stability of enclosures Meets the product standard's requirements. 10.2.3.2 Verification of the sistance of insulating materials to normal heat 10.2.3.3 Resist. of insul. mat. to abnormal heat/fire by internal elect. effects 10.2.4 Resistance to ultra-violet (UV) radiation 10.2.5 Lifting 10.2.6 Mechanical impact 10.2.6 Mechanical impact 10.2.7 Inscriptions Meets the product standard's requirements. 10.3 Degree of protection of assemblies 10.4 Clearances and creepage distances Meets the product standard's requirements. 10.5 Protection against electric shock 10.6 Incorporation of switching devices and components 10.7 Internal electrical circuits and components 10.7 Internal electrical circuits and components 10.9 Power-frequency electric strength 10.9 Power-frequency electric strength 10.9 Power-frequency electric strength 10.9 Power-frequency electric strength 10.9 Internal electrical circuits and of insulating material 10.10 Themperature rise 10.11 Short-circuit rating 10.12 Electromagnetic compatibility 10.15 Hop panel builder's responsibility. 10.16 Internal electrical circuits and of insulating material 10.17 Electromagnetic compatibility 10.18 Lectromagnetic compatibility 10.19 Electromagnetic compatibility 10.19 Electromagnetic compatibility 10.19 Electromagnetic compatibility 10.10 Mechanical function The device meets the requirements, provided the information in the instruction	Design verification	
Heat dissipation per pole, current-dependent Pvid Rated operational current for specified heat dissipation (In) Static heat dissipation, non-current-dependent Pvs 0W Meets the product standard's requirements. 10.2.3 I Verification of thermal stability of enclosures Meets the product standard's requirements. 10.2.3 Verification of resistance of insulating materials to normal heat 10.2.3 Verification of resistance of insulating materials to normal heat 10.2.3 I Verification of resistance of insulating materials to normal heat 10.2.3 Resistance to ultra-violet (UV) radiation 10.2.4 Resistance to ultra-violet (UV) radiation 10.2.5 Lifting 10.2.5 Lifting 10.2.6 Mechanical impact 10.2.7 Inscriptions Meets the product standard's requirements. 10.3 Degree of protection of assemblies 10.4 Clearances and creepage distances 10.5 Protection against electric shock 10.6 Incorporation of switching devices and components 10.6 Incorporation of switching devices and components 10.7 Internal electrical circuits and connections 10.8 Connections for external conductors 10.9 Impulse withstand voltage 10.10 Temperature rise The panel builder's responsibility. 10.10 Temperature rise The panel builder's responsibility. 10.10 Temperature rise The panel builder's responsibility. 10.11 Short-circuit rating 10.13 Mechanical function The device meets the requirements, provided the information in the instruction observed.	Equipment heat dissipation, current-dependent Pvid	7.5 W
Rated operational current for specified heat dissipation (In) Static heat dissipation, non-current-dependent Pvs 0 W 10.22 Corrosion resistance Meets the product standard's requirements. 10.2.3.1 Verification of thermal stability of enclosures Meets the product standard's requirements. 10.2.3.2 Verification of resistance of insulating materials to normal heat 10.2.3.3 Resist. of insul. mat. to abnormal heat/fire by internal elect. effects Meets the product standard's requirements. 10.2.4 Resistance to ultra-violat (UV) radiation 10.2.5 Lifting Does not apply, since the entire switchgear needs to be evaluated. 10.2.7 Inscriptions Does not apply, since the entire switchgear needs to be evaluated. 10.3 Degree of protection of assemblies Does not apply, since the entire switchgear needs to be evaluated. 10.4 Clearances and creepage distances Meets the product standard's requirements. 10.5 Frotection against electric shock Does not apply, since the entire switchgear needs to be evaluated. 10.6 Incorporation of switching devices and components Does not apply, since the entire switchgear needs to be evaluated. 10.7 Internal electrical circuits and connections Is the panel builder's responsibility. 10.8 Connections for external conductors Is the panel builder's responsibility. 10.9.4 Testing of enclosures made of insulating material 10.10 Temperature rise The panel builder's responsibility. 10.11 Short-circuit rating Is the panel builder's responsibility. 10.12 Electromagnetic compatibility Is the panel builder's responsibility. The specifications for the switchgear must be observed. 10.13 Mechanical function The device meets the requirements, provided the information in the instruction	Heat dissipation capacity Pdiss	0 W
Static heat dissipation, non-current-dependent Pvs 10.2.2 Corrosion resistance 10.2.3.1 Verification of thermal stability of enclosures Meets the product standard's requirements. 10.2.3.2 Verification of resistance of insulating materials to normal heat 10.2.3.3 Resist of insul. mat. to abnormal heatfire by internal elect. effects 10.2.4 Resistance to ultra-violet (UV) radiation 10.2.5 Lifting 10.2.5 Lifting 10.2.6 Mechanical impact 10.2.7 Inscriptions 10.2.8 Mechanical of assemblies 10.3 Degree of protection of assemblies 10.4 Clearances and creepage distances 10.4 Clearances and creepage distances 10.5 Protection against electric shock 10.6 Incorporation of switching devices and components 10.7 Internal electrical circuits and connections 10.8 Connections for external conductors 10.9 Power-frequency electric strength 10.9.4 Testing of enclosures made of insulating material 10.10 Temperature rise 10.11 Short-circuit rating 10.12 Electromagnetic compatibility 10.13 Mechanical function 10.13 Mechanical function 10.14 Mechanical function 10.15 Mechanical function 10.16 Mechanical function 10.17 Leterorements 10.18 Leterorements 10.19 Power-frequency electric strength 10.10 Temperature rise 10.11 Short-circuit rating 10.12 Electromagnetic compatibility 10.13 Mechanical function 10.13 Mechanical function 10.14 Mechanical function 10.15 Mechanical function 10.16 Mechanical function 10.17 Meets the product standard's requirements. 10.18 Meats the product standard's requirements. 10.19 Des not apply, since the entire switchgear needs to be evaluated. 10.10 Temperature rise 10.11 Short-circuit rating 10.12 Electromagnetic compatibility 10.13 Mechanical function 10.14 Mechanical function 10.15 Mechanical function 10.16 Meets the product standard's requirements. 10.17 Meets the product standard's requirements. 10.18 Meets the product standard's requirements. 10.19 Meets the product standard's requirements. 10.10 Meets the product standard's requirements. 10.11 Short-c	Heat dissipation per pole, current-dependent Pvid	7.5 W
Meets the product standard's requirements. 10.2.3.1 Verification of thermal stability of enclosures Meets the product standard's requirements. 10.2.3.2 Verification of resistance of insulating materials to normal heat Meets the product standard's requirements. 10.2.3 Resists of insul. mat. to abnormal heat/fire by internal elect. effects Meets the product standard's requirements. 10.2.4 Resistance to ultra-violet (UV) radiation UV resistance only in connection with protective shield. 10.2.5 Lifting Does not apply, since the entire switchgear needs to be evaluated. 10.2.7 Inscriptions Meets the product standard's requirements. 10.3 Degree of protection of assemblies Does not apply, since the entire switchgear needs to be evaluated. 10.4 Clearances and creepage distances Meets the product standard's requirements. 10.5 Protection against electric shock Does not apply, since the entire switchgear needs to be evaluated. 10.6 Incorporation of switching devices and components 10.6 Incorporation of switching devices and components 10.7 Internal electrical circuits and connections Is the panel builder's responsibility. 10.8 Connections for external conductors Is the panel builder's responsibility. 10.9.2 Power-frequency electric strength Is the panel builder's responsibility. 10.9.4 Testing of enclosures made of insulating material Is the panel builder's responsibility. 10.10 Temperature rise The panel builder's responsibility. The specifications for the switchgear must be observed. 10.11 Short-circuit rating Is the panel builder's responsibility. The specifications for the switchgear must be observed. 10.12 Electromagnetic compatibility Is the panel builder's responsibility. The specifications for the switchgear must be observed. 10.13 Mechanical function The device meets the requirements, provided the information in the instruction	Rated operational current for specified heat dissipation (In)	100 A
10.2.3.1 Verification of thermal stability of enclosures 10.23.2 Verification of resistance of insulating materials to normal heat 10.2.3 Resist. of insul. mat. to abnormal heat/fire by internal elect. effects 10.2.4 Resistance to ultra-violet (UV) radiation 10.2.5 Lifting 10.2.5 Lifting 10.2.6 Mechanical impact 10.2.7 Inscriptions 10.3 Degree of protection of assemblies 10.3 Degree of protection of assemblies 10.4 Clearances and creepage distances 10.5 Protection against electric shock 10.6 Incorporation of switching devices and components 10.7 Internal electrical circuits and connections 10.8 Connections for external conductors 10.9 Power-frequency electric strength 10.9.1 Degree of insulating material 10.9.2 Power-frequency electric strength 10.9.3 Impulse withstand voltage 10.9.4 Testing of enclosures made of insulating material 10.10 Temperature rise 10.11 Short-circuit rating 10.12 Electromagnetic compatibility 10.13 Mechanical function 10.13 Mechanical function 10.13 Mechanical function 10.13 Mechanical function 10.14 Mechanical function 10.15 Medianical function 10.16 Internal electric strength 10.17 Internal electrical circuits and connections 10.18 Lepanel builder's responsibility. 10.29 Power-frequency electric strength 10.19 Lepanel builder's responsibility. 10.20 Lepanel builder's responsibility. 10.30 Lepanel builder's responsibility. 10.40 Lepanel builder's responsibility. 10.50 Lepanel builder's responsibility. 10.60 Lepanel builder's responsibility. 10.70 Lepanel builder's responsibil	Static heat dissipation, non-current-dependent Pvs	0 W
10.2.3.2 Verification of resistance of insulating materials to normal heat 10.2.3.3 Resist. of insul. mat. to abnormal heat/fire by internal elect. effects 10.2.4 Resistance to ultra-violet (UV) radiation 10.2.5 Lifting 10.2.6 Mechanical impact 10.2.7 Inscriptions 10.3 Degree of protection of assemblies 10.4 Clearances and creepage distances 10.5 Protection against electric shock 10.6 Incorporation of switching devices and components 10.7 Internal electrical circuits and connections 10.8 Connections for external conductors 10.9 Power-frequency electric strength 10.9 Power-frequency electric strength 10.9 Testing of enclosures made of insulating material 10.10 Temperature rise 10.11 Short-circuit rating 10.12 Electromagnetic compatibility 10.13 Mechanical function 10.13 Mechanical function 10.14 Mechanical function 10.13 Mechanical function 10.15 Medes the product standard's requirements. 10.16 Lord of insulating material 10.17 Internal electrical circuits and connections 10.18 the panel builder's responsibility. 10.19 Temperature rise 10.10 Temperature rise 10.11 Short-circuit rating 10.12 Electromagnetic compatibility 10.13 Mechanical function 10.13 Mechanical function 10.14 Mechanical function 10.15 Mechanical function 10.16 Meeting devices meets the requirements. 10.17 Meeting device meets the requirements. 10.18 Mechanical function 10.19 Meeting devices in suitang material 10.10 Temperature rise 10.11 Short-circuit rating 10.12 Electromagnetic compatibility 10.13 Mechanical function 10.14 Mechanical function	10.2.2 Corrosion resistance	Meets the product standard's requirements.
10.2.3. Resist. of insul. mat. to abnormal heat/fire by internal elect. effects 10.2.4 Resistance to ultra-violet (UV) radiation 10.2.5 Lifting 10.2.6 Mechanical impact 10.2.6 Mechanical impact 10.2.7 Inscriptions 10.3 Degree of protection of assemblies 10.3 Degree of protection of assemblies 10.4 Clearances and creepage distances 10.5 Protection against electric shock 10.6 Incorporation of switching devices and components 10.7 Internal electrical circuits and connections 10.8 Connections for external conductors 10.9 Power-frequency electric strength 10.9.1 Testing of enclosures made of insulating material 10.10 Temperature rise 10.11 Short-circuit rating 10.12 Electromagnetic compatibility 10.13 Mechanical function 10.13 Mechanical function 10.13 Mechanical function 11.15 Mechanical fun	10.2.3.1 Verification of thermal stability of enclosures	Meets the product standard's requirements.
10.2.4 Resistance to ultra-violet (UV) radiation 10.2.5 Lifting 10.2.6 Mechanical impact 10.2.6 Mechanical impact 10.2.7 Inscriptions 10.3 Degree of protection of assemblies 10.4 Clearances and creepage distances 10.5 Protection against electric shock 10.6 Incorporation of switching devices and components 10.7 Internal electrical circuits and connections 10.8 Connections for external conductors 10.9.2 Power-frequency electric strength 10.9.3 Impulse withstand voltage 10.9.1 Testing of enclosures made of insulating material 10.10 Temperature rise 10.11 Short-circuit rating 10.12 Electromagnetic compatibility 10.13 Mechanical function 10.13 Mechanical function 10.14 Clearances and creepage distances 10.25 Protection against electric switchgear needs to be evaluated. 10.4 Clearances and creepage distances 10.5 Protection against electric shock 10.6 Incorporation of switching devices and components 10.6 Incorporation of switching devices and components 10.6 Incorporation of switching devices and components 10.8 Connections for external conductors 10.9 Power-frequency electric strength 10.9 Is the panel builder's responsibility. 10.9 Power-frequency electric strength 10.10 Temperature rise 10.10 Temperature rise 10.11 Short-circuit rating 10.12 Electromagnetic compatibility 10.13 Mechanical function 10.13 Mechanical function 10.14 Mechanical function 10.15 Mechanical function 10.16 Incorporation of with product standard's requirements, provided the information in the instruction	10.2.3.2 Verification of resistance of insulating materials to normal heat	Meets the product standard's requirements.
10.2.5 Lifting Does not apply, since the entire switchgear needs to be evaluated. 10.2.6 Mechanical impact Does not apply, since the entire switchgear needs to be evaluated. 10.2.7 Inscriptions Meets the product standard's requirements. 10.3 Degree of protection of assemblies Does not apply, since the entire switchgear needs to be evaluated. 10.4 Clearances and creepage distances Meets the product standard's requirements. 10.5 Protection against electric shock Does not apply, since the entire switchgear needs to be evaluated. 10.6 Incorporation of switching devices and components Does not apply, since the entire switchgear needs to be evaluated. 10.7 Internal electrical circuits and connections Is the panel builder's responsibility. 10.9.2 Power-frequency electric strength Is the panel builder's responsibility. 10.9.3 Impulse withstand voltage Is the panel builder's responsibility. 10.10 Temperature rise The panel builder is responsibility. 10.11 Short-circuit rating Is the panel builder's responsibility. The specifications for the switchgear must be observed. 10.12 Electromagnetic compatibility Is the panel builder's responsibility. The specifications for the switchgear must be observed. 10.13 Mechanical function The device meets the requirements, provided the information in the instruction	10.2.3.3 Resist. of insul. mat. to abnormal heat/fire by internal elect. effects	Meets the product standard's requirements.
10.26 Mechanical impact 10.27 Inscriptions Meets the product standard's requirements. 10.3 Degree of protection of assemblies 10.4 Clearances and creepage distances Meets the product standard's requirements. 10.5 Protection against electric shock Does not apply, since the entire switchgear needs to be evaluated. 10.6 Incorporation of switching devices and components Does not apply, since the entire switchgear needs to be evaluated. 10.7 Internal electrical circuits and connections Is the panel builder's responsibility. 10.8 Connections for external conductors Is the panel builder's responsibility. 10.9.2 Power-frequency electric strength Is the panel builder's responsibility. 10.9.3 Impulse withstand voltage Is the panel builder's responsibility. 10.10 Temperature rise The panel builder's responsibility. 10.10 Temperature rise The panel builder's responsibility. 10.11 Short-circuit rating Is the panel builder's responsibility. The specifications for the switchgear must be observed. 10.12 Electromagnetic compatibility 10.13 Mechanical function The device meets the requirements, provided the information in the instruction	10.2.4 Resistance to ultra-violet (UV) radiation	UV resistance only in connection with protective shield.
10.27 Inscriptions Meets the product standard's requirements. 10.3 Degree of protection of assemblies Does not apply, since the entire switchgear needs to be evaluated. 10.4 Clearances and creepage distances Meets the product standard's requirements. 10.5 Protection against electric shock Does not apply, since the entire switchgear needs to be evaluated. 10.6 Incorporation of switching devices and components Does not apply, since the entire switchgear needs to be evaluated. 10.7 Internal electrical circuits and connections Is the panel builder's responsibility. 10.8 Connections for external conductors Is the panel builder's responsibility. 10.9.2 Power-frequency electric strength Is the panel builder's responsibility. 10.9.3 Impulse withstand voltage Is the panel builder's responsibility. 10.10 Temperature rise The panel builder's responsibility. 10.10 Temperature rise The panel builder is responsibility. The specifications for the switchgear must be observed. 10.11 Short-circuit rating Is the panel builder's responsibility. The specifications for the switchgear must be observed. 10.12 Electromagnetic compatibility The device meets the requirements, provided the information in the instruction	10.2.5 Lifting	Does not apply, since the entire switchgear needs to be evaluated.
10.3 Degree of protection of assemblies Does not apply, since the entire switchgear needs to be evaluated. 10.4 Clearances and creepage distances Meets the product standard's requirements. 10.5 Protection against electric shock Does not apply, since the entire switchgear needs to be evaluated. 10.6 Incorporation of switching devices and components Does not apply, since the entire switchgear needs to be evaluated. 10.7 Internal electrical circuits and connections Is the panel builder's responsibility. 10.8 Connections for external conductors Is the panel builder's responsibility. 10.9.1 Power-frequency electric strength Is the panel builder's responsibility. 10.9.2 Fower-frequency electric strength Is the panel builder's responsibility. 10.9.3 Impulse withstand voltage Is the panel builder's responsibility. 10.10 Temperature rise The panel builder's responsibility. 10.11 Short-circuit rating Is the panel builder's responsibility. 10.12 Electromagnetic compatibility Is the panel builder's responsibility. The specifications for the switchgear must be observed. 10.13 Mechanical function The device meets the requirements, provided the information in the instruction	10.2.6 Mechanical impact	Does not apply, since the entire switchgear needs to be evaluated.
Meets the product standard's requirements. 10.5 Protection against electric shock 10.6 Incorporation of switching devices and components 10.7 Internal electrical circuits and connections 10.8 Connections for external conductors 10.9.2 Power-frequency electric strength 10.9.3 Impulse withstand voltage 10.9.4 Testing of enclosures made of insulating material 10.10 Temperature rise 10.11 Short-circuit rating 10.12 Electromagnetic compatibility 10.13 Mechanical function Meets the product standard's requirements. Does not apply, since the entire switchgear needs to be evaluated. 10 Does not apply, since the entire switchgear needs to be evaluated. Is the panel builder's responsibility. Is the panel builder's responsibility. Is the panel builder's responsibility. The panel builder's responsibility. Is the panel builder is responsibility. Is the panel builder's responsibility. The panel builder's responsibility. The specifications for the switchgear must be observed. 10.13 Mechanical function The device meets the requirements, provided the information in the instruction	10.2.7 Inscriptions	Meets the product standard's requirements.
10.5 Protection against electric shock 10.6 Incorporation of switching devices and components 10.7 Internal electrical circuits and connections 10.8 Connections for external conductors 10.9.2 Power-frequency electric strength 10.9.3 Impulse withstand voltage 10.9.4 Testing of enclosures made of insulating material 10.10 Temperature rise 10.11 Short-circuit rating 10.12 Electromagnetic compatibility 10.13 Mechanical function Does not apply, since the entire switchgear needs to be evaluated. Does not apply, since the entire switchgear needs to be evaluated. Does not apply, since the entire switchgear needs to be evaluated. Does not apply, since the entire switchgear needs to be evaluated. Does not apply, since the entire switchgear needs to be evaluated. Is the panel builder's responsibility. Is the panel builder's responsibility. Is the panel builder is responsibility. The panel builder is responsibility. The specifications for the switchgear must be observed. Is the panel builder's responsibility. The specifications for the switchgear must be observed. Is the panel builder's responsibility. The specifications for the switchgear must be observed. The device meets the requirements, provided the information in the instruction	10.3 Degree of protection of assemblies	Does not apply, since the entire switchgear needs to be evaluated.
10.6 Incorporation of switching devices and components 10.7 Internal electrical circuits and connections 10.8 Connections for external conductors 10.9.2 Power-frequency electric strength 10.9.3 Impulse withstand voltage 10.9.4 Testing of enclosures made of insulating material 10.10 Temperature rise 10.11 Short-circuit rating 10.12 Electromagnetic compatibility 10.13 Mechanical function 10.14 Mechanical function 10.15 Internal electrical circuits and connections 10.16 Is the panel builder's responsibility. 10.17 Is the panel builder's responsibility. 10.18 Is the panel builder is responsibility. 10.19 Is the panel builder is responsibility. 10.10 Temperature rise 10.11 Short-circuit rating 10.12 Electromagnetic compatibility 10.13 Mechanical function 10.14 Is the panel builder's responsibility. The specifications for the switchgear must be observed. 10.15 The device meets the requirements, provided the information in the instruction	10.4 Clearances and creepage distances	Meets the product standard's requirements.
10.7 Internal electrical circuits and connections 1s the panel builder's responsibility. 10.8 Connections for external conductors 1s the panel builder's responsibility. 10.9.2 Power-frequency electric strength 1s the panel builder's responsibility. 10.9.3 Impulse withstand voltage 1s the panel builder's responsibility. 1o.9.4 Testing of enclosures made of insulating material 1s the panel builder's responsibility. 1o.10 Temperature rise The panel builder is responsibile for the temperature rise calculation. Eaton will provide heat dissipation data for the devices. 1o.11 Short-circuit rating Is the panel builder's responsibility. The specifications for the switchgear must be observed. 1o.12 Electromagnetic compatibility Is the panel builder's responsibility. The specifications for the switchgear must be observed. 1o.13 Mechanical function The device meets the requirements, provided the information in the instruction	10.5 Protection against electric shock	Does not apply, since the entire switchgear needs to be evaluated.
10.8 Connections for external conductors 10.9.2 Power-frequency electric strength 10.9.3 Impulse withstand voltage 10.9.4 Testing of enclosures made of insulating material 10.10 Temperature rise 10.11 Short-circuit rating 10.12 Electromagnetic compatibility 10.13 Mechanical function 10.13 Mechanical function 10.14 Strength builder's responsibility. 11.15 Is the panel builder's responsibility. 12.16 Is the panel builder is responsibility. 13.17 Is the panel builder is responsibility. 14.18 Is the panel builder is responsibility. 15.19 Is the panel builder's responsibility. The specifications for the switchgear must be observed. 16.19 Is the panel builder's responsibility. The specifications for the switchgear must be observed. 17.19 Is the panel builder's responsibility. The specifications for the switchgear must be observed. 18.10 Is the panel builder's responsibility. The specifications for the switchgear must be observed. 19.10 Is the panel builder's responsibility. The specifications for the switchgear must be observed. 10.11 Short-circuit rating 10.12 Electromagnetic compatibility 10.13 Mechanical function 10.14 Is the panel builder's responsibility. The specifications for the switchgear must be observed.	10.6 Incorporation of switching devices and components	Does not apply, since the entire switchgear needs to be evaluated.
10.9.2 Power-frequency electric strength 10.9.3 Impulse withstand voltage 10.9.4 Testing of enclosures made of insulating material 10.10 Temperature rise 10.11 Short-circuit rating 10.12 Electromagnetic compatibility 10.13 Mechanical function 10.13 Mechanical function 10.14 Is the panel builder's responsibility. The specifications for the switchgear must be observed. 10.15 The panel builder's responsibility. The specifications for the switchgear must be observed. 10.15 The panel builder's responsibility. The specifications for the switchgear must be observed. 10.16 The panel builder's responsibility. The specifications for the switchgear must be observed. 10.17 The device meets the requirements, provided the information in the instruction	10.7 Internal electrical circuits and connections	Is the panel builder's responsibility.
10.9.3 Impulse withstand voltage 10.9.4 Testing of enclosures made of insulating material 10.10 Temperature rise 10.11 Short-circuit rating 10.12 Electromagnetic compatibility 10.13 Mechanical function 10.13 Mechanical function Is the panel builder's responsibility. The panel builder is responsible for the temperature rise calculation. Eaton will provide heat dissipation data for the devices. Is the panel builder's responsibility. The specifications for the switchgear must be observed. 10.13 Mechanical function The device meets the requirements, provided the information in the instruction	10.8 Connections for external conductors	Is the panel builder's responsibility.
10.9.4 Testing of enclosures made of insulating material 10.10 Temperature rise The panel builder is responsibility. The panel builder is responsible for the temperature rise calculation. Eaton will provide heat dissipation data for the devices. 10.11 Short-circuit rating Is the panel builder's responsibility. The specifications for the switchgear must be observed. 10.12 Electromagnetic compatibility Is the panel builder's responsibility. The specifications for the switchgear must be observed. 10.13 Mechanical function The device meets the requirements, provided the information in the instruction	10.9.2 Power-frequency electric strength	Is the panel builder's responsibility.
10.10 Temperature rise The panel builder is responsible for the temperature rise calculation. Eaton will provide heat dissipation data for the devices. 10.11 Short-circuit rating Is the panel builder's responsibility. The specifications for the switchgear must be observed. 10.12 Electromagnetic compatibility Is the panel builder's responsibility. The specifications for the switchgear must be observed. 10.13 Mechanical function The device meets the requirements, provided the information in the instruction	10.9.3 Impulse withstand voltage	Is the panel builder's responsibility.
provide heat dissipation data for the devices. 10.11 Short-circuit rating 1s the panel builder's responsibility. The specifications for the switchgear must be observed. 10.12 Electromagnetic compatibility 1s the panel builder's responsibility. The specifications for the switchgear must be observed. 10.13 Mechanical function The device meets the requirements, provided the information in the instruction	10.9.4 Testing of enclosures made of insulating material	Is the panel builder's responsibility.
observed. 10.12 Electromagnetic compatibility Is the panel builder's responsibility. The specifications for the switchgear must be observed. 10.13 Mechanical function The device meets the requirements, provided the information in the instruction	10.10 Temperature rise	
observed. 10.13 Mechanical function The device meets the requirements, provided the information in the instruction	10.11 Short-circuit rating	Is the panel builder's responsibility. The specifications for the switchgear must be observed.
· · · · · · · · · · · · · · · · · · ·	10.12 Electromagnetic compatibility	Is the panel builder's responsibility. The specifications for the switchgear must be observed.
	10.13 Mechanical function	

Technical data ETIM 8.0

Low-voltage industrial components (EG000017) / Switch disconnector (EC000216)

Electric engineering, automation, process control engineering / Low-voltage switch technology / Off-load switch, circuit breaker, control switch / Switch disconnector (ecl@ss10.0.1-27-37-14-03 [AKF060013])

Version as main switch		Yes	
Version as maintenance-/service switch		Yes	
Version as safety switch		No	
Version as emergency stop installation		Yes	
Version as reversing switch		No	
Number of switches		1	
Max. rated operation voltage Ue AC	V	600	
Rated operating voltage	V	690	
Rated permanent current lu	А	100	
Rated permanent current at AC-23, 400 V	А	100	
Rated permanent current at AC-21, 400 V	А	100	
Rated operation power at AC-3, 400 V	kV	V 30	
Rated short-time withstand current lcw	kA	1.7	
Rated operation power at AC-23, 400 V	kV	V 55	
Switching power at 400 V	kV	V 55	
Conditioned rated short-circuit current Iq	kA	2	
Number of poles		6	
Number of auxiliary contacts as normally closed contact		1	

Number of auxiliary contacts as normally open contact	1
Number of auxiliary contacts as change-over contact	0
Motor drive optional	No
Motor drive integrated	No
Voltage release optional	No
Device construction	Built-in device fixed built-in technique
Suitable for floor mounting	Yes
Suitable for front mounting 4-hole	No
Suitable for front mounting centre	No
Suitable for distribution board installation	No
Suitable for intermediate mounting	Yes
Colour control element	Red
Type of control element	Door coupling rotary drive
Interlockable	Yes
Type of electrical connection of main circuit	Screw connection
Degree of protection (IP), front side	IP65
Degree of protection (NEMA)	12