


July 15, 2015

Declaration of Conformity

Issued by
Pentair Poland Sp. z o. o.
ul. Strefowa 10
58-200 Dzierżoniów, Poland

Equipment Description:	GL66 Mild Steel M-type Wall-Mount enclosures
Ingress Protection:	IP 66 – Single Door IP 55 – Overlapping door
Mechanical Impact Protection:	IK 9
Applicable Standards:	IEC/EN 60529:2003 Degrees of protection provided by enclosures (IP code) IEC/EN 62262:2002 Degrees of protection provided by enclosures (IK code) UL 508A Listed; Type 4,12; File Number E61997 IEC/EN 62208:2011 Empty enclosures for low-voltage switchgear and controlgear assemblies

Authorized by:



Krzysztof Niemiec
R&D Manager
Pentair Equipment Protection

Stamp of Company:

Copyright Note: The information contained in this document is the property of Pentair Poland Sp. z o. o.; ul. Strefowa 10; 58-200 Dzierżoniów, Poland. The content cannot be reproduced and used without authorization. Pentair Poland Sp. z o. o. pursues a policy of continual product improvement and reserves the right to alter without notice the content of the present document.