

## **General Information**

CM-PBE **Extended Product Type:** 

1SVR550882R9500 **Product ID:** EAN: 4013614348136

**Catalog Description:** CM-PBE Phase loss monitoring relay 1n/o, L1,2,3= 380-440VAC

Long Description: Phase loss- and undervoltage monitoring relay CM-PBE, width 22.5mm, three phase,

measuring range L1,L2,L3=380-440VAC, powered by measuring circuit, 1 n/o (closed circuit

principle)

## Categories

Products » Low Voltage Products and Systems » Control Products » Electronic Relays and Controls » Three Phase Monitors

## **Ordering**

**Minimum Order Quantity:** 1 piece **Customs Tariff Number:** 85364900 4013614348136 EAN:

## **Container Information**

Package Level 1 Width: 24 mm Package Level 1 Height: 83 mm Package Level 1 Length: 25 mm Package Level 1 Gross Weight: 0.078 kg Package Level 1 Units: 1 piece

#### **Dimensions**

**Product Net Depth:** 78.5 mm **Product Net Height:** 78 mm **Product Net Weight:** 0.066 kg **Product Net Width:** 22.5 mm

#### **Technical**

Standards: EN 50178

IEC/EN 61000-6-2 IEC/EN 61000-6-3

**UL 508** 

CAN/CSA C22.2 No.14 (L-L) 380 ... 440 V AC

Rated Control Supply Voltage (U<sub>s</sub>): (L-L) 380 ... 440 V AC Rated Frequency (f): Supply Circuit 50/60 Hz

**Output:** 1 n/o contact

Time Range: 500 ms start-up delay 150 ms tripping delay

Screw Terminals

**Terminal Type:** Function: Phase failure detection

#### **Environmental**

Measuring Range:

**RoHS Status:** Following EU Directive 2011/65/EC

# **Certificates and Declarations (Document Number)**

Instructions and Manuals: 1SVC550510M0001 **CB Certificate:** CB DK-8880 CCC Certificate: CCC\_2013010303605960 **cUL Certificate:** cUL508 E140448

Data Sheet, Technical Information: 2CDC112194D0201 **Declaration of Conformity - CE:** 1SVD981025-0000

**EAC Certificate:** EAC\_RU\_C-BG.ME77.B.00507 **RMRS Certificate:** RMRS\_12.04009.250 **RoHS Information:** 1SVD981001-4400 **UL Certificate:** UL508 E140448

#### Classifications

ETIM 4:EC001441 - Phase monitoring relayETIM 5:EC001441 - Phase monitoring relayETIM 6:EC001441 - Phase monitoring relayeClass:7.0 27371803UNSPSC:39121500Object Classification Code:B

