

OMRON


Best Selection

Fiber Sensor Best Selection Catalog



Start with Smart!

Easily select the most reliable Fiber Unit for your detection conditions.







realizing

oer Sensor atures

> election iuide

Fiber Units

Standard Installatio

Saving Space

Beam Improvements

Transparent Objects

Immunity

Applications





Technical Guide and Precaution


Nodel Index

Easy

"Mounts Anywhere"


Wide Variety


Variously-shaped, compact heads allow installation in any small space.



Suitable for Harsh Environments

Fiber Units are available for various installation conditions and can be installed as is, even in harsh environments.







Optimal Fiber Sensor for additional Fiber Units for various Installation Conditions,

"Achieve Easy Detection in Many Applications"

Smart Tuning

Just press the button to set the optimum incident level and threshold. Consistent settings are achieved for all users with this ultra-easy procedure.






Optimum Light Intensity Adjustment

from Transparent Objects to Black Workpieces

The incident level is optimized to enable stable detection even for saturated or insufficient incident levels.



NEW

Smart Fiber Amplifier Units E3NX-FA

> 62, 64 Page

"Smooth Wiring and Setting"

Reduced Wiring

Simply link the Fiber Amplifier Units together for easy wiring and checking.

Separate Installation

Use the Distributed Sensor Unit for distributed installation to reduce introduction costs and work.

Easy Setup

Commissioning time is reduced with batch setting from a Touch Panel or backup data for process switchovers.





Fiber

'Easy' and 'Stable' for

ber Sensor

installation when starting production.

Fiber Amplifier Units with easy optimum setting

Stable

Fiber Units

E32





"Expanded Application Response Capabilities"

Improved Basic Performance

Improvements in the sensing distance and minimum sensing object increase the range of application for stable detection.

1.5 Times the Sensing Distance*

6 m

For E32-LT11 Fiber Unit with a fiber length of 3.5 m

1/10th
the Minimum Sensing Object*

 $0.3 \, \mu \mathrm{m}$ dia.

Typical example of actual measurements with E32-D11R Fiber Unit.

*Compared to E3X-HD.



Sensor Communications Units

E3NW

Ether CAT.


CompoNet

62, 64 Page

CC-Link V2

Sensor

Minimal Cost Process.



Cylindrical

Flat

Sleeved

Small Spot

High Power
Narrow
view

BGS

Retroreflective Limitedreflective

resistant, Oil-resistant Bending

Heatresistant

Detection Liquid-level

Vacuum FPD, Semi, Solar

chnical Colide and Un

Model Index

Selection by Category

STEP 1

Select a Fiber Unit.

Select a category.

Fiber Unit Index

Select a model.
Category Pages 06 to 61
Page

STEP 2

Select a Fiber Amplifier Unit and Communications Unit. STEP 3

Select Accessories of Fiber Amplifier Unit

Before Selecting Fiber Units

The Fiber Units specifications give the sensing distance when the Fiber Unit and Fiber Amplifier Unit is combined. Check the Fiber Amplifier Unit series for easier selection.

<Specifications on Each Fiber Unit Category Page>

Fiber Amplifier Unit Series

			E3X-HD Series	E3NX-FA Series <u>NEW</u>
	Output		1 output	1 or 2 outputs (depending on the model)
	External input		Not supported	Supported or not supported (depending on the model)
Fiber Amplifier	Response time		50 μs (55 μs)/250 μs/1 ms/16 ms (Default: 250 μs)	30 μs (32 μs)/250 μs/1 ms/16 ms (Default: 250 μs)
Unit specifications	Sensing distance	E32-T11R	2,000 mm	3,000 mm
	(Giga-power mode)	E32-D11R	840 mm	1,260 mm
	Minimum sensing object	E32-T11R	5 μm dia.	2 μm dia.
Sensor Communications	Communications m (Sensor Communica		EtherCAT (E3X-ECT) CompoNet (E3X-CRT)	EtherCAT (E3NW-ECT) CompoNet (E3NW-CRT) CC-Link (E3NW-CCL)
Unit application	Applicable Sens	sors	Fiber Sensor (E3X-HD0) Fiber Sensor (E3X-MDA0) Laser Photoelectric Sensor (E3C-LDA0) Proximity Sensor (E2C-EDA0)	Fiber Sensor (E3NX-FA0) Laser Sensors (E3NC-LA0, E3NC-SA0) Contact-Type Sensor (E9NC-TA0)*
	Ordering Inform	nation	78 Page	64 Page
Page listings	Ratings and Sp	ecifications	80 Page	66 Page
	Dimensions		80 Page	68 Page

^{*} E3NW-CRT Sensor Communications Units (CompoNet) cannot be used.

Selection by Model

STEP 1

Search for the page in the model index.

98 Page

STEP 2

Search for the model on the corresponding pages.

Page Page

Fiber Unit Index





Standard screw-type installation. The Fiber Units is mounted into a drilled hole and secured

Cylindrical Models



Ideal for installation in narrow spaces.
The Fiber Unit is secured with 10

Saving Space



Mount directly in limited spaces without using special mounting brackets.

14

Sleeve Models



Suitable for close-range

Ideal for detecting minute objects in areas with limited space

16

Beam Improvements

06

Small-Spot, Reflective (Minute Object Detection)



Small-spot to accurately detect

High-power Beam



Suitable for detection on large equipment, of large objects, and in environments with airborne particles.



Narrow View (Detection Across Clearance)



The Fiber Unit emit a non-spreading beam to prevent false detection of light reflected off surrounding objects



Detection without Background Interference



Detect only objects in the sensing range, and not in the background.


32

Transparent Object Detection

20

Page

Retro-reflective



Detect transparent objects reliably through the object twice, resulting in greater light interruption.




34

Page

48

Page

Limited-reflective (Glass Detection)



The limited-reflective optical system provides stable detection of specular reflective 36

Environmental Immunity

Chemical-resistant, **Oil-resistant**



chemicals.

Bending-resistant, **Disconnection-resistant**



Resistant to repeated bending on moving parts and breaking from snagging or shock



40



Can be used in environments at up to 400°C.

44 Page

Special Applications



Detect across areas for meandering materials or falling workpieces whose position

Liquid-level Detection



Detect only liquid when being mounted on tubes or in liquid.



Vacuum-resistant



Can be used under high vacuums of up to 10⁻⁵ Pa.



FPD, Semiconductors, and Solar Cells



Designed specifically to reliably detect glass substrates and wafers.

Threaded

Cylindrical

Flat

Sleeved

Small Spot

High Power

Narrow view

BGS

Retroreflective

Limitedreflective

Chemicalresistant, Oil-resistant

Bending

Heatresistant

Detection

Liquid-level

Vacuum

FPD, Semi. Solar

Threaded Models

iber Sensor eatures

selection Suide

Fiber Units

Threaded

Cylindrical

Flat

Sleeved

Small Spot

High Power
Narrow
view

BGS

Retroreflective

Chemicalresistant, Oil-resistant

Heat-

Area

resistant

Detection

Liquid-level

FPD, Semi, Solar

Standard Installation

Saving Space

Beam Improvement

ty Transparent Obje


Environmental In

Applications

plifiers, ications

> chnical iide and ecautions

> > Model Index



- Standard configuration. These Fiber Units are mounted into a hole drilled in a bracket and secured with nuts.
- The Right-angle Model prevents snagging on the cable because the cable runs along the mounting surface.





Hex-shaped Fiber Units with Build-in Lenses Build-in Lenses have been added to the series. (They have a right-angle shape like that of the E32-T11N shown below.)

→ 96 Page

Specifications

■→■ Through-beam Fiber Units

Sensing				Se	ensing dis	tance (mm)		Optical axis		
direction (Aperture	Size	Appearance (mm)	Bending radius of cable	ЕЗХ-Н	D	E3NX-FA	<u>NEW</u>	diameter (minimum sensing	Models	07 Page Dimensions No.
angle)			Oi Gubio	■GIGA=HS	Other modes	■GIGA=HS	Other modes			1101
Right- angle (Approx. 60°)		14.7 M4	Flexible,	2,000	ST : 1,000	3,000	ST : 1,500	1 dia. (5 μm dia./	E32-T11N 2M	07-A
Top-view (Approx. 60°)	M4	14 M4 IP67	R1	700	SHS: 280	1,050	SHS: 280	2 μm dia.)	E32-T11R 2M	07-B
Top-view	IVI	15	R25	4,000 2,700	ST : 4,000 SHS: 1,080	4,000 4,000	ST : 4,000 SHS: 1,080	2.3 dia. (0.1 dia./	E32-LT11 2M <u>NEW</u>	- (07-C)
(Approx. 15°)		M4 Build-in Lens IP50	Flexible, R1	2,300	ST : 3,500 SHS: 920	4,000 3,450	ST : 4,000 SHS: 920	0.03 dia.)	E32-LT11R 2M <u>NEW</u>	

^{*} The optical fiber is 2 m long on each side, so the sensing distance is 4,000 mm.

Note The following mode names and response times apply to the modes given in the Sensing distance column.

- 1. [E3X-HD] GIGA: Giga-power mode (16 ms), HS: High-speed mode (250 μs), ST: Standard mode (1 ms), and SHS: Super-high-speed mode (NPN output: 50 μs, PNP output: 55 μs) [E3NX-FA] GIGA: Giga-power mode (16 ms), HS: High-speed mode (250 μs), ST: Standard mode (1 ms), and SHS: Super-high-speed mode (30 μs)
- The values for the minimum sensing object are reference values that indicate values obtained in standard mode with the sensing distance and sensitivity set to the optimum values.
- 2. The first value is for the E3X-HD and the second value is for the E3NX-FA.

Threaded Models

Dimensions


Installation Information → 59, 60 Page

Standard Installation




Through-beam Fiber Units (Set of 2)


07-A E32-T11N 2M (Free Cutting)



(07-B) E32-T11R 2M (Free Cutting)



07-C E32-LT11 2M (Free Cutting) E32-LT11R 2M (Free Cutting)



- Reference Information for Model Selection -

Features of the Right-angle Type

- · Cable is less prone to snagging.
- Cable runs along the mounting surface for less space compared with Top-view Fiber Units.
- The nut is attached to the Fiber Unit to reduce installation work.

Build-in Lens

What Are Fiber Units with Build-in Lenses?

These Fiber Units have built-in lenses.

They feature high-power beams.

You don't have to worry about the lens falling off and getting lost.

What Is "Flexible" Fiber?

The flexible fiber has a small bending radius for easy routing without easily breaking. It is easy to use because the cable can be bent without significantly reducing light intensity.



Structure which has a cladding around a large number of ultrafine cores

And

Long-distance Sensing Applications

A separate Lens Unit can be attached to extend the sensing distance.

→ 26 Page

Breaking Due to Snagging or Shock

The Fiber Unit can be protected from breaking with stainless steel spiral tube.

→ 40 Page (Excluding the E32-T11N 2M.)

Cylindrical

Flat

Sleeved

High Power

Small Spot

Narrow view

BGS

Retroreflective Limited-

reflective Chemicalresistant,

Oil-resistant Bending

resistant

Area Detection

Liquid-level

Vacuum FPD, Semi. Solar

Top-view Type

Cylindrical

Flat

Sleeved

Small Spot

High Power Narrow view

BGS

Retro-reflective

Limited-

Chemical-Oil-resistant Bending

Heatresistant

Area Detection

Liquid-level Vacuum FPD, Semi. Solar

Threaded Models









Hex-shaped Fiber Units have been added to the series. (They have a right-angle shape like that of the E32-C31N shown below.)

Specifications

Reflective Fiber Units

Right-angle Type

Sensing				Se	nsing dis	tance (mm)		Optical axis		
direction (Aperture	Size	Appearance (mm)	Bending radius of cable	ЕЗХ-Н	ID	E3NX-FA	NEW	diameter (minimum sensing	Models	09 Page Dimensions No.
angle)			OI GUDIC	■GIGA =HS	Other modes	■GIGA =HS	Other modes			140.
Right-	М3	Coaxial 20.5	Flexible,	■ 110 □ 46	ST : 50 SHS: 14	■ 160 ■ 69	ST : 75 SHS: 14		E32-C31N 2M	09-A
angle (Approx. 60°)	M6	Coaxial 24 M6	R4	780	ST : 350 SHS: 100	1,170	ST : 520 SHS: 100		E32-C91N 2M <u>NEW</u>	09-B
		11 M3	Flexible, R1	■ 140 □ 40	ST : 60 SHS: 16	210 60	ST : 90 SHS: 16		E32-D21R 2M	09-C
	M3 Coaxial	Coaxial 25 M3 IP67	R25	330	ST : 150	490	ST : 220	(5 μm dia./	E32-C31 2M	09-D
Top-view (Approx. 60°)		Coaxial 11 M3 IP67	R10	100	SHS: 44	1 50	SHS: 44	2 μm dia.) ¯	E32-C31M 1M	09-E
, , ,	M4	15 M4 IP67	Flexible,	140 40	ST : 60 SHS: 16	210 60	ST : 90 SHS: 16		E32-D211R 2M	09-F
	M6	17 M6	R1	840	ST : 350 SHS: 100	360	ST : 520 SHS: 100		E32-D11R 2M	09-G
	WO	Coaxial 23 M6	R25	400	ST : 600 SHS: 180	2,100	ST : 900 SHS: 180		E32-CC200 2M	09-H
Top-view	Me	23	R25	250	ST : 360 SHS: 110	1,290	ST : 540 SHS: 110	(1 dia./	E32-LD11 2M <u>NEW</u>	- (09-1)
(Approx. 15°)	M6 M6	Flexible, R1	840	ST : 350 SHS: 100	1,260	ST : 520 SHS: 100	0.03 dia.)	E32-LD11R 2M <u>NEW</u>	03-1	

Note The following mode names and response times apply to the modes given in the Sensing distance column.

- 1. [E3X-HD] GIGA: Giga-power mode (16 ms), HS: High-speed mode (250 μ s), ST: Standard mode (1 ms), and SHS: Super-high-speed mode (NPN output: 50 μ s, PNP output: 55 μ s) [E3NX-FA] GIGA: Giga-power mode (16 ms), HS: High-speed mode (250 μ s), ST: Standard mode (1 ms), and SHS: Super-high-speed mode (30 μ s)
 - The values for the minimum sensing object are reference values that indicate values obtained in standard mode with the sensing distance and sensitivity set to the optimum values.
- 2. The first value is for the E3X-HD and the second value is for the E3NX-FA.
- The sensing distances for Reflective Fiber Units are for white paper. (The sensing distance for the E32-LD11 2M / E32-LD11R 2M are for glossy white paper.)


Threaded Models

Dimensions


Installation Information → 58, 59 Page

Standard Installation

Reflective Fiber Units




09-B E32-C91N 2M (Free Cutting)




Washers (Nickel-plated brass) provided (2 of each)


09-C E32-D21R 2M (Free Cutting)



09-D E32-C31 2M (Free Cutting)




09-E E32-C31M 1M (Free Cutting)




Note: There is a white line on the emitter fiber.

The Fiber Attachments that are provided were specially designed for this Fiber Unit.
 E39-F9 cannot be attached.


09-F E32-D211R 2M (Free Cutting)



09-G E32-D11R 2M (Free Cutting)




09-H E32-CC200 2M (Free Cutting)



Note: There is a white line on the emitter fiber

09-I E32-LD11 2M (Free Cutting) E32-LD11R 2M (Free Cutting)



- Reference Information for Model Selection -

Features of Coaxial Reflective Type

These Fiber Units offer better detection of small objects at close distances (of 2 mm or less) than Standard Reflective Fiber Units.

They also detect glossy surfaces more reliably than Standard Reflective Fiber Units, even if the surface is tilted.

The receiver fibers are arranged around the emitter fiber as shown below.

Emitter Fiber Receiver Fibers

Breaking Due to Snagging or Shock

The Fiber Unit can be protected from breaking with stainless steel spiral tube.

→ 42 Page

Features of the Right-angle Type

- · Cable is less prone to snagging.
- · Cable runs along the mounting surface for less space compared with Top-view Fiber Units.
- · The nut is attached to the Fiber Unit to reduce installation work.

What Is "Flexible" Fiber?

The flexible fiber has a small bending radius for easy routing without easily breaking. It is easy to use because the cable can be bent without significantly reducing light intensity.



Structure which has a cladding around a large number of ultrafine cores

What Are Fiber Units with Build-in Lenses?

These Fiber Units have built-in lenses

They feature high-power beams.

You don't have to worry about the lens falling off and getting lost.

OMRON

Cylindrical

Flat

Sleeved

Small Spot

High Power

Narrow view

BGS

Retroreflective Limited-

reflective Chemical-

resistant. Oil-resistant

Bending

resistant Area

Detection Liquid-level

Vacuum FPD. Semi. Solar

Threaded

Cylindrical

Flat

Sleeved

Small Spot

Narrow view

BGS

High Power

Retro-reflective Limitedreflective


Chemicalresistant, Oil-resistant Bending

Heatresistant Area

Liquid-level

Vacuum FPD, Semi. Solar

Detection



- · Inserted where space is limited. (Secured using a set screw.)
- Ultramate space-saving by micro-fiber head. (1 dia. × 10 mm)



· Side-view models can be mounted where there is limited depth.

Specifications

Through-beam Fiber Units

			Dan dia a	Se	nsing dis	tance (mm)		Optical axis		44 Dans
Size	Sensing direction	Appearance (mm)	Bending radius of cable	us E3X-HD		E3NX-FA <u>NEW</u>		diameter (minimum sensing	Models	11 Page Dimensions No.
			Oi oubio	■GIGA =HS	Other modes	■GIGA =HS	Other modes			110.
1 dia.		10 1 dia.	Flexible, R1	450	ST : 250 SHS: 60	670	ST : 370 SHS: 60	0.5 dia.	E32-T223R 2M	11-A
1.5 dia.	Top-view	10	Bendresistant, R4	680	ST : 400 SHS: 90	330	ST : 600 SHS: 90	(5 μm dia./ - 2 μm dia.)	E32-T22B 2M	11-B
3 dia.		14 3 dia.	Flexible,	700	ST : 1,000 SHS: 280	3,000 1,050	ST : 1,500 SHS: 280	1 dia.	E32-T12R 2M	11-C
3 dia.	Side-view	35 3 dia.	R1	750	ST : 450 SHS: 100	1,120 390	ST : 670 SHS: 100	(5 μm dia./- 2 μm dia.)	E32-T14LR 2M	(11-D)

Note 1. The following mode names and response times apply to the modes given in the Sensing distance column. [E3X-HD] GIGA: Giga-power mode (16 ms), HS: High-speed mode (250 µs), ST: Standard mode (1 ms), and SHS: Super-high-speed mode (NPN output: 50 µs, PNP output: 55 µs) [E3NX-FA] GIGA: Giga-power mode (16 ms), HS: High-speed mode (250 µs), ST: Standard mode (1 ms), and SHS: Super-high-speed mode (30 µs)

2. The values for the minimum sensing object are reference values that indicate values obtained in standard mode with the sensing distance and sensitivity set to the optimum values. The first value is for the E3X-HD and the second value is for the E3NX-FA.

Dimensions

Installation Information → 60 Page



Through-beam Fiber Units (Set of 2)

11-A E32-T223R 2M (Free Cutting)




11-B E32-T22B 2M (Free Cutting)



11-C E32-T12R 2M (Free Cutting)



11-D E32-T14LR 2M (Free Cutting)



Reference Information for Model Selection -

Recommended Mounting Hole Dimensions

The recommended mounting-hole dimensions for Cylindrical Fiber Units are given below.



			(Orne. min)
Outer diameter of Fiber Unit	1 dia.	1.5 dia.	3 dia.
Dimension F	1.2 ^{+0.5} dia.	1.7 ^{+0.5} dia.	3.2 ^{+0.5} ₀ dia.

Cylindrical

Flat

Sleeved

Small Spot

High Power

Narrow view

BGS

Retroreflective

Limitedreflective

Chemicalresistant, Oil-resistant

Bending

resistant

Area Detection

Liquid-level

Vacuum

FPD, Semi, Solar

Cylindrical Models

Threaded

Cylindrical

Flat

Sleeved

Small Spot

Narrow view

BGS

Retro-reflective

Limitedreflective Chemical-

High Power

resistant, Oil-resistant Bending

Heatresistant Area Detection

Liquid-level Vacuum FPD, Semi.

Solar

· Inserted where space is limited. (Secured using a set screw.)

Specifications

Reflective Fiber Units

				Ser	nsing dis	stance (mm)		Optical axis		
Size	Sensing direction	Appearance (mm)	Bending radius of cable	E3X-HD)	E3NX-FA	NEW	diameter (minimum sensing	Models	13 Page Dimensions No.
			OI CUDIC	■GIGA =HS	Other modes	■GIGA =HS	Other modes			140.
1.5 dia.		15 1.5 dia.	Bend- resistant, R4	140 40	ST : 60 SHS: 16	210	ST : 90 SHS: 16		E32-D22B 2M	13-A
1.5 dia. + 0.5 dia.		The sleeve cannot be bent. 3 15 1.5 dia. 0.5 dia.	R4	■ 28		42 12	ST : 18 SHS: 4		E32-D43M 1M	13-B
	Top-view	15 3 dia. IP67	Flexible, R1	140 40	ST : 60 SHS: 16	210	ST : 90 SHS: 16	(5 μm dia./	E32-D22R 2M	13-C
3 dia.		15 \\ 3 dia.	Bend- resistant, R4	300	ST : 140 SHS: 40	450	ST : 210 SHS: 40	2 μm dia.)	E32-D221B 2M	13-D
		Coaxial 15 3 dia. IP67	R25	200	ST : 300 SHS: 90	1,050	ST : 450 SHS: 90		E32-D32L 2M	13-E
3 dia. + 0.8 dia.		The sleeve cannot be bent. 20 15 3 dia. IP67	ΠΖIJ	■ 70	ST : 30 SHS: 8	100	ST : 45 SHS: 8		E32-D33 2M	13-F

Note 1. The following mode names and response times apply to the modes given in the Sensing distance column.

[E3X-HD] GIGA: Giga-power mode (16 ms), HS: High-speed mode (250 µs), ST: Standard mode (1 ms), and SHS: Super-high-speed mode (NPN output: 50 µs, PNP output: 55 µs) [E3NX-FA] GIGA: Giga-power mode (16 ms), HS: High-speed mode (250 µs), ST: Standard mode (1 ms), and SHS: Super-high-speed mode (30 µs)

- 2. The values for the minimum sensing object are reference values that indicate values obtained in standard mode with the sensing distance and sensitivity set to the optimum values. The first value is for the E3X-HD and the second value is for the E3NX-FA.
- 3. The sensing distances for Reflective Fiber Units are for white paper.

Dimensions

Installation Information → 58, 59 Page

Standard Installation


Reflective Fiber Units

(13-A) E32-D22B 2M (No Cutting)

Brancher (ABS): 3.5 dia 2.000 *Attached with adhesive and cannot be removed

Enlarged View of Sensing Surface Emitter fiber: two, 0.25 dia.


13-B E32-D43M 1M (No Cutting)




13-C E32-D22R 2M (Free Cutting)



13-D E32-D221B 2M (Free Cutting)




13-E E32-D32L 2M (Free Cutting)



Note: There is a yellow dotted line on the Emitter fiber

13-F E32-D33 2M (Free Cutting)



- Reference Information for Model Selection -

Features of Coaxial Reflective Type

These Fiber Units offer better detection of small objects at close distances (of 2 mm or less) than Standard Reflective Fiber Units.

They also detect glossy surfaces more reliably than Standard Reflective Fiber Units, even if the surface is tilted.

The receiver fibers are arranged around the emitter fiber as shown below.

Emitter fiber Receiver fibers

Recommended Mounting Hole Dimensions

The recommended mounting-hole dimensions for Cylindrical Fiber Units are given below.



		(Unit: mm)
Outer diameter of Fiber Unit	1.5 dia.	3 dia.
Dimension F	1.7 ^{+0.5} dia.	3.2 ^{+0.5} ₀ dia.

Cylindrical

Flat Sleeved

Small Spot

High Power

Narrow view

BGS

Retroreflective Limited-

reflective Chemicalresistant,

Oil-resistant Bending

resistant Area Detection

Liquid-level

Vacuum

FPD, Semi. Solar

Flat Models

Flat

Sleeved

Small Spot

Narrow view

BGS

Retro-reflective

Limitedreflective Chemicalresistant, Oil-resistant

Bending


Heat-

Area

High Power

resistant Detection Liquid-level

Vacuum FPD, Semi. Solar



- · Thin profile for mounting in limited spaces.
- Mounts directly without using special mounting brackets.

Specifications

Through-beam Fiber Units

- Till Out	gii beaiii i ibei	Office							
			Se	ensing dis	stance (mm)		Optical axis		
Sensing direction	Appearance (mm)	Bending radius of cable	ЕЗХ-НІ)	E3NX-FA	NEW	diameter (minimum sensing	Models	15 Page Dimensions No.
		or cabic	■GIGA =HS	Other modes	■GIGA =HS	Other modes	1		140.
Top-view	3 13 15 [P67		2,000	ST : 1,000 SHS: 280	3,000 1,050	ST : 1,500 SHS: 280		E32-T15XR 2M	15-A
Side-view	15 31 8	Flexible,	750	ST : 450	1,120	ST : 670	1 dia. (5 μm dia./ 2 μm dia.)	E32-T15YR 2M	15-B
Flat-view	15 8 3	R1	260	SHS: 100	390	SHS: 100		E32-T15ZR 2M	15-C
riai-view	12 8.5 3 Build-in Lens		2,400	ST : 1,200 SHS: 300	3,600	ST : 1,800 SHS: 300	3 dia. (0.1 dia./ 0.03 dia.)	E32-LT35Z 2M <u>NEW</u>	15-D

Reflective Fiber Units

			Se	nsing dis	stance (mm)		Optical axis		
Sensing direction	Appearance (mm)	Bending radius of cable	E3X-HI	•	E3NX-FA	NEW	diameter (minimum sensing	Models	15 Page Dimensions No.
		or oublo	■GIGA =HS	Other modes	■GIGA =HS	Other modes			
	15,>		840	ST : 350	1,260	ST : 520			
Top-view	3 I 10 IP67		240	SHS: 100	360	SHS: 100		E32-D15XR 2M	(15-E)
Side-view	3 L 10 IP67	Flexible, R1	200	ST : 100	300	ST : 150	(5 μm dia./ 2 μm dia.)	E32-D15YR 2M	15-F
Flat-view	15 10 3 IP67		■ 52	SHS: 24	■ 78	SHS: 24		E32-D15ZR 2M	15-G

Note 1. The following mode names and response times apply to the modes given in the Sensing distance column.

[E3X-HD] GIGA: Giga-power mode (16 ms), HS: High-speed mode (250 µs), ST: Standard mode (1 ms), and SHS: Super-high-speed mode (NPN output: 50 µs, PNP output: 55 µs) [E3NX-FA] GIGA: Giga-power mode (16 ms), HS: High-speed mode (250 µs), ST: Standard mode (1 ms), and SHS: Super-high-speed mode (30 µs)


- 2. The values for the minimum sensing object are reference values that indicate values obtained in standard mode with the sensing distance and sensitivity set to the optimum values. The first value is for the E3X-HD and the second value is for the E3NX-FA.
- 3. The sensing distances for Reflective Fiber Units are for white paper.

Dimensions

Installation Information → 60 Page

Through-beam Fiber Units (Set of 2)


15-A E32-T15XR 2M (Free Cutting)



Note: 1. Set of two symmetrically shaped Fiber Units.

2. Four, M2 × 8 stainless steel countersunk mounting screws are provided.


15-B E32-T15YR 2M (Free Cutting)



Note: 1. Set of two symmetrically shaped Fiber Units.


2. Four, M2 \times 8 stainless steel countersunk mounting screws are provided.

15-C E32-T15ZR 2M (Free Cutting)



Note: 1. Set of two symmetrically shaped Fiber Units 2. Four, M2 × 8 stainless steel countersunk mounting screws are provided.

15-D E32-LT35Z 2M (Free Cutting)




Note: 1. Set of two symmetrically shaped Fiber Units.

2. Four, M2 x 8 stainless-steel, pan-head mounting screws. four spring washers, four flat washers, and four nuts are provided.

Installation Information → 58 Page


Reflective Fiber Units

15-E E32-D15XR 2M (Free Cutting)




Note: Two, M2 x 8 stainless steel countersunk mounting screws are provided.

15-F E32-D15YR 2M (Free Cutting)



Note: Two, M2 x 8 stainless steel countersunk mounting screws are provided.

(15-G) E32-D15ZR 2M (Free Cutting)



Note: Two, M2 x 8 stainless steel countersunk mounting screws are provided.

Threaded

Cylindrical

Flat

Sleeved

Small Spot

High Power

Narrow view

BGS

Retroreflective

Limitedreflective

Chemicalresistant, Oil-resistant

Bending

resistant

Area Detection

Liquid-level

Vacuum

FPD, Semi. Solar

Cylindrical

Flat

Small Spot

Sleeved

High Power Narrow view

BGS

Retro-reflective Limited-

> Chemicalresistant, Oil-resistant

reflective

Bending Heat-


resistant

Area Detection

Liquid-level

Vacuum FPD, Semi.

Solar



- · Sleeve Fiber Units allow detection away from the point of installation for stable close-range detection of small objects.
- The shape of sleeve can be changed freely. (Refer to the sleeve bending specifications in the Appearance column of the specifications table.)



Specifications

■→■ Through-beam Fiber Units

			Se	nsing dis	stance (mm)		Optical axis		47.0
Sensing direction	Appearance (mm)	Bending radius of cable	E3X-HD		E3NX-FA	<u>NEW</u>	diameter (minimum sensing	Models	17 Page Dimensions No.
			■GIGA =HS	Other modes	■GIGA =HS	Other modes			
	The sleeve cannot be bent. 20	Flexible,	170	ST : 100	250	ST : 150		E32-T24R 2M	(17-A)
Olds sissu	IP67	R1	■ 50	SHS: 20	7 5	SHS: 20	0.5 dia. (5 µm dia./		
Side-view	The sleeve cannot be bent. 15		450	ST : 250	670	ST : 370	2 μm dia.)	E32-T24E 2M	
	2.5 dia. 0.81 dia.		150	SHS: 60	220	SHS: 60		E32*124E 2M	(17-B)
	The sleeve cannot be bent.		150	ST : 90	220	ST : 130	0.25 dia.		
	15 0.5 dia. 3 dia.	R10	■ 50	SHS: 20	■ 75	SHS: 20	(5 μm dia./ 2 μm dia.)	E32-T33 1M	(17-C)
	The sleeve cannot be bent.		510	ST : 300	760	ST : 450	0.5 dia.		
Top-view	15 0.82 dia. M3 IP67		170	SHS: 68	250	SHS: 68	(5 μm dia./ 2 μm dia.)	E32-T21-S1 2M <u>NEW</u>	(17-D)
	Sleeve bending radius: 5 mm	Flexible,	2,000	ST : 1,000	3,000	ST : 1,500	1 dia.		
	11 1.2 dia. IP67	R1	700	SHS: 280	1,050	SHS: 280	(5 μm dia./ 2 μm dia.)	E32-TC200BR 2M	(17-E)

Note 1. The following mode names and response times apply to the modes given in the Sensing distance column.

[E3X-HD] GIGA: Giga-power mode (16 ms), HS: High-speed mode (250 µs), ST: Standard mode (1 ms), and SHS: Super-high-speed mode (NPN output: 50 µs, PNP output: 55 µs) [E3NX-FA] GIGA: Giga-power mode (16 ms), HS: High-speed mode (250 μ s), ST: Standard mode (1 ms), and SHS: Super-high-speed mode (30 μ s)

2. The values for the minimum sensing object are reference values that indicate values obtained in standard mode with the sensing distance and sensitivity set to the optimum values. The first value is for the E3X-HD and the second value is for the E3NX-FA.

OMRON


Dimensions

Installation Information → 60, 61 Page




Through-beam Fiber Units (Set of 2)


17-A E32-T24R 2M (Free Cutting)




17-B E32-T24E 2M (Free Cutting)




17-C E32-T33 1M (Free Cutting)



17-D E32-T21-S1 2M (Free Cutting)



17-E E32-TC200BR 2M (Free Cutting)



- Reference Information for Model Selection -



In case of bending sleeve

The E32-TC200BR has a bendable sleeve. Use the Sleeve Bender to bend them.

Sleeve Bender (sold separately)

Appearance	Applicable Fiber Units	Model
Uses for the bending of the sleeve.	E32-TC200BR	E39-F11

iber Sensc

electio

er Units

Threaded

Cylindrical

Flat

Sleeved

Small Spot

High Power

Narrow view

BGS

Retroreflective Limited-

reflective Chemical-

resistant, Oil-resistant Bending

> Heatresistant

Area Detection

Liquid-level

Vacuum FPD,

Semi.

Solar

er Amplifiers, mmunications t, and

> chnical ide and ecautions

> > lodel Index

iber Sensol eatures

selectio Suide

Fiber Units

tallation

Threaded Cylindrical

Flat

Small Spot

High Power

Sleeved

Narrow view BGS

Retroreflective

Limitedreflective

Chemicalresistant, Oil-resistant

> Heatresistant

Bending

Detection

Liquid-level

Area

Vacuum

FPD, Semi, Solar

Installation Information

riber Ampliners, Communications Jnit, and Accessories

> Guide and Precautions

Model Index

Sleeve Fib the point of detection of the shape (Refer to the Appearance)

- Sleeve Fiber Units allow detection away from the point of installation for stable close-range detection of small objects.
- The shape of sleeve can be changed freely.
 (Refer to the sleeve bending specifications in the Appearance column of the specifications table.)



Specifications

Reflective Fiber Units

			Se	nsing dis	stance (mm)		Optical axis		
Sensing direction	Appearance (mm)	Bending radius of cable	ЕЗХ-Н	D	E3NX-FA	NEW	diameter (minimum sensing	Models	19 Page Dimensions No.
		Oi Cable	■GIGA =HS	Other modes	■GIGA =HS	Other mode			NO.
Side-view	The sleeve cannot be bent. 15 3 dia.	Flexible, R1	70	ST : 30 SHS: 8	100	ST : 45 SHS: 8		E32-D24R 2M	19-A
Side-view	Steeve bending 15 radius: 65 4.8 dia. 2.1 dia.	R25	120	ST : 53 SHS: 14	67	ST : 79 SHS: 14		E32-D24-S2 2M <u>NEW</u>	19-B
	The sleeve cannot be bent. 15 3 1.5 dia. IP67	R4	28 8	ST : 12 SHS: 4	42 12	ST : 18 SHS: 4		E32-D43M 1M	19-C
	The sleeve cannot 15 be bent. 15 2 dia. 0.5 dia.		■ 14 4	ST : 6 SHS: 2	■ 21 ■ 6	ST : 9 SHS: 2		E32-D331 2M	19-D
	The sleeve cannot be bent. 15 3 dia. IP67	R25	70	ST : 30 SHS: 8	100	ST : 45 SHS: 8		E32-D33 2M	19-E
	The sleeve cannot 5 be bent. 5 3 dia.	R4	63	ST : 27	94	ST : 40	(5 μm dia./ 2 μm dia.)	E32-D32-S1 0.5M <u>NEW</u>	19-F
Top-view	The sleeve 15 cannot be bent. 15 M3		18	SHS: 7	27	SHS: 7	2 μm dia.)	E32-D31-S1 0.5M <u>NEW</u>	19-G
	Steeve bending 11 radius: 5 mm 40 M3 M3 I.2 dia. IP67	Flexible, R1	40	ST : 60 SHS: 16	60	ST : 90 SHS: 16		E32-DC200F4R 2M	19-H
	The sleeve 15 cannot be bent. 22 4 dia. 1.65 dia.	R10	250	ST : 110	370	ST : 160		E32-D22-S1 2M <u>NEW</u>	19-1
	Sleeve bending 16 radius: 67 M4 1.65 dia.	1110	72	SHS: 30	100	SHS: 30		E32-D21-S3 2M <u>NEW</u>	19-J
	The sleeve 17 cannot be bent. 90 M6 2.5 dia.	Flexible, R1	240	ST : 350 SHS: 100	1,260 360	ST : 520 SHS: 100		E32-DC200BR 2M	19-K
	Sleeve bending 15 10 radius: 10 mm 67 3 3	R10	250 72	ST : 110 SHS: 30	370	ST : 160 SHS: 30		E32-D25-S3 2M <u>NEW</u>	19-L

- Note 1. The following mode names and response times apply to the modes given in the Sensing distance column.
 - [E3X-HD] GIGA: Giga-power mode (16 ms), HS: High-speed mode (250 μs), ST: Standard mode (1 ms), and SHS: Super-high-speed mode (NPN output: 50 μs, PNP output: 55 μs) [E3NX-FA] GIGA: Giga-power mode (16 ms), HS: High-speed mode (250 μs), ST: Standard mode (1 ms), and SHS: Super-high-speed mode (30 μs)
 - 2. The values for the minimum sensing object are reference values that indicate values obtained in standard mode with the sensing distance and sensitivity set to the optimum values. The first value is for the E3X-HD and the second value is for the E3NX-FA.
 - 3. The sensing distances for Reflective Fiber Units are for white paper.

Installation Information → 58, 59 Page

Sleeved


Semi

Dimensions


Reflective Fiber Units

19-A E32-D24R 2M (Free Cutting) Stainless-steel tube 2 dia. 3 dia. (SUS304) Heat-shrinkable tube Two, 1 dia. 1.25 Light baffle Sensing surface


19-B E32-D24-S2 2M (Free Cutting)




19-C E32-D43M 1M (No Cutting)




19-D E32-D331 2M (No Cutting)




19-E E32-D33 2M (Free Cutting)




19-F E32-D32-S1 0.5M (No Cutting)




19-G E32-D31-S1 0.5M (No Cutting)




19-H E32-DC200F4R 2M (Free Cutting)




19-I E32-D22-S1 2M (Free Cutting)




19-J E32-D21-S3 2M (Free Cutting)



19-K E32-DC200BR 2M (Free Cutting)



19-L E32-D25-S3 2M (Free Cutting)



- Reference Information for Model Selection -



In case of bending sleeve

The E32-DC200F4R, E32-D21-S3 and E32-D25-S3 have bendable sleeves. Use the Sleeve Bender to bend them

Sleeve Bender (sold separately)

Appearance	Applicable Fiber Units	Model
Uses for the bending of the sleeve.	E32-DC200F4R E32-D21-S3 E32-D25-S3	E39-F11

Small-Spot, Reflective (Minute Object Detection)

Variable-spot, Parallel-light-spo Integrated lens → This Page

Small-spot Lens Unit → 22 Page

iber Sensol eatures

Selection Suide

Fiber Units

Th

Cylindrical
eput

Small Spot

Sleeved

High Power

Narrow view BGS

Retroreflective
Limited-

> Chemicalresistant, Oil-resistant

reflective

Bending

Heatresistant Area

Detection

Liquid-level

Vacuum

FPD, Semi, Solar

Installation Information

Fiber Amplifiers, Communications Unit, and Accessories

> ecnnical Juide and Precautions


> > Model Index



Small-spot is ideal for detecting minute objects.
 Select the Fiber Unit that is best suited for the workpiece size and installation distance.

(Refer to Reference Information for Model Selection)

 Available with a variable-spot Lens Unit to change the spot diameter without replacing the fiber. The spot diameter can be adjusted according to the size of the workpiece by changing the withdrew length and sensing distance.
 Refer to the following graph, which shows the relation between the withdrew length, focal distance, and spot diameter.



Specifications

--

Reflective Fiber Units

Variable-spot types

Lens Units + Fiber Unit

	Const	Center	Lens Units	Lens Units + Fiber Units	Fibe	21 Page		
Туре	Spot diameter	distance (mm)	Models	Appearance (mm)	Bending radius of cable	Model	Dimensions No.	
Variable spot 0.6 dia. 0.7 dia. 0.8 dia.	6 to 15	E39-F3A	23 2 dia. 6 dia.	- R25	E32-C42 1M	21-A		
		10 to 30	E39-F17	22.2 2 dia. 6 dia.	1123	E32-042 IM	21-B	

Parallel-light-spot types

Lens Units + Fiber Unit

	Spot	Center	Lens Units	Lens Units + Fiber Units	Fiber	21 Page	
Туре	diameter			Appearance (mm)	Bending radius of cable	Models	Dimensions No.
Dovallal light	4 dia	0 to 20		10.9 M3 5 dia.	R25	E32-C31 2M	21-C
raranet light	rallel light 4 dia. 0 to 20 E39-F3C	10.9 5 dia. M3	Flexible, R2	E32-C21N 2M <u>NEW</u>	21-D		

Small-spot types


Integrated Lens

og.u.ou =						
Туре	Spot diameter	Center distance (mm)	Appearance (mm)	Bending radius of cable	Models	21 Page Dimensions No.
Short-distance, Small-spot	0.1 dia.	5	Lens: unnecessary		E32-C42S 1M	21-E
Long-distance, Small-spot	6 dia.	50	11.6 29 Lens: unnecessary 25.6 [IP50	R25	E32-L15 2M	21-F

^{*} The spot diameter and the center distance are the same when using with E3X-HD series or E3NX-FA series.


■ Reflective Fiber Units

21-A E32-C42 1M (No Cutting) + E39-F3A



* Attached with adhesive and cannot be removed. Note: There is a white tube on the emitter fiber

E39-F3A




Material:

Aluminum for body and optical glass for lens.

Small-Spot, Reflective (Minute Object Detection)

Note: This is the Lens Unit for the E32-C42.

21-B E32-C42 1M (No Cutting) + E39-F17



* Attached with adhesive and cannot be removed Note: There is a white tube on the emitter fiber.


E39-F17



Material:


optical glass for lens.

21-C E32-C31 2M (Free Cutting) + E39-F3C



Note: There is a white line on the emitter fiber

E39-F3C



Material:

optical glass for lens.

Note: This is the Lens Unit for the E32-C31 and E32-C31N.

21-D E32-C21N 2M (Free Cutting) + E39-F3C



(ABS resin): 3.5 dia.


Note: There is a white line on the emitter fiber

White marks: Emitter side

Fiber Attachment*

(heat-shrinkable tube)

21-F E32-L15 2M (Free Cutting)



* Attached with adhesive and cannot be removed. Note: There is a white tube on the emitter fiber.

Reference Information for Model Selection -


21-E E32-C42S 1M (No Cutting)

3 dia.

Model Selection Tips

Select the best model by following these steps.

- 1. Select the model based on the spot diameter suitable for the workpiece size.
 - * The Variable-spot Type is useful if there are different sensing object sizes.
- 2. Select the model based on the allowable installation distance and center distance



		V		V				
Spot diameter	0.1 dia.	0.1 dia.	0.2 dia.	0.5 dia.	0.5 dia.	3 dia.	4 dia.	6 dia.
Center distance	5	7	17	7	17	50	0 to 20	50
Optical axis diameter	2.4	3.7	4.8	3.7	4.8	9.4	3.7	10
Models	E32-C42S	E39-F3A-5 + E32-C41	E39-F3B + E32-C41	E39-F3A-5 + E32-C31 E32-C21N	E39-F3B + E32-C31 E32-C21N	E39-F18 + E32-CC200 E32-C91N	E39-F3C + E32-C31 E32-C21N	E32-L15

* Refer to page 22 for details.

Cylindrical

Flat

Sleeved

Small Spot

High Power

Narrow view

BGS

Retroreflective

Limitedreflective

Chemicalresistant. Oil-resistant

Bending

resistant

Area Detection

Liquid-level

Vacuum

FPD. Semi Solar

Cylindrical Flat

Sleeved

Small Spot

High Power

Narrow view

BGS

Retro-reflective Limited-

Chemicalresistant, Oil-resistant

Bending

Heatresistant

Area Detection Liquid-level

Vacuum FPD, Semi, Solar



· Small-spot is ideal for detecting minute objects. Select the Fiber Unit that is best suited for the workpiece size and installation

(Refer to Reference Information for Model Selection)

Specifications

Reflective Fiber Units

Small-spot Models

Lens Units + Fiber Units

	Spot	Center	Lens Units	Lens Units + Fiber Units	Fiber	Units	23 Page
Туре	diameter	distance (mm)	Models	Appearance(mm)	Bending radius of cable	Models	Dimensions No.
	0.1 dia.			16.5 M3 5 dia.	R25	E32-C41 1M	23-A
Short- distance, small-spot	0.5 dia.	7	E39-F3A-5	HZ5	E32-C31 2M	23-B	
	0.5 dia.			16.5 5 dia. M3	Flexible, R2	E32-C21N 2M <u>NEW</u>	23-C
	0.2 dia.			25.2 M3	- R25	E32-C41 1M	23-D
Medium- distance, small-spot	0.5 dia.	17	E39-F3B	25.2 6 dia.	H25	E32-C31 2M	23-E
	0.5 dia.			25.2 6 dia. M3	Flexible, R2	E32-C21N 2M <u>NEW</u>	23-F
Long- distance,	² , 3 dia. 50 E39-F1		E39-F18	30 M6 10 dia.	R25	E32-CC200 2M	23-G
	3 uia.	30	E39-T10	30 M6 10 dia.	Flexible, R4	E32-C91N 2M	23-H

 $^{^{\}star}$ The spot diameter and the center distance are the same when using with E3X-HD series or E3NX-FA series.

Installation Information → 58, 61 Page

Area Detection

Liquid-level

FPD, Semi.

Solar

Installation Information

oer Amplifiers, ommunications iit, and


> ide and cautions

> > odel Index

Dimensions

Defication






* Attached with adhesive and cannot be removed.

Note: There is a white tube on the emitter fiber

23-B E32-C31 2M (Free Cutting) + E39-F3A-5



E39-F3A-5

Straight knurling

2.1 dia.

2.1 dia.

Straight knurling

2.1 dia.

M3x0.5

Effective screw length: 3

Material:

Aluminum for body and optical glass for lens

Note: This is a Lens Unit for the E32-C41, E32-C31 and E32-C31N.

M3×0.5

Depth: 4.4

 $(\bigcirc$

5.5

Note: This is a Lens Unit for the E32-C91N and E32-CC200.


23-C E32-C21N 2M (Free Cutting) + E39-F3A-5



-24.1

Note: This is a Lens Unit for the E32-C41, E32-C31 and E32-C31N.





* Attached with adhesive and cannot be removed. Note: There is a white tube on the emitter fiber.

23-F E32-C21N 2M (Free Cutting) + E39-F3B

E39-F3B

Material:

E39-F18

Material:

glass for lens

Aluminum for body and optical


glass for lens

6 dia.




10 dia

23-E E32-C31 2M (Free Cutting) + E39-F3B




Note: There is a white line on the emitter fiber

23-G E32-CC200 2M (Free Cutting) + E39-F18



Note: There is a white line on the emitter fiber.

(23-H) E32-C91N 2M (Free Cutting) + E39-F18



Spot diameter Center distance Optical axis diame

Models

Note: There is a white line on the emitter fiber

- Reference Information for Model Selection -

Model Selection Tips

Select the best model by following these steps.

- Select the model based on the spot diameter suitable for the workpiece size.
 - * The Variable-spot Type is useful if there are different sensing object sizes.
- 2. Select the model based on the allowable installation distance and center distance.

	<map of="" sp<="" th=""><th>ot Diameters</th><th>and Center</th><th>Distances></th><th></th><th></th><th></th><th>(Unit: mm)</th></map>	ot Diameters	and Center	Distances>				(Unit: mm)
	Optical axis diameter .	Center distance		•	•		ľ	
	0.1 dia.	0.1 dia.	0.2 dia.	0.5 dia.	0.5 dia.	3 dia.	4 dia.	6 dia.
	5	dia. 0.1 dia. 0.2 dia. 0.5 dia. 0.5 dia. 3 dia. 4 dia. 6 dia. 7 17 7 17 50 0 to 20 50 4 3.7 4.8 3.7 4.8 9.4 3.7 10			50			
eter	2.4	3.7	4.8	3.7	4.8	9.4	3.7	10
	E32-C42S	+	+	+ E32-C31	+ E32-C31	+ E32-CC200	+ E32-C31	E32-L15

* Refer to page 20 for details.

High-power Beam (Long-distance Installation, Dust-resistant) Fiber only → This Page

Lens (to 70° C) \rightarrow 26 Page

iber Sensol eatures

electio iuide

Fiber Units

Threaded

Cylindrical

ing Space

Flat

Sleeved

Small Spot

High Powe Narrow view

BGS

Retroreflective

Chemicalresistant, Oil-resistant

ovements

Beam Imp

ınity Transparent Ol

Environmental Im

Heatresistant

Area Detection

Liquid-level

Vacuum


ications

FPD, Semi, Solar

Fiber Amplifiers, Communications Unit, and Accessories

> Technical Guide and Precautions

Model Index



- Maximum sensing distance without attaching a Lens: 20 m (E32-T17L)
 Suitable for detection of large objects and for use in large-scale installations.
- Powerful enough to resist the influences of dust and dirt.
 (Refer to the comparisons of incident level on the Reference Information for Model Selection.)
- In addition to the products listed on this page, Lenses are available to extend the sensing distance. (→ 26 to 29 pages)

Specifications

■→■ Through-beam Fiber Units

				S	Sensing dis	stance (mm)		Optical axis		
Sensing direction	Aperture angle	Appearance (mm)	Bending radius of cable	E3X-HD	•	E3NX-FA	<u>NEW</u>	diameter (minimum sensing	Models	25 Page Dimensions No.
			0.000.0	■GIGA HS Other modes ■GIGA		■GIGA=HS	Other modes	object)		
Right-	15°	14.4	Flexible,	4,000 *1	ST : 3,500	4,000 *1	ST : 4,000	2.3 dia. (0.1 dia./	E32-LT11N 2M	25-A
angle		M4 Build-in Lens	R2	2,300	SHS: 920	3,450	SHS: 920	0.03 dia.)	<u>NEW</u>	
	400	42		20,000 *2	*2 ST : 20,000	20,000 *2	*2 ST : 20,000			
	10°	M14 [P67		20,000 *2	SHS: 8,000	20,000 *2	SHS: 8,000	10 dia.	E32-T17L 10M	25-B
			R25	4,000 *1	*1 ST : 4,000	4,000 *1	*1 ST : 4,000			
Top-view		15		2,700	SHS: 1,080	4,000 *1	SHS: 1,080	2.3 dia. (0.1 dia./	E32-LT11 2M <u>NEW</u>	
	15°	M4	Flexible,	4,000 *1	ST : 3,500	4,000 *1	*1 ST : 4,000	0.03 dia.)		25-C
	Buildin Lens	Build-in Lens IP50	R1	2,300	SHS: 920	3,450	SHS: 920		E32-LT11R 2M <u>NEW</u>	
		10.5		4,000 *1	*1 ST : 4,000	4,000 *1	*1 ST : 4,000	4 dia.		
Side-view 3	30°	36.4 8	R25	4,000 *1	SHS: 1,800	4,000 *1	SHS: 1,800	(0.1 dia./ 0.03 dia.)	E32-T14 2M	25-D

- *1 The optical fiber is 2 m long on each side, so the sensing distance is 4,000 mm.
- *2 The optical fiber is 10 m long on each side, so the sensing distance is 20,000 mm.

Reflective Fiber Units

				S	ensing dis		Optical axis					
Sensing direction			Bending radius E3X-HD of cable		D E3NX-FA _		E3NX-FA <u>NEW</u>		E3NX-FA NEW (minimum sensing		Model	25 Page Dimensions No.
		or capic	■GIGA=HS	Other modes	■GIGA=HS	Other modes	object)					
Top-view	4 °	9 17.5 IP40	Bendresistant, R4		ST : 40 to 1,400 SHS: 40 to 480	40 to 4,000 40 to 1,350	ST :40 to 2,100 SHS:40 to 480	_	E32-D16 2M	25-E		

Note The following mode names and response times apply to the modes given in the Sensing distance column.

- 1. [E3X-HD] GIGA: Giga-power mode (16 ms), HS: High-speed mode (250 μs), ST: Standard mode (1 ms), and SHS: Super-high-speed mode (NPN output: 50 μs, PNP output: 55 μs) [E3NX-FA] GIGA: Giga-power mode (16 ms), HS: High-speed mode (250 μs), ST: Standard mode (1 ms), and SHS: Super-high-speed mode (30 μs)
- The values for the minimum sensing object are reference values that indicate values obtained in standard mode with the sensing distance and sensitivity set to the optimum values.

 2. The first value is for the E3X-HD and the second value is for the E3NX-FA.
- The sensing distances for Reflective Fiber Units are for white paper.

Sleeved


BGS

del Index


Dimensions

JIIIICI1310113


Through-beam Fiber Units (Set of 2)








25-C E32-LT11 2M (Free Cutting) E32-LT11R 2M (Free Cutting)



25-D E32-T14 2M (Free Cutting)




Installation Information → 58 Page

Beam Improvements

Installation Information → 59, 60 Page

Reflective Fiber Units


25-E E32-D16 2M (Free Cutting)




- Reference Information for Model Selection -

Comparisons of incident level

Select the model based on the comparisons of incident level against Standard Fiber Units.





High-power Beam (Long-distance Installation, Dust-resistant) **Fiber only** → 24 Page

Lens (to 70° C) \rightarrow This Page

Cylindrical

Flat

Sleeved

Narrow

BGS

Small Spot High Powe

view

Retro-reflective Limitedreflective

Chemicalresistant, Oil-resistant

> Bendina Heatresistant

Area Detection

Liquid-level

Vacuum FPD, Semi.

Solar

Specifications

Specifications						
Through-be	eam Fiber Uni	ts				
Lens Units	Туре	High-power (incident level: 50 times)	Ultra-high-power (incident level: 160 times)	Side-View (incident level: 0.8 times)		
	Models	E39-F1	E39-F16	E39-F2		
	Appearance	26-A	26-B	26-C)		

		Appearance				26-A	•			26-B		100	0	26-C
				Appro	ox. 12°			Appr	ox. 6°		Approx. 60°			
Optical axis diameter (minimum sensing object)		4 dia. (0.1 dia.) 7.2 dia.					3 dia. (0.1 dia.)							
			Sensing distance (mm)											
Models	Appearance (mm)		E3X-		E3NX-FA		E3X-		E3NX-F	_	E3X-		E3NX-F	_
			■GIGA =HS	Other modes	■GIGA=HS	Other modes	■GIGA=HS	Other modes	■GIGA=HS	Other modes	■GIGA=HS	Other modes	■GIGA=HS	Other modes
E32-T11N 2M	14	M4		ST :4,000 SHS:2,000		* ST : 4,000 SHS: 2,000		ST: 4,000 SHS: 3,600		* ST : 4,000 SHS: 3,600		_	_	_
E32-T11R 2M	1.	4 M4		SHS: 2,000		* ST : 4,000 SHS: 2,000		SHS: 3,600		* ST : 4,000 SHS: 3,600		ST : 800 SHS: 200		ST : 1,200 SHS: 200
E32-T11 2M	14	4 M4	4.000*	SHS: 1,860		* ST : 4,000 SHS: 1,860		SHS: 4,000 * SHS: 4,000		* ST : 4,000 * SHS: 4,000		ST : 1.320 SHS: 320		ST : 1,980 SHS: 320

 $^{^{\}star}\,$ The optical fiber is 2 m long on each side, so the sensing distance is 4,000 mm.

Note 1. The following mode names and response times apply to the modes given in the Sensing distance column.


[E3X-HD] GIGA: Giga-power mode (16 ms), HS: High-speed mode (250 μ s), ST: Standard mode (1 ms), and SHS: Super-high-speed mode (NPN output: 50 μ s, PNP output: 55 μ s) [E3NX-FA] GIGA: Giga-power mode (16 ms), HS: High-speed mode (250 μ s), ST: Standard mode (1 ms), and SHS: Super-high-speed mode (30 μ s)


2. The values for the minimum sensing object are reference values that indicate values obtained in standard mode with the sensing distance and sensitivity set to the optimum values. The first value is for the E3X-HD and the second value is for the E3NX-FA.

Dimensions

Installation Information → 61 Page

Lens Units (Set of 2)





Brass for the body and optical glass for the lens itself.

Note: Two per set.

Beam Improvements

Installation Information → 60, 61 Page

Small Spot

Limitedreflective


FPD,

Nodel Index


Dimensions

Through-beam Fiber Units (Set of 2)







27-B E32-T11R 2M (Free Cutting) + E39-F1




27-C E32-T11 2M (Free Cutting) + E39-F1




27-D E32-T11N 2M (Free Cutting) + E39-F16




27-E E32-T11R 2M (Free Cutting) + E39-F16




27-F E32-T11 2M (Free Cutting) + E39-F16



27-G E32-T11R 2M (Free Cutting) + E39-F2



27-H E32-T11 2M (Free Cutting) + E39-F2




- Reference Information for Model Selection -

Comparisons of incident level

Select the model based on the comparisons of incident level against Standard Fiber Units.

Comparisons of incident level (Through-beam)



Cylindrical

Flat

Sleeved

Small Spot

High Powe

Narrow

BGS

Retroreflective Limitedreflective Chemicalresistant. Oil-resistant Bendina

view

resistant Detection

Heat-

Area

Liquid-level

Vacuum

FPD, Semi. Solar

Specifications

Through-beam Fiber Units (Heat-resistant)

			•											
	Lens Units	Туре	High-pov	ver (incid	ent level: 5	0 times)	Ultra-high	-power (inc	ident level:	160 times)	Side-Vie	w (incide	nt level: 0	.8 times)
		Models		E39)-F1			E39-	F16			E39-	F2	
		Appearance	(8-A)			•			28-B		100		28-C	
		Aperture angle	Approx. 12°			Approx. 6°				Approx. 60°				
Fiber Units		Optical axis diameter (minimum sensing object)		4 dia. (0.1 dia.)		7.2 dia.				3 dia. (0.1 dia.)			
							Sen	sing dis	g distance (mm)					
Models	Appearance (mm)		E3X	-HD	E3NX-FA		ЕЗХ	-HD	E3NX-FA	<u>NEW</u>	E3X-HD		E3NX-FA NE	
			■GIGA =HS	Other modes	■GIGA=HS	Other modes	■GIGA=HS	Other modes	■GIGA=HS	Other modes	■GIGA=HS	Other modes	■GIGA=HS	Other
	Heat-resistant up to		4,000*	ST : 4,000	4,000*	ST : 4,000	4,000*	ST :4,000	4,000*	ST : 4,000	1,400	ST : 720	2,100	ST : 1,080
E32-T51R 2M		14 M4	3,900	SHS: 1,500	4,000*	SHS: 1,500	4,000*	SHS: 4,000	4,000*	SHS: 4,000	■500	SHS: 200 29-G	■ 750	SHS: 200
	Heat-resistant up to		4,000*	ST : 4,000	4,000*	ST : 4,000	4,000*	ST :4,000	4,000*	ST :4,000	1,000	ST : 550	1,500	ST : 820
E32-T81R-S 2M	20 M4		2,700	SHS: 1,000	4,000*	SHS: 1,000	4,000*	SHS: 1,800	4,000*	SHS: 1,800	□360	SHS: 140	540	SHS: 140
E32-T61-S 2M	Heat-resistant up to 3 (200°C) (See Note 3)	350°C		ST : 4,000		ST : 4,000	4,000*	ST :4,000		ST :4,000	1,000	ST : 900	2,520	ST : 1,350
E02"101"3 ZM		20 M4		SHS: 1,800	4,000*	SHS: 1,800	4,000*	SHS: 3,100	4,000*	SHS: 3,100	■ 600	SHS: 240	900	SHS: 240

 $^{^{\}star}\,$ The optical fiber is 2 m long on each side, so the sensing distance is 4,000 mm.

Note 1. The following mode names and response times apply to the modes given in the Sensing distance column.

[E3X-HD] GIGA: Giga-power mode (16 ms), HS: High-speed mode (250 μ s), ST: Standard mode (1 ms), and SHS: Super-high-speed mode (NPN output: 50 μ s, PNP output: 55 μ s) [E3NX-FA] GIGA: Giga-power mode (16 ms), HS: High-speed mode (250 μ s), ST: Standard mode (1 ms), and SHS: Super-high-speed mode (30 μ s)

- 2. The values for the minimum sensing object are reference values that indicate values obtained in standard mode with the sensing distance and sensitivity set to the optimum values. The first value is for the E3X-HD and the second value is for the E3NX-FA.
- 3. The ambient temperature of E32-T61-S must be between -40 to 200°C when using it with E39-F1 or E39-F2 Lens Unit. The ambient temperature of E32-T61-S must be between -40 to 350°C when using it with E39-F16 Lens Unit.

	Lens Units	Туре	High-power (incid	lent level: 50 times	Ultra-high-power (i	Ultra-high-power (incident level: 160 times)				
	Mod			F1-33	E	E39-F16				
		Appearance	6	28-D		28-B				
		Aperture angle	Appr	ox. 12°	Ар	Approx. 6°				
Fiber Units (m		Optical axis diameter (minimum sensing object)	4 dia.	(0.1 dia.)	7.2 dia.					
			Sensing distance (mm)							
Models	App	pearance (mm)	E3X-HD	E3NX-FA NEW	E3X-HD	E3NX-FA <u>NEW</u>				
			■GIGA=HS Other modes	■GIGA=HS Other modes	■GIGA=HS Other mode	GIGA=HS Other modes				
E32-T51 2M	Heat-resistant up to	o 150°C	4,000* ST : 4,000 2,300 SHS: 1,400	4,000* ST : 4,00	4,000* ST :4,00	4,000* ST : 4,000 30 SHS: 4,000				

 $^{^{\}star}\,$ The optical fiber is 2 m long on each side, so the sensing distance is 4,000 mm.


Note 1. The following mode names and response times apply to the modes given in the Sensing distance column.


[E3X-HD] GIGA: Giga-power mode (16 ms), HS: High-speed mode (250 \(\nu\)s), ST: Standard mode (1 ms), and SHS: Super-high-speed mode (NPN output: 50 \(\nu\)s, PNP output: 55 \(\nu\)s [E3NX-FA] GIGA: Giga-power mode (16 ms), HS: High-speed mode (250 μ s), ST: Standard mode (1 ms), and SHS: Super-high-speed mode (30 μ s)

2. The values for the minimum sensing object are reference values that indicate values obtained in standard mode with the sensing distance and sensitivity set to the optimum values. The first value is for the E3X-HD and the second value is for the E3NX-FA.

Dimensions

Installation Information → 61 Page





29-G E32-T51R 2M (Free Cutting) + E39-F2

5.7

-- 20.2

5.7

29-I E32-T61-S 2M (No Cutting) + E39-F2

29-H E32-T81R-S 2M (No Cutting) + E39-F2

Beam Improvements

Installation Information → 60, 61 Page

2,000

Flat

Small Spot

Solar

iber Amplifiers, Communications Unit, and

> ide and scautions

> > Model Index


Dimensions

Through-beam Fiber Units (Set of 2)







29-B E32-T81R-S 2M (No Cutting) + E39-F1



29-C E32-T61-S 2M (No Cutting) + E39-F1




29-J E32-T51 2M (Free Cutting) + E39-F1-33




M4D0.7 (SUS303)




29-D E32-T51R 2M (Free Cutting) + E39-F16



29-K E32-T51 2M (Free Cutting) + E39-F16



29-F E32-T61-S 2M (No Cutting) + E39-F16




- Reference Information for Model Selection -

Comparisons of incident level

Select the model based on the comparisons of incident level against Standard Fiber Units.

Comparisons of incident level (Through-beam)



Narrow View (Detection Across clearance)

Cylindrical

Flat

Sleeved

Small Spot

High Power

Narrow view BGS


Retro-reflective Limited-

Chemicalresistant, Oil-resistant Bending Heatresistant

Detection Liquid-level

Area

Vacuum FPD, Semi. Solar



• The fine beam prevents false detection of light that is reflected off surrounding objects.



Specifications

Through-beam Fiber Units

		Appearance (mm)	Bending radius of cable	Se	ensing dis	tance (mm)	Optical axis		04 8	
Sensing direction	Aperture angle			E3X-HD		E3NX-FA <u>NEW</u>		diameter (minimum sensing	Models	31 Page Dimensions No.
			or ouble	■GIGA=HS	Other modes	■GIGA=HS	Other modes	object)		140.
	1.50	Thickness: 3 mm IP50	Flexible, R1	3,220	ST : 1,780	4,000*	ST : 2,670	2 dia. (0.1 dia./ 0.03 dia.)	E32-A03 2M	31-A
	1.5	24.5 10 Thickness: 3 mm IP50		1,200	SHS: 500	1,800	SHS: 500		E32-A03-1 2M	31-B
	3.4°	Thickness: 2 mm IP50	R10	1,280 450	ST : 680 SHS: 200	1,920	ST : 1,020 SHS: 200	1.2 dia. (0.1 dia./ 0.03 dia.)	E32-A04 2M	31-C
		20.5 3.5 dia.	Flexible, R1	1,460	ST : 2,200 SHS: 580	4,000* 2,190	ST : 3,300 SHS: 580	2 dia. - (0.1 dia./	E32-T24SR 2M	31-D
	4°	3.5 tida.		1,740	ST : 2,600 SHS: 700	2,610	ST : 3,900 SHS: 700	0.03 dia.)	E32-T24\$ 2M	31-E
Top-view		15 3 dia. IP50	RIO	4,000*	ST : 3,800 SHS: 1,000	4,000*	ST : 4,000 SHS: 1,000	1.7 dia. (0.1 dia./ 0.03 dia.)	E32-T22S 2M	31-F

 $^{^{\}star}\,$ The optical fiber is 2 m long on each side, so the sensing distance is 4,000 mm.

Note 1. The following mode names and response times apply to the modes given in the Sensing distance column.

[E3X-HD] GIGA: Giga-power mode (16 ms), HS: High-speed mode (250 μ s), ST: Standard mode (1 ms), and SHS: Super-high-speed mode (NPN output: 50 μ s, PNP output: 55 μ s) $[E3NX-FA]\ GIGA:\ Giga-power\ mode\ (16\ ms),\ HS:\ High-speed\ mode\ (250\ \mu s),\ ST:\ Standard\ mode\ (1\ ms),\ and\ SHS:\ Super-high-speed\ mode\ (30\ \mu s)$

2. The values for the minimum sensing object are reference values that indicate values obtained in standard mode with the sensing distance and sensitivity set to the optimum values. The first value is for the E3X-HD and the second value is for the E3NX-FA.


Narrow View (Detection Across clearance)

Dimensions

Installation Information → 58, 60 Page


Through-beam Fiber Units (Set of 2)

31-A E32-A03 2M (Free Cutting)



Note: Use the engraved surface and its opposing surface as installation (reference) surfaces


31-B E32-A03-1 2M (Free Cutting)



Note 1: Use the engraved surface and its opposing surface as installation (reference) surfaces.


Note 2: Set of two symmetrically shaped Fiber Units.

31-C E32-A04 2M (Free Cutting)




Note: Use the engraved surface and its opposing surface as installation (reference) surfaces.


31-D E32-T24SR 2M (Free Cutting)



31-E E32-T24S 2M (Free Cutting)



31-F E32-T22S 2M (Free Cutting)



Reference Information for Model Selection -

Aperture angle and Optical Axis Diameter

The Aperture angle is the output angle of the emitted beam, and the optical axis diameter is the core diameter of the emitter fiber. A fiber with a narrow view has a larger optical axis diameter than standard fibers, but the aperture angle is smaller so it is not influenced by surrounding objects.



Cylindrical

Flat

Sleeved

Small Spot

High Power

Narrow view

BGS

Retroreflective

Limitedreflective Chemical-

resistant, Oil-resistant Bending

resistant

Area Detection

Liquid-level

Vacuum FPD,

Semi.

Solar

Detection without Background Interference

ilber Sensor eatures

election iuide

Fiber Units

nstallation

Threaded

Cylindrical

Flat
Sleeved

Small Spot

High Power
Narrow

view

Retroreflective Limited-

Chemicalresistant, Oil-resistant

Bending

Heatresistant

Area Detection

Liquid-level

FPD, Semi, Solar

Installation Information


iber Amplifiers, Communications Jnit, and Accessories

> echnical iuide and recautions

> > Model Index



 These Fiber Units detect only objects in the sensing range. Objects in the background that are located beyond a certain point are not detected.
 They are not easily affected by the material or color of the sensing object.



Specifications

Limited-reflective Fiber Units

Sensing direction		Bending radius of cable	Se	ensing dis	tance (mm)		Standard		
	Appearance (mm)		E3X-HD		E3NX-FA <u>NEW</u>		sensing object (minimum sensing	Models	33 Page Dimensions No.
		or capic	■GIGA=HS	Other modes	■ GIGA=HS	Other modes	object)		No.
Flat-view	20.5 3.8 14 IP40	R25	0 to 15	ST : 0 to 15	0 to 15 0 to 15	ST : 0 to 15	Soda glass with reflection factor of 7%	E32-L16-N 2M	33-A
riat-view	14 2.5 I			ST : 0 to 4 SHS: 0 to 4		ST : 0 to 4 SHS: 0 to 4	(5 μm dia./	E32-L24S 2M	33-B
Side-view	18 4 16	H10	5.4 to 9 5.4 to 9 (Center 7.2)	ST : 5.4 to 9 SHS: 5.4 to 9 (Center 7.2)	5.4 to 9 5.4 to 9 (Center 7.2)	ST : 5.4 to 9 SHS: 5.4 to 9 (Center 7.2)	2 μm dia.)	E32-L25L 2M	33-C

Note 1. If operation is affected by the background, perform power tuning or use the ECO Mode to decrease the incident light level.

- 2. The following mode names and response times apply to the modes given in the Sensing distance column.

 [E3X-HD] GIGA: Giga-power mode (16 ms), HS: High-speed mode (250 µs), ST: Standard mode (1 ms), and SHS: Super-high-speed mode (NPN output: 50 µs, PNP output: 55 µs) [E3NX-FA] GIGA: Giga-power mode (16 ms), HS: High-speed mode (250 µs), ST: Standard mode (1 ms), and SHS: Super-high-speed mode (30 µs)
- 3. The values for the minimum sensing object are reference values that indicate values obtained in standard mode with the sensing distance and sensitivity set to the optimum values. The first value is for the E3X-HD and the second value is for the E3NX-FA.
- 4. The sensing distances for Reflective Fiber Units are for white paper


Dimensions

Installation Information → 59 Page




Limited-reflective Fiber Units


33-A E32-L16-N 2M (Free Cutting)



33-B E32-L24S 2M (Free Cutting)




33-C E32-L25L 2M (Free Cutting)




- Reference Information for Model Selection -

Sensing Distance vs. Digital Value

The following graphs show how the digital value is high within the sensing range and small outside. This explains why false detection does not occur outside the sensing range, even against common metal backgrounds, such as stainless steel.







Cylindrical

Flat Sleeved

Small Spot

High Power

Narrow view

BGS

Retroreflective Limited-

reflective Chemicalresistant,

Oil-resistant Bending

resistant

Area Detection

Liquid-level

Vacuum FPD,

Semi. Solar

White paper Black paper

SUS304

Glass, t = 0.7

Retro-reflective

Retro-reflective → This page Limited-reflective → 36 page

Cylindrical

Flat Sleeved

Small Spot **High Power**

Narrow view BGS

Chemical-Oil-resistant Bendina

reflective Limited-

resistant

Area Detection

Liquid-level

Vacuum


FPD, Semi. Solar

· Retro-reflective Fiber Units are ideal for detecting transparent objects. The light beam passes through the object twice, this model interrupts light more than Through-beam model.



 Excellent detection performance with transparent films. (E32-LR11NP + E39-RP1)

The specially designed filter eliminates undesirable light, which allows significantly more light to be interrupted for stable detection of films.



Specifications

Retro-reflective Fiber Units (With M.S.R. Function)

Ту	ре		Panding		Sensing dis	stance (mm)	Optical axis diameter		OF Domo	
Features 5	Size	Appearance (mm)	Bending radius of cable	E3X-HD		E3NX-FA <u>NEW</u>		(minimum sensing	Models	35 Page Dimensions No.
				■GIGA=HS	Other modes	■GIGA=HS	Other modes	object)		
Film detection *	М6	8.5 / 44 15.8 80 M6 Belitáin J.ens IP50	Flexible, R2	1,350	ST : 1,200 SHS: 550	2,020	ST : 1,800 SHS: 550	-	E32-LR11NP 2M + E39-RP1 <u>NEW</u>	35-A
Square	_	42 21.5 10 IP66	R25	150 to 1,500 150 to 1,500	ST : 150 to 1,500 SHS: 150 to 1,500	150 to 1,500 150 to 1,500	ST : 150 to 1,500 SHS: 150 to 1,500	(0.2 dia./ 0.07 dia.)	E32-R16 2M	35-B
Threaded Models	M6	27.8 M6 IP67	R10	10 to 250 10 to 250	ST : 10 to 250 SHS: 10 to 250	10 to 370	ST : 10 to 370 SHS: 10 to 250	(0.1 dia./ 0.03 dia.)	E32-R21 2M	35-C

^{*} This effect may not be as strong for some films. Check suitability beforehand.

Note 1. Objects with a high reflection factor may cause the Fiber Sensor to detect reflected light as incident light. Also, stable detection may not be possible for transparent objects. Check suitability beforehand.


- 2. The following mode names and response times apply to the modes given in the Sensing distance column. [E3X-HD] GIGA: Giga-power mode (16 ms), HS: High-speed mode (250 μ s), ST: Standard mode (1 ms), and SHS: Super-high-speed mode (NPN output: 50 μ s, PNP output: 55 μ s) [E3NX-FA] GIGA: Giga-power mode (16 ms), HS: High-speed mode (250 μs), ST: Standard mode (1 ms), and SHS: Super-high-speed mode (30 μs)
- 3. The values for the minimum sensing object are reference values that indicate values obtained in standard mode with the sensing distance and sensitivity set to the optimum values. The first value is for the E3X-HD and the second value is for the E3NX-FA.


Dimensions

Installation Information → 58, 59 and 61 Page


Retro-reflective Fiber Units (With M.S.R. Function)

35-A E32-LR11NP 2M (Free Cutting)





E39-RP1



Cylindrical

Flat

Sleeved

Small Spot

High Power

Narrow view

BGS

Retroreflective

Limitedreflective

Chemicalresistant, Oil-resistant

Bending

resistant


Area Detection

Liquid-level


Vacuum FPD,

Semi. Solar


35-B E32-R16 2M (Free Cutting)




E39-R1 (Provided)



E32-R21 2M (Free Cutting)



E39-R3 (Provided)



Reference Information for Model Selection -

Performance Comparison of Transparent Object Detection

For detecting transparent objects, consider using following products together: E32-LR11NP 2M + E39-RP1.

- · This configuration features a special built-in optical filter that ensures stable detection of double-refractive materials, such as films and PET bottles.
- · The retro-reflective model is suitable for detecting glass.

Sensing object Models	Film wrapper on cigarette packs		Glass bottles	Plate glass, t: 0.7
E32-LR11NP 2M + E39-RP1	0	0	0	0
E32-R16 2M	Δ	Δ	0	0
E32-R21 2M	\triangle	\triangle	0	0

E32-LR11NP Usage in Combination with a Sheet Reflector

Reference values of sensing distance are provided in the following table.

Reflector shape	Sensing of	listance (m			
(mm)	E3X	-HD	E3NX-F/	NEW	Models
()	■GIGA=HS	Other modes	■GIGA=HS	Other modes	
50	550	ST : 500 SHS: 250	820 640	ST : 750 SHS: 250	E39-RSP1
13.7	2 10 1 60	ST : 190	310 240	ST : 280	E39-RP37

Limited-reflective (Glass Detection)

Cylindrical

Flat

Sleeved

Small Spot **High Power**

Narrow view

Retroreflective

BGS

Limited-

Oil-resistant

Bendina


Heatresistant

Area Detection


Liquid-level

Vacuum

FPD, Semi. Solar



· These Fiber Units are based on a limited-reflective optical system where the emitting light and receiving light axes intersect at the same angle. This allows for stable detection of glass because the Fiber Units receives the specular reflection of the glass when the glass is in the sensing range.



Specifications

Limited-reflective Fiber Units

Ту	ре			Sensing distance (mm)				Standard		
Features	Detection direction	Appearance (mm)	Bending radius of cable	E3X-HD		E3NX-FA <u>NEW</u>		sensing object (minimum	Models	37 Page Dimensions No.
	unoonon			■GIGA=HS	Other modes	■GIGA=HS	Other modes	sensing object		110.
Small		14 2.5 1	R10	0 to 4	ST : 0 to 4	0 to 4	ST : 0 to 4	(5 μm dia./	E32-L24S 2M	37-A
size		11		0 to 4	SHS: 0 to 4	0 to 4	SHS: 0 to 4	2 μm dia.)	E32-L243 2M	0.7
		20.5		0 to 15	ST : 0 to 15	0 to 15	ST : 0 to 15			
Standard	Flat-	3.8 14 IP40		0 to 15	SHS: 0 to 12	0 to 15	SHS: 0 to 12		E32-L16-N 2M	37-B
Glass- substrate	view	24.5 ~	D05	10 to 20	ST : 10 to 20	10 to 20	ST : 10 to 20	Soda glass with		
alignment, 70°C		51 14 IP40	R25	== 10 to 20	SHS: -	10 to 20	SHS: -	reflection factor of 7%	E32-A08 2M *	(37-C)
Standard		24.5		12 to 30	ST : 12 to 30	12 to 30	ST : 12 to 30		F20 440 014	
long distance		51 14 IP40		12 to 30	SHS: -	12 to 30	SHS: -		E32-A12 2M	(37-D)
Side	Side-	18		5.4 to 9	ST : 5.4 to 9	5.4 to 9	ST : 5.4 to 9	(5 μm dia./		
View form	view	16 IP50	R10	5.4 to 9 (Center 7.2)	SHS: 5.4 to 9 (Center 7.2)	5.4 to 9 (Center 7.2)	SHS: 5.4 to 9 (Center 7.2)	2 μm dia.)	E32-L25L 2M	(37-E)
Glass- substrate	Тор-	23		15 to 38	ST : 15 to 38	15 to 38	ST : 15 to 38	End surface of soda glass with reflection factor		
Mapping, 70°C	view	9 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1	R25	15 to 38 (Center 25)	(Center 25) SHS: –	15 to 38 (Center 25)	(Center 25) SHS: –	of 7% (t = 0.7 mm, rounded edges)	E32-A09 2M	37-F

^{*} If operation is affected by the background, perform power tuning to decrease the incident light level.

Note 1. The following mode names and response times apply to the modes given in the Sensing distance column.


[E3X-HD] GIGA: Giga-power mode (16 ms), HS: High-speed mode (250 µs), ST: Standard mode (1 ms), and SHS: Super-high-speed mode (NPN output: 50 µs, PNP output: 55 µs) [E3NX-FA] GIGA: Giga-power mode (16 ms), HS: High-speed mode (250 µs), ST: Standard mode (1 ms), and SHS: Super-high-speed mode (30 µs)

- 2. The values for the minimum sensing object are reference values that indicate values obtained in standard mode with the sensing distance and sensitivity set to the optimum values. The first value is for the E3X-HD and the second value is for the E3NX-FA.
- 3. The sensing distances for Reflective Fiber Units are for white paper


Installation Information → 58, 59 Page




Limited-reflective Fiber Units




37-B E32-L16-N 2M (Free Cutting)




37-C E32-A08 2M (Free Cutting)




37-D E32-A12 2M (Free Cutting)



37-E E32-L25L 2M (Free Cutting)



37-F E32-A09 2M (Free Cutting)





- Reference Information for Model Selection -

Sensing Distance vs. Digital Value

Limited-reflective Fiber Unit can keep high digital value within the sensing area for glass.

The digital value gets lower out of the sensing area for metals, including SUS (common as background).





* E3NX-FA21 used in high-speed (HS) mode.

Cylindrical

Flat Sleeved

Small Spot

High Power

Narrow view

BGS

Retroreflective

Limited-

Chemicalresistant, Oil-resistant

Bending

resistant Area

Detection Liquid-level

Vacuum

FPD, Semi Solar

Sleeved

Small Spot

High Power Narrow view

BGS

reflective Limitedreflective Chemical-

Bending

resistant


Liquid-level

Vacuum

Heat-

Area

FPD, Semi, Solar



· These Fiber Units are made from fluororesin for resistance to chemicals.

Chemical-resistant Data for Fluororesin (Reference)

Material Chemical	Fluororesin	Acryl	ABS	Polycarbonate	Polyethylene	PVC
Hydrochloric acid	0	Δ	Δ	Δ	Δ	×
Sulfuric acid	0	×	×	×	×	×
Sodium hydroxide	0	Δ	Δ	×	0	×
Methyl alcohol	0	×	Δ	×	0	×
Acetone	0	×	×	×	Δ	×
Toluene	0	Δ	×	×	Δ	×
Benzene	0	Δ	Δ	×	Δ	×

Note: Results depend on concentration.

Specifications

■→■ Through-beam Fiber Units

				Se	nsing dis	tance (mm)		Optical axis		
Туре	Sensing direction	Appearance (mm)	Bending radius of cable	E3X-HD	E3X-HD		<u>NEW</u>	diameter (minimum sensing	Models	39 Page Dimensions No.
				■GIGA =HS	Other modes	■GIGA =HS	Other modes			
Oil-	Right-	19.1	Flexible,	4,000 *1	*1 ST : 4,000	4,000 *1	*1 ST : 4,000			39-A
resistant	angle	M8 *3	R1	4,000 *1	SHS: 2,200	4,000 *1	SHS: 2,200		E32-T11NF 2M <u>NEW</u>	39-A
		20 5 dia. IP67		4,000 *1	*1 ST : 4,000	4,000 *1	*1 ST : 4,000	4 dia.		
	T		R40	4,000 *1	SHS: 1,600	4,000 *1	SHS: 1,600	(0.1 dia./ 0.03 dia.)	E32-T12F 2M	39-B
Chemical/	Top-view	35	35	4,000 *1	*1 ST : 4,000	4,000 *1	*1 ST : 4,000		E32-T11F 2M	39-C
oil resistant		7.2 dia. IP67	R4	2,600	SHS: 1,000	3,900	SHS: 1,000		E32-111F 2M	39-0
	Side view	21		1,400	ST : 800	2,100	ST : 1,200	3 dia. (0.1 dia./		39-D
	Side-view	5 dia.		= 500	SHS: 200	750	SHS: 200	0.03 dia.)	E32-T14F 2M	39-0
Chemical/		20	R40	4,000 *1	ST : 2,800	4,000 *1	*1 ST : 4,000	4 dia.		(a) F
resistant 150°C *2	Top-view	5 dia.	_	1,800	SHS: 700	2,700	SHS: 700	(0.1 dia./ 0.03 dia.)		(39-E)

11 The optical fiber is 2 m long on each side, so the sensing distance is 4,000 mm.
12 For continuous operation, use the Fiber Unit between -40 and 130°C.
13 The IP868 is the degree of protection which is defined according to the JIS (Japanese Industrial Standards). The IP68 indicates the same level of protection as defined by the IEC, and the G indicates that a device has resistance to oil. Passed OMRON's Oil-resistant Component Evaluation Standards (OMRON's own durability evaluation standards) (Cutting oil type: specified in JIS K 2241:2000; Temperature: 35°C max.)

Reflective Fiber Units

			D		nsing dis	tance (mm)		Standard		00 D
Туре	Sensing direction	Appearance (mm)	Appearance (mm) Bending radius of cable		ius E3X-HD E3NX-FA <u>NEW</u>			sensing object (minimum	Models	39 Page Dimensions No.
				■GIGA =HS	Other modes	■GIGA =HS	Other modes	sensing object)		
Semiconductors: Cleaning, developing, and etching, 60°C		Mounting holes A Mounting hol		(Recomme 19 to 31 mm	nded sens from cent	om tip of lens ling distance: 11 m ler of mounting hol ling distance: 22 m	e A	Glass	E32-L11FP 2M	39-F
Semiconductors: Resist stripping, 85°C	Top-view		R40	(Recomme 32 to 44 mm	nded sens from cent	om tip of lens ing distance: 11 m ter of mounting hol ing distance: 35 m	e A	(t=0.7 mm)	E32-L11FS 2M	39-G
Chemical/ oil resistant	Top-view	16 A 6 dia. IP67		GIGA -		alart	ST : 280 SHS: 60	(5 μm dia./	E32-D12F 2M	39-H
Only cable: chemical resistant		17 M6 IP67	R4	■ 840 ■ 240	ST : 350 SHS: 100	1,260 360	ST : 520 SHS: 100	2 μm dia.)	E32-D11U 2M	39-I

Note 1. The following mode names and response times apply to the modes given in the Sensing distance column.

[E3X-HD] GIGA: Giga-power mode (16 ms), HS: High-speed mode (250 μs), ST: Standard mode (1 ms), and SHS: Super-high-speed mode (NPN output: 50 μs, PNP output: 55 μs)

[E3NX-FA] GIGA: Giga-power mode (16 ms), HS: High-speed mode (250 μs), ST: Standard mode (1 ms), and SHS: Super-high-speed mode (30 μs)


2. The values for the minimum sensing object are reference values that indicate values obtained in standard mode with the sensing distance and sensitivity set to the optimum values. The first value is for the E3X-HD and the second value is for the E3NX-FA.

3. The sensing distances for Reflective Fiber Units are for white paper.

Installation Information → 60 Page

Through-beam Fiber Units (Set of 2)


39-A E32-T11NF 2M (Free Cutting)




39-B E32-T12F 2M (Free Cutting)




39-C E32-T11F 2M (Free Cutting)



39-D E32-T14F 2M (Free Cutting)




39-E E32-T51F 2M (Free Cutting)




Installation Information → 58, 59 Page


Reflective Fiber Units




39-G E32-L11FS 2M (Free Cutting)



39-H E32-D12F 2M (Free Cutting)



39-I E32-D11U 2M (Free Cutting)



- Reference Information for Model Selection -


Oil-resistance performance of the E32-T11NF

Fluororesin Outer Cable Sheath

The fluororesin that covers the entire surface of the cable sheath (fiber covering) prevents the penetration of cutting oil.

Mechanical Seal Structure

An aluminum ring bushing is compressed and deformed by a set screw to seal the structure by pressing against the fluororesin part of the fiber core. This prevents the ingress of cutting oil from the joined surfaces.



Structure Around Sensing Surface Also Resists Cutting Oil and Cutting Chips

Shape that prevents accumulation of oil drops and cutting chips

Spherical glass lens resists oils adhered

iber Sensor

Selection Guide

Fiber Unit

Threaded

Cylindrical Flat

Sleeved

Small Spot

High Power

Narrow view

BGS

Retroreflective

Limitedreflective

Chemicalresistant, Dil-resistant

Bending

Heatresistant

Area Detection

Liquid-level

Vacuum FPD,

Semi, Solar

Installation

oitemations (artions (artions (artions (artions (artions (articles)))

Fiber Amplifie Communicatio Unit. and

echnical iuide and

Model Inde

iber Senso eatures

Selectio Suide

Fiber Units

Threaded

Cylindrical

Flat Sleeved

Small Spot

Narrow view
BGS

Retro-reflective

Chemicalresistant, Oil-resistant

> Heatresistant

Area Detection

Liquid-level

Vacuum FPD, Semi.

Solar

Installation

Fiber Amplifiers, Communications Unit, and Accessories

echnical Juide and Precautions

Model Index

· Capable of withstanding one million repeated bends.



 A large number of independent fine fibers ensures good flexibility. Suitable for use on moving parts without easily breaking.



 Protective Stainless Spiral Tube is available for covering the fiber cable to protect it from accidental breaking due to snagging or shock.

Specifications

■→■ Through-beam Fiber Units

		D	Se	nsing dis	tance (m	m)		Optical axis diameter		41 Dogg
Size	Appearance (mm)	Bending radius of cable	E3X-HD	E3NX-FA <u>NEW</u>			(minimum sensing	Models	41 Page Dimensions No.	
			■GIGA =HS	Other modes	■GIGA	-HS	Other modes			140.
1.5 dia.	10 1.5 dia.		680	ST : 400		1,020	ST : 600	0.5 dia. (5 μm dia./	E32-T22B 2M	41-A
M3	11 M3	Rendresistant	=== 220 t.	SHS: 90	330		SHS: 90	2 μm dia.)	E32-T21 2M	41-B
M 4	14 M4 IP67	Bendresistant, R4	2,500	ST : 1,350		3,750 1,350	ST : 2,020	1 dia. (5 μm dia./ 2 μm dia.)	E32-T11 2M	41-C
Square	12 12		500	ST : 300 SHS: 70	250	750	ST : 450 SHS: 70	0.5 dia. (5 μm dia./ 2 μm dia.)	E32-T25XB 2M	41-D

Note The following mode names and response times apply to the modes given in the Sensing distance column.

- 1. [E3X-HD] GIGA: Giga-power mode (16 ms), HS: High-speed mode (250 μs), ST: Standard mode (1 ms), and SHS: Super-high-speed mode (NPN output: 50 μs, PNP output: 55 μs) [E3NX-FA] GIGA: Giga-power mode (16 ms), HS: High-speed mode (250 μs), ST: Standard mode (1 ms), and SHS: Super-high-speed mode (30 μs)
- The values for the minimum sensing object are reference values that indicate values obtained in standard mode with the sensing distance and sensitivity set to the optimum values. **2.** The first value is for the E3X-HD and the second value is for the E3NX-FA.

Protective Stainless Spiral Tube (Sold separately)

Insert the fiber cable into the protective tube to prevent breaking by snagging or shock.

Applicable Fiber Units	Model	Quantity	41 Page Dimensions No.
E32-T11R 2M/E32-T11 2M/ E32-LT11 2M/E32-LT11R 2M/ E32-T51R 2M/E32-T51 2M	E39-F32C 1M	2 pieces	41-E


^{*} This Tube cannot be used if a Lens Unit is being used

Installation Information → 60, 61 Page




Through-beam Fiber Units (Set of 2)


41-A E32-T22B 2M (Free Cutting)




41-B E32-T21 2M (Free Cutting)



41-C E32-T11 2M (Free Cutting)




41-D E32-T25XB 2M (Free Cutting)



Note 1: Set of two symmetrically shaped Fiber Units.

Note 2: Four, M2 × 8 stainless steel countersunk mounting screws are provided.

41-E E39-F32C 1M



Note: Saddles (four, trivalent chromate-plated iron) are provided.

Cylindrical

Flat

Sleeved

Small Spot

High Power

Narrow view

BGS

Retroreflective

Limitedreflective

Chemicalresistant, Oil-resistant

> Bendina Heat-

resistant

Detection Liquid-level

Vacuum

FPD, Semi. Solar

Bending-resistant, Disconnection-resistant

Through-beam → 40 page

Reflective → This page

Cylindrical

Flat

Sleeved

Small Spot

view

BGS

Retroreflective Limited-

Chemicalresistant, Oil-resistant Bendina

resistant


Detection

High Power Narrow

Liquid-level Vacuum FPD, Semi. Solar



· Capable of withstanding one million repeated bends.



· A large number of independent fine fibers ensures good flexibility. Suitable for use on moving parts without easily breaking.



· Protective Stainless Spiral Tube is available for covering the fiber cable to protect it from accidental breaking due to snagging or shock.

Specifications

Reflective Fiber Units

n L	enective riber	OTITES									
		Bending	Se	nsing dis	stance (mm)		Optical axis diameter		43 Page		
Size	Appearance (mm)	radius of cable	E3X-HD		E3NX-FA	NEW	(minimum sensing	Models	Dimensions No.		
		0.000.0	■GIGA = HS	Other modes	■GIGA =HS	Other modes					
1.5 dia.	15 1.5 dia.		140	ST : 60	210	ST : 90		E32-D22B 2M	43-A		
M 3	11 M3		4 0	SHS: 16	60	SHS: 16		E32-D21 2M	43-B		
3 dia.	15 3 dia.	Bendresistant,	300	ST : 140	450	ST : 210	(5 μm dia./	E32-D221B 2M	43-C		
M4	15 M4	R4			90	SHS: 40	130	SHS: 40	2 μm dia.)	E32-D21B 2M	43-D
M 6	17 M6 IP67		240	ST : 350 SHS: 100	360	ST : 520 SHS: 100		E32-D11 2M	43-E		
Square	12 23 8		240	ST : 100 SHS: 30	360	ST : 150 SHS: 30		E32-D25XB 2M	43-F		

Note The following mode names and response times apply to the modes given in the Sensing distance column.

- 1. [E3X-HD] GIGA: Giga-power mode (16 ms), HS: High-speed mode (250 µs), ST: Standard mode (1 ms), and SHS: Super-high-speed mode (NPN output: 50 µs, PNP output: 55 µs) [E3NX-FA] GIGA: Giga-power mode (16 ms), HS: High-speed mode (250 µs), ST: Standard mode (1 ms), and SHS: Super-high-speed mode (30 µs)
- The values for the minimum sensing object are reference values that indicate values obtained in standard mode with the sensing distance and sensitivity set to the optimum values.
- 2. The first value is for the E3X-HD and the second value is for the E3NX-FA. The sensing distances for Reflective Fiber Units are for white paper.

Protective Stainless Spiral Tube (Sold separately)

Insert the fiber cable into the protective tube to prevent breaking by snagging or shock.

Applicable Fiber Units	Models	Quantity	43 Page Dimensions No.
E32-D21R 2M/E32-C31 2M/ E32-D21 2M	E39-F32A 1M	1 piece	
E32-D211R 2M/E32-D21B 2M	E39-F32C 1M	2 pieces	43-G
E32-D11R 2M/E32-CC200 2M/ E32-D11 2M/E32-D51R 2M/ E32-D51 2M	E39-F32D 1M	1 piece	

^{*} This Tube cannot be used if a Lens Unit is being used.


Installation Information → 58, 59 and 61 Page

Environmental Immunity




Limited-reflective Fiber Units

43-A E32-D22B 2M (No Cutting)




Enlarged View of Sensing Surface Two 0.25 dia. emitter fibers Two. 0.25 dia

43-B E32-D21 2M (Free Cutting)




Enlarged View of Sensing Surface




43-C E32-D221B 2M (Free Cutting)




43-D E32-D21B 2M (Free Cutting)



43-E E32-D11 2M (Free Cutting)




43-F E32-D25XB 2M (Free Cutting)



Note: Two, M2×8 stainless steel countersunk mounting screws are provided

43-G E39-F32A 1M/E39-F32C 1M/E39-F32D 1M



Models	Α	В	С	D
E39-F32A 1M	M3×0.5 Depth: 4	3 dia.	6 dia.	(4.6 dia.)
E39-F32C 1M	M4×0.7 Depth: 4	4 dia.	7 dia.	(5.6 dia.)
E39-F32D 1M	M6×0.75 Depth: 4	5 dia.	8.5 dia.	(7 dia.)

Note: Saddles (two (four for the E39-F32C 1M), trivalent chromate-plated iron)

Cylindrical

Flat

Sleeved

Small Spot

High Power

Narrow view

BGS

Retroreflective

Limitedreflective

Chemicalresistant, Oil-resistant

Bendina

resistant

Detection Liquid-level

Vacuum

FPD, Semi. Solar

Heat-resistant

Through-beam → This page

Reflective → 46 page

Sleeved

Flat

Small Spot High Power

> Narrow view BGS

Retro-reflective Limited-

> Chemicalresistant, Oil-resistant Bendina


resistant

Area Detection

Liquid-level

Vacuum

FPD, Semi. Solar



• Wide product variety for temperatures from 100 to 350°C. Select the model according to heat-resistant temperature.

Specifications

Through-beam Fiber Units

Heat-		Dandina	Sei	nsing dis	tance (mm)		Optical axis		4F Domo
resistant temperature	Appearance (mm)	Bending radius of cable	E3X-HD)	E3NX-FA /	<u>VEW</u>	diameter (minimum sensing	Models	45 Page Dimensions No.
			■GIGA =HS	Other modes	■GIGA = HS	Other modes	object)		
100°C *1	14 M4 IP50	Flexible, R2	1,600	ST : 800 SHS: 225	2,400	ST : 1,200 SHS: 225	(0.1 dia./	E32-T51R 2M	45-A
150°C *2	17 M4	R35	2,800	ST : 1,500 SHS: 400	1,500	ST : 2,250 SHS: 400	(0.1 dia./	E32-T51 2M	45-B
200°C *3	30 20 M4 IP67	R10	1,000	ST : 550 SHS: 140	1,500	ST : 820 SHS: 140	(5 μm dia./	E32-T81R-S 2M	45-C
350°C *4	30 20 M4	R25	1,680	ST : 900 SHS: 240	900	ST : 1,350 SHS: 240	(5 μm dia./	E32-T61-S 2M	45-D
70°C			_	=				Standard Fiber Units can be used.	_

- For continuous operation, use the Fiber Unit between -40 to 90°C. For continuous operation, use the Fiber Unit between -40 to 130°C.
- The heat-resistant rating is not the same for all parts of the Fiber Unit. Refer to the dimensions diagrams for details The ambient operating temperature for the E32-T61-S 2M is –60 to 350°C.
- The optical fiber is 2 m long on each side, so the sensing distance is 4,000 mm.

Note 1. The following mode names and response times apply to the modes given in the Sensing distance column.


- [E3X-HD] GIGA: Giga-power mode (16 ms), HS: High-speed mode (250 µs), ST: Standard mode (1 ms), and SHS: Super-high-speed mode (NPN output: 50 µs, PNP output: 55 µs) [E3NX-FA] GIGA: Giga-power mode (16 ms), HS: High-speed mode (250 μ s), ST: Standard mode (1 ms), and SHS: Super-high-speed mode (30 μ s)
- 2. The values for the minimum sensing object are reference values that indicate values obtained in standard mode with the sensing distance and sensitivity set to the optimum values. The first value is for the E3X-HD and the second value is for the E3NX-FA.

OMRON


Installation Information → 60 Page




Through-beam Fiber Units (Set of 2)



45-B **E32-T51 2M** (Free Cutting)




45-C E32-T81R-S 2M (No Cutting)



Note: The maximum allowable temperatures for sections A and B are 200°C and 110°C, respectively. The section inserted into the Amplifier Unit (indicated by ') must be maintained within the Amplifier Unit's operating temperature range.

45-D **E32-T61-S 2M** (No Cutting)



Note: The maximum allowable temperatures for sections A and B are 350°C and 110°C, respectively. The section inserted into the Amplifier Unit (indicated by ") must be maintained within the Amplifier Unit's operating temperature range.

- Reference Information for Model Selection -



Long-distance Sensing Applications

A separate Lens Unit can be attached to extend the sensing distance.

→ 28 page

Fiber Sensi Features

selection Suide

ber Units

Threaded

Cylindrical

Flat Sleeved

Small Spot

High Power

Narrow view

BGS

Retroreflective Limited-

Chemicalresistant, Oil-resistant

reflective

Bending

Heatresistant

Area Detection

Liquid-level

Vacuum FPD,

Semi, Solar

Installation

iber Amplifiers, communications

> schnical uide and ecautions

> > lodel Inde

Heat-resistant

Through-beam → 44 page

Reflective → This page

Cylindrical

Flat

Sleeved

Small Spot High Power

Narrow view BGS


Retro-reflective Limited-

Chemicalresistant, Oil-resistant Bending

resistant Detection

> Liquid-level Vacuum

FPD, Semi. Solar



• Wide product variety for temperatures from 100 to 400°C. Select the model according to heat-resistant temperature.

Specifications

Reflective Fiber Units

Heat- resistant	Appearance (mm)	Bending radius	ЕЗХ-Н		g distance (mi		VEW	Standard sensing object	Models	47 Page Dimensions
temperature	., ,	of cable	■GIGA =HS	Other mode		_	Other modes	(minimum sensing object)		No.
100°C *1	17.5 M6	Flexible, R2	670	ST : 280 SHS: 80		1	ST : 420 SHS: 80		E32-D51R 2M	47-A
150°C *2	17 M6 IP67	R35	1,120	ST : 450 SHS: 144	400	T	ST : 670 SHS: 144	(5 μm dia./ 2 μm dia.)	E32-D51 2M	47-B
200°C *3	25 M6 IP67	R10	420	ST : 180 SHS: 54			ST : 270 SHS: 54		E32-D81R-S 2M	47-C
	26 5 1 18		10 to 20	ST : 10 to 20	10 to 20		ST : 10 to 20 SHS: -	Soda glass with reflection factor of 7%	E32-A08H2 2M	47-D
300°C	30 9 24		20 to 30	ST : 20 to 30	20 to 30		ST : 20 to 30 SHS: -	End surface of soda glass with eflection factor of 7% (t = 0.7 mm, rounded edges)	E32-A09H2 2M	47-E
3500 *3	28 M4	R25	420	ST : 180	630		ST : 270		E32-D611-S 2M	47-F
	25 M6		120	SHS: 54	180		SHS: 54	(5 μm dia./ 2 μm dia.)	E32-D61-S 2M	47-G
400°C *3	Sleeve bending 30 radius : 10 mm 60 M4		280 80	ST : 120 SHS: 36	420		ST : 180 SHS: 36		E32-D73-S 2M	47-H
70 0				_					Standard Fiber Units can be used.	-

- For continuous operation, use the Fiber Unit between -40 to 90°C. For continuous operation, use the Fiber Unit between -40 to 130°C.
- The heat-resistant rating is not the same for all parts of the Fiber Unit. Refer to the dimensions diagrams for details.

Note 1. The following mode names and response times apply to the modes given in the Sensing distance column.

- [E3X-HD] GIGA: Giga-power mode (16 ms), HS: High-speed mode (250 µs), ST: Standard mode (1 ms), and SHS: Super-high-speed mode (NPN output: 50 µs, PNP output: 55 µs) [E3NX-FA] GIGA: Giga-power mode (16 ms), HS: High-speed mode (250 μ s), ST: Standard mode (1 ms), and SHS: Super-high-speed mode (30 μ s)
- 2. The values for the minimum sensing object are reference values that indicate values obtained in standard mode with the sensing distance and sensitivity set to the optimum values. The first value is for the E3X-HD and the second value is for the E3NX-FA.
- 3. The sensing distances for Reflective Fiber Units are for white paper.


Installation Information → 58, 59 Page

Environmental Immunity


Heat-resistant

Reflective Fiber Units


47-A E32-D51R 2M (Free Cutting)



47-B E32-D51 2M (Free Cutting)




47-C E32-D81R-S 2M (No Cutting)




The maximum allowable temperatures for sections A and B are 200°C and 110°C, respectively. The section inserted into the Amplifier Unit (indicated by *) must be maintained within the Amplifier Unit's operating temperature

47-D E32-A08H2 2M (No Cutting)




47-E E32-A09H2 2M (No Cutting)




Note: The maximum allowable temperatures for sections A and B are 300°C and 110°C, respectively. The section inserted into the Amplifier Unit (indicated by 7) must be maintained within the Amplifier Unit (indicated by 7)

47-F E32-D611-S 2M (No Cutting)



Note: The maximum allowable temperatures for sections The maximum anowable temperatures to sections A and B are 350°C and 110°C, respectively. The section inserted into the Amplifier Unit (indicated by *) must be maintained within the Amplifier Unit's operating temperature range.

47-G E32-D61-S 2M (No Cutting)




*2. The diameter is 6 dia. if the fiber

length exceeds 10 m.
The length is 10 if the fiber length exceeds 10 m.

Note: The maximum allowable temperatures for sections A and B are 350°C and 110°C, respectively. The section inserted into the Amplifier Unit (indicated by *1) must be maintained within the Amplifier Unit's operating temperature range.

47-H E32-D73-S 2M (No Cutting)



Note: The maximum allowable temperatures for sections A, B, and C are 400°C, 300°C, and 110°C, respectively.

The section inserted into the Amplifier Unit (indicated by *) must be

maintained within the Amplifier Unit's operating temperati

Cylindrical

Flat Sleeved

Small Spot

High Power

Narrow view

BGS

Retroreflective Limited-

reflective Chemicalresistant. Oil-resistant

Bending

resistant

Detection

Liquid-level

Vacuum

FPD. Semi Solar

Flat

Sleeved

Small Spot **High Power**

Narrow view

BGS

Retroreflective Limited-


Chemicalresistant. Oil-resistant Bendina

> Heatresistant


Detection Liquid-level

Vacuum

FPD, Semi. Solar



- · Area beams are optimum for detecting workpieces presented in inconsistent positions, such as falling workpieces, or for meander detection, or for detecting workpieces with holes.
- · This Fiber Unit is ideal for meander detectin because it outputs the digital value in a linear relation to the interrupted light distance.



Specifications

Through-beam Fiber Units

				Sei	nsing dis	tance (mm)		Optical axis		
Туре	Sensing width	Appearance (mm)	Bending radius of cable	E3X-HD	E3X-HD		NEW	diameter (minimum sensing	Models	49 Page Dimensions No.
			or cable	■GIGA =HS	Other modes	■GIGA =HS	Other modes			
11 mm	11 mm	14.5 27 4 IP50			ST : 1,700 SHS: 440	4,000 *1	ST : 2,550 SHS: 440	*2 (0.2 dia./	E32-T16PR 2M	49-A
		27 17.8 IP50	Flexible, R1	2,750	ST : 1,500 SHS: 380	4,000 *1 1,440	ST : 2,250 SHS: 380	0.07 dia.)	E32-T16JR 2M	49-B
	30 mm	69 5 NIP50			ST : 2,600 SHS: 680	4,000 *1 2,550	ST : 3,900 SHS: 680	*2 (0.3 dia./ 0.1 dia.)	E32-T16WR 2M	49-C
Array	10 mm	7 32 7 1P50	R5		ST : 10 SHS: 10	10	ST : 10 SHS: 10	11 dia.	E32-G16 2M <u>NEW</u>	49-D

- The optical fiber is 2 m long on each side, so the sensing distance is 4,000 mm.
- The values for the minimum sensing object were obtained for detection in the sensing area with the sensing distance set to 300 mm. (The values are for a stationary sensing object.)

The first value is for the E3X-HD and the second value is for the E3NX-FA.

Reflective Fiber Units

				Sei	nsing dis	stance (mm)		Optical axis		
Туре	Type Sensing width Appearance		radius E3X-HD of cable			E3NX-FA		diameter (minimum sensing	Model	49 Page Dimensions No.
		or oublo	■GIGA =HS	Other modes	■GIGA =HS	Other modes			110.	
Array	11 mm	15 5 25	Bend- resistant, R4	700 200	ST : 300 SHS: 90	1,050 300	ST : 450 SHS: 90	(5 μm dia./ 2 μm dia.)	E32-D36P1 2M	49-E

Note 1. The following mode names and response times apply to the modes given in the Sensing distance column.


[E3X-HD] GIGA: Giga-power mode (16 ms), HS: High-speed mode (250 μ s), ST: Standard mode (1 ms), and SHS: Super-high-speed mode (NPN output: 50 μ s, PNP output: 55 μ s) [E3NX-FA] GIGA: Giga-power mode (16 ms), HS: High-speed mode (250 µs), ST: Standard mode (1 ms), and SHS: Super-high-speed mode (30 µs)

2. The values for the minimum sensing object are reference values that indicate values obtained in standard mode with the sensing distance and sensitivity set to the optimum values. The first value is for the E3X-HD and the second value is for the E3NX-FA.


Installation Information → 60 Page

Through-beam Fiber Units (Set of 2)


49-A E32-T16PR 2M (Free Cutting)




49-B E32-T16JR 2M (Free Cutting)



49-C E32-T16WR 2M (Free Cutting)




49-D E32-G16



Installation Information → 59 Page

Through-beam Fiber Units (Set of 2)

49-E E32-D36P1 2M (Free Cutting)



Cylindrical

Flat Sleeved

Small Spot

High Power

Narrow view

BGS

Retroreflective Limited-

reflective Chemical-

resistant, Oil-resistant

Bending

resistant

Detection

Liquid-level

Vacuum

FPD, Semi. Solar

Flat Sleeved

Small Spot

High Power Narrow view

BGS

Retro-reflective Limited-

reflective Chemicalresistant, Oil-resistant

Bending

Heatresistant

Area Detection

Liquid-level

Vacuum

FPD, Semi. Solar

· Fiber Units for detecting liquid levels are available in two types: for tube mounting and liquid contact.

► Tube-mounting Types


Detect the liquid level inside transparent tubes. Strap the Fiber Unit to a tube with band.



▶ Liquid-contact Type

Detect the liquid level by direct contact with the liquid.

This model has excellent chemical-resistance because the Fiber Unit is covered in fluororesin.



Specifications

Detection scheme	Tube diameter	Features	Appearance (mm)	Bending radius of cable	Applicable range	Optical axis diameter (minimum sensing object)	Models	51 Page Dimensions No.
	3.2, 6.4 and 9.5 dia.	Resistant to bubbles and droplets Residual quantity detection	19.9 27 IP50	Bend- resistant, R4	Applicable tube: Transparent tube with a diameter of 3.2, 6.4, or 9.5 dia. and a recommended wall thickness of 1 mm	_	E32-A01 5M	51-A
Tube- mounting	8 to 10 dia.	Ideal for mounting at multilevels	18 10 I	R10	Applicable tube: Transparent tube with a diameter of 8 to 10 dia. and a recommended wall thickness of 1 mm	_	E32-L25T 2M	(51-B)
	No restrictions	Usable on large diameter tubes Resistant to bubbles and droplets	23.45 215	R4	Applicable tube: Transparent tube (no restrictions on diameter)	_	E32-D36T 2M	51-C
Liquid contact (heat-resistant up to 200°C)		-	6 dia.	R40 R25 *3	Liquid-contact Type *1	_	E32-D82F1 4M	(51-D)

- *1 If the incident light level is too high, perform power tuning or use the ECO mode to decrease the incident level.
 *2 The applicable range is the same whether an E3X-HD series or E3NX-FA series is used.
- When using a Fiber Amplifier Unit in giga-power mode, level detection may not work depending on the tube diameter. Make sure to confirm operation with the actual tube.

 *3 The bending radius of the sensing section (except for the unbendable section) is 40 mm, and the bending radius of the fiber is 25 mm.

- Reference Information for Model Selection -


Determining the Best Model for Tube-mounted Types

Mounting and conditions	Recommended Unit	Features
When bubbles and the water droplets are generated	E32-A01	This is a Through-beam Model, so the incident light will differ greatly between with and without of liquid. It also uses an area beam, which is less prone to false detection by bubbles and droplets. With liquid Without liquid Light interrupted Light incident
Multilevel installation in limited space	E32-L25T	This model is suitable for mounting at multilevels because of the thin type (height: 10 mm).
Mounting on large diameter tubes	E32-D36T	This model has no restrictions on the tube diameter, so it can be mounted on many different tube sizes. It also uses an area beam, which is less prone to false detection by bubbles and droplets. With liquid Air Tube Reflective= Light incident Radiation

Installation Information → 58, 59 Page


Dimensions

51-A E32-A01 5M (Free Cutting)






51-B E32-L25T 2M (Free Cutting)






Note: Two nylon bands and one anti-reflector are provided

51-C E32-D36T 2M (Free Cutting)





51-D E32-D82F1 4M (Free Cutting)



* The 2-m section of optical fiber on the Amplifier unit side is plastic and therefore allows free cutting

Note: The maximum allowable temperature is 200°C for section A and 85°C for section B.

And

Designed for Safe Residual quantity detection (E32-A01 only)

The E32-A01 Fiber Unit is designed to default to the same output as for liquid absent in the event of a failure, such as when the fiber breaks. This makes it suitable for residual quantity detection.

Trouble (disconnection)	Light interrupted
With liquid	Light interrupted
Without liquid	Light incident

If the failure goes unnoticed, this failsafe design will prevent false detection of liquid when there is no liquid present.

Cylindrical

Flat

Sleeved

Small Spot

High Power

Narrow view

BGS

Retroreflective Limited-

reflective Chemical-

resistant, Oil-resistant

Bending

resistant Area

Detection Liquid-level

Vacuum FPD, Semi.

Solar

ilber Sensor eatures

election iuide

Fiber Units

Threaded

Cylindrical

Space

Flat

Sleeved

Small Spot

High Power
Narrow
view

BGS

Retroreflective

Chemicalresistant, Oil-resistant

Heat-

resistant

ovements

arent Objects

ironmental Immunity

Area
Detection
Liquid-level

Vacuum FPD,

Installation Information

Semi.

Fiber Amplifiers, Communications Unit, and Accessories


echnical Suide and Precautions

Model Index



- Can be used under high vacuums of up to 10⁻⁵ Pa.
- Available in models with heat resistant up to 120 or 200°C.

Configuration Example for using under vacuum



Specifications

Through-beam Fiber Units

			D !!	Ser	nsing dis	stance (mm)		Optical axis		50 D
Туре	Heat- resistant temperature	Appearance (mm)	Bending radius			E3NX-FA	<u>VEW</u>	diameter (minimum sensing	Models	53 Page Dimensions No.
	tomporataro		or cable	■GIGA =HS	Other modes	■GIGA =HS	Other modes			110.
	120°C	30 M4	Doo	720 260	ST : 400 SHS: 100	1,080	ST : 600 SHS: 100	1.2 dia. (10 μm dia./ 4 μm dia.)	E32-T51V 1M	53-A
Vacuum side		35.9 4 dia.	- R30	2,000*	ST : 2,000 SHS: 520	2,000*	* ST : 2,000 SHS: 520	4 dia. (0.1 dia./ 0.03 dia.)	E32-T51V 1M + E39-F1V	53-B
	200°C	30 January	- R25	1,760	ST : 950 SHS: 260		ST : 1,420 SHS: 260	2 dia. (0.1 dia./ 0.03 dia.)	E32-T84SV 1M	53-C
Atmospheric pressure side	70°C	0	- n25	_	ST : - SHS: -	_	ST : - SHS: -	_	E32-T10V 2M	53-D

^{*} The optical fiber is 2 m long on each side, so the sensing distance is 4,000 mm.

Note 1. The following mode names and response times apply to the modes given in the Sensing distance column.

[E3X-HD] GIGA: Giga-power mode (16 ms), HS: High-speed mode (250 μs), ST: Standard mode (1 ms), and SHS: Super-high-speed mode (NPN output: 50 μs, PNP output: 55 μs) [E3NX-FA] GIGA: Giga-power mode (16 ms), HS: High-speed mode (250 μs), ST: Standard mode (1 ms), and SHS: Super-high-speed mode (30 μs)

2. The values for the minimum sensing object are reference values that indicate values obtained in standard mode with the sensing distance and sensitivity set to the optimum values. The first value is for the E3X-HD and the second value is for the E3NX-FA.

Flange


Appearance	Туре	Models	53 Page Dimensions No.
	4-channel flange	E32-VF4	53-E
5	1-channel flange	E32-VF1	(53-F)

Installation Information → 60, 61 Page




Through-beam Fiber Units (Set of 2)


53-A E32-T51V 1M (No Cutting)




53-B E32-T51V 1M (No Cutting) + E39-F1V



E39-F1V




53-C E32-T84SV 1M (No Cutting)



53-D E32-T10V 2M (Free Cutting)






- Note 1. Mount the Flange so that the V40 O-ring is on the atmospheric-pressure side of the vacuum chamber wall.

 2. Mounting-hole dimensions: 38 dia. ±0.5 mm

 3. The maximum tightening torque is 9.8 N·m.

 4. A V40 O-ring is provided.

53-F E32-VF1



- Note 1. Mount the Flange so that the V15 O-ring is on the atmospheric-pressure side of the vacuum chamber wall.

 2. Mounting-hole dimensions: 14.5 dia. ±0.2 mm

 3. The maximum tightening torque is 14.7 N·m for the clamp nut and 1.5 N·m


 - for the connector.

 4. A V15 O-ring, nut, spring washer, two connectors, and four O-rings for

- Reference Information for Model Selection -

What Is a Vacuum-resistant Fiber Unit?

- · The Flange is designed to create an air-tight seal on the vacuum side.
- The fibers and Flange on the vacuum side are made of non-outgassing materials. These parts are inspected, cleaned, and sealed in an air-tight package in a clean room prior to shipment.



Cylindrical

Flat

Sleeved

Small Spot

High Power

Narrow view

BGS

Retroreflective

Limitedreflective

Chemicalresistant, Oil-resistant

Bending

resistant

Area Detection

Liquid-level

Vacuum

FPD, Semi Solar

iber Sensol eatures

Selection Suide

Fiber Units

Threaded

Cylindrical

Flat

Sleeved

Small Spot

High Power

Narrow view BGS

Retroreflective Limited-

Chemicalresistant, Oil-resistant

Bending

Heatresistant

Area Detection

Liquid-level


Vacuum FPD,

Installation Information

iber Amplifiers, Jommunications Jnit, and Accessories

echnical Juide and Precautions

Model Index




· Glass-substrate Alignment

Detection position accuracy: 0.2 mm max. No variation in detection positions even if the sensing distance changes.

▶ Tilting workpiece does not affect detection.


· Glass-substrate Mapping

Stable detection is possible even for difficult-todetect curved surfaces.



 Glass Presence Detection in Wet Processes

- Stable non-contact detection even with warped glass.
- The spherical heads ensure stable detection without being influenced by liquid.





Specifications

Limited-reflective Fiber Units

			Bending		ensing dis	tance (mm)		Standard		55 Page
Application	Ambient temperature	Appearance (mm)	radius of cable	E3X-HI	D	E3NX-FA	<u>NEW</u>	sensing object (minimum	Models	Dimensions No.
				■GIGA = HS	Other modes	■GIGA =HS	Other modes	sensing object)		
Glass presence detection		20.5 3.8 1 14		0 to 15	ST : 0 to 15 SHS: 0 to 12	0 to 15	ST : 0 to 15 SHS: 0 to 12		E32-L16-N 2M *1	55-A
	70°C	24.5 5 1 14 IP40		10 to 20	ST : 10 to 20	10 to 20	ST : 10 to 20	Soda glass	E32-A08 2M	55-B
Glass- substrate Alignment	300°C	26 5 1 18 IP30		10 to 20	SHS: -	10 to 20	SHS: -	with reflection factor of 7%	E32-A08H2 2M *1	55-C
	70°C	24.5 51 14 IP40	R25	12 to 30	ST : 12 to 30 SHS: -	12 to 30	ST : 12 to 30 SHS: -		E32-A12 2M	55-D
Mapping of	70 C	9 20 IP40		15 to 38 15 to 38 (Center 25)	ST : 15 to 38 SHS: - (Center 25)	15 to 38 15 to 38 (Center 25)	ST : 15 to 38 SHS: - (Center 25)	End surface of soda glass with reflection	E32-A09 2M	55-E
glass substrates	300°C *2	30 9 24		20 to 30 20 to 30 (Center 25)	ST : 20 to 30 SHS: - (Center 25)	20 to 30 20 to 30 (Center 25)	ST : 20 to 30 SHS: - (Center 25)	factor of 7% (t = 0.7 mm, rounded edges)	E32-A09H2 2M	55-F
Wet processes (Cleaning, Resist developing, and etching)	60°C	14 20 Mounting hole A	R40	(Recomn 19 to 31 n	nended sen nm from cei	rom tip of lens sing distance: 11 hter of mounting sing distance: 22	hole A	Glass	E32-L11FP 2M	55-G
Wet processes (Resist stripping)	85°C	Mounting hole A 717.5 IP67		(Recomm 32 to 44 m	nended sen nm from cei	rom tip of lens sing distance: 11 hter of mounting sing distance: 35	(t=0.7mm)	E32-L11FS 2M	(55-H)	

- *1 If operation is affected by the background, perform power tuning to decrease the incident light level.
- *2 The maximum allowable temperature is not the same for all parts of the Fiber Unit. Refer to the dimensions diagrams for details. Must not be repeatedly subject to rapid temperature changes.

Note 1. The following mode names and response times apply to the modes given in the Sensing distance column.


[E3X-HD] GIGA: Giga-power mode (16 ms), HS: High-speed mode (250 µs), ST: Standard mode (1 ms), and SHS: Super-high-speed mode (NPN output: 50 µs, PNP output: 55 µs)

[E3NX-FA] GIGA: Giga-power mode (16 ms), HS: High-speed mode (250 µs), ST: Standard mode (1 ms), and SHS: Super-high-speed mode (30 µs)


Installation Information → 58, 59 Page




Limited-reflective Fiber Units



55-B E32-A08 2M (Free Cutting)




55-C E32-A08H2 2M (No Cutting)




Note: The maximum allowable temperatures is 300°C for sections A and 110°C for section B (section inserted into Amplifier Unit).

55-D E32-A12 2M (Free Cutting)




Mounting holes

55-E E32-A09 2M (Free Cutting)




55-F E32-A09H2 2M (No Cutting)




Note: The maximum allowable temperatures for sections A and B are 300°C and 110°C, respectively. The section inserted into the Amplifier Unit (indicated by ") must be maintained within the Amplifier Unit's operating temperature range.

55-G E32-L11FP 2M (Free Cutting)



55-H E32-L11FS 2M (Free Cutting)



Cylindrical

Flat

Sleeved

Small Spot

High Power

Narrow view

BGS

Retroreflective

Limitedreflective

Chemicalresistant, Oil-resistant

> Bending resistant

Area Detection

Liquid-level

Vacuum

FPD, Semiconductors, and Solar Cells **Limited-reflective** → 54 page **Through-beam** → This page

Cylindrical

Flat

Sleeved

Small Spot

High Power

Narrow view

Retro-reflective

BGS

Limited-

Chemical-Oil-resistant

Bendina

Heatresistant


Area Detection

Liquid-level

Vacuum



· Wafer Mapping



- Thin-profile design enables easy mounting on robot arms.
- Easy to adjust optical axis. (Typical alignment error between mechanical and optical axes is only ±0.1°.)
- Reliably wafer detection, even when stacked closely together.

Specifications

Through-beam Fiber Units

				Danding	Ser	sing dis	tance (mm)		Optical axis		EZ Domo
Application	Ambient temperature		Appearance (mm)	Bending radius of cable	E3X-HD		E3NX-FA _	<u>VEW</u>	diameter (minimum sensing	Models	57 Page Dimensions No.
					■GIGA =HS	Other modes	■GIGA =HS	Other modes	object)		
		1.5°	20.5 Thickness: 3 mm	Flexible, R1	3,220	ST : 1,780	4,000 *	ST : 2,670	O dia	E32-A03 2M	57-A
			24.5 10 Thickness: 3 mm	5	1,200	SHS: 500	1,800	SHS: 500	0.03 dia.)	E32-A03-1 2M	57-B
Wafer Mapping	70°C	3.4°	20.5 Thickness: 2 mm	H10	1,280 450	ST : 680 SHS: 200	1,920	ST : 1,020 SHS: 200	1.2 dia. (0.1 dia./ 0.03 dia.)	E32-A04 2M	57-C
		40	Thickness: 2 mm IP50	Flexible, R1	1,460	ST : 2,200 SHS: 580	2,190	ST : 3,300 SHS: 580		E32-T24SR 2M	57-D
		4° 3.5 dia.		R10	1,740	ST : 2,600 SHS: 700	4,000 * 2,610	ST : 3,900 SHS: 700	0.03 dia.)	E32-T24S 2M	57-E

^{*} The optical fiber is 2 m long on each side, so the sensing distance is 4,000 mm.

Note 1. The following mode names and response times apply to the modes given in the Sensing distance column.

[E3X-HD] GIGA: Giga-power mode (16 ms), HS: High-speed mode (250 μ s), ST: Standard mode (1 ms), and SHS: Super-high-speed mode (NPN output: 50 μ s, PNP output: 55 μ s) [E3NX-FA] GIGA: Giga-power mode (16 ms), HS: High-speed mode (250 μ s), ST: Standard mode (1 ms), and SHS: Super-high-speed mode (30 μ s)


2. The values for the minimum sensing object are reference values that indicate values obtained in standard mode with the sensing distance and sensitivity set to the optimum values. The first value is for the E3X-HD and the second value is for the E3NX-FA.

Installation Information → 58, 60 Page




Through-beam Fiber Units (Set of 2)

57-A E32-A03 2M (Free Cutting)



Note: Use the engraved surface and its opposing surface as installation (reference) surfaces.


57-B E32-A03-1 2M (Free Cutting)



Note1: Use the engraved surface and its opposing surface as installation (reference) surfaces.


2. Set of two symmetrical parts.

57-C E32-A04 2M (Free Cutting)




Note: Use the engraved surface and its opposing surface as installation (reference) surfaces.

57-D E32-T24SR 2M (Free Cutting)



57-E E32-T24S 2M (Free Cutting)



Cylindrical

Flat

Sleeved

Small Spot

High Power

Narrow view

BGS

Retroreflective

Limitedreflective Chemical-

resistant, Oil-resistant

Bending

resistant

Detection

Liquid-level

Vacuum

Flat

Sleeved

Small Spot

High Power Narrow view

BGS

Retro-reflective

reflective Chemicalresistant, Oil-resistant

Bending

Heatresistant

Area Detection

Liquid-level

Vacuum FPD, Semi, Solar

Installation Information

Models	Ambient	tallation	Mauritin	Daydin	Hub ar debt	Town:	Cable	Emittos/varai	Weight Demension (packed Page		
Models	temperature	Tightening torque	Mounting hole	Bending radius	Unbendable length*1	Tensile strength	Sheath material	Core material	Emitter/receiver differentiation	state) (g)	No.
E32-A01 5M	-40 to 70°C	0.03N · m	-	R4	10	9.8N	Fluororesin	Plastic	None	200	51 Page (51-A
E32-A03 2M	-40 to 70°C	0.29N · m	-	R1	0	9.8N	Polyethylene	Plastic	None	40	31 Page 31-4 57 Page 57-4
E32-A03-1 2M	-40 to 70°C	0.29N · m	-	R10	10	9.8N	Polyethylene	Plastic	None	50	31 Page 31-E 57 Page 57-E
E32-A04 2M	-40 to 70°C	0.29N · m	2.2 ^{+0.5} ₀ dia.	R10	10	9.8N	Polyethylene	Plastic	None	40	31 Page 31-0 57 Page 57-0
E32-A08 2M	-40 to 70°C	0.53N · m	-	R25	10	9.8N	Polyethylene	Plastic	None	60	37 Page 37-0 55 Page 55-E
E32-A08H2 2M	-40 to 300°C	0.53N · m	-	R25	10	29.4N	SUS	Glass	None	240	47 Page 47- 55 Page 55- 0
E32-A09 2M	-40 to 70°C	0.53N · m	-	R25	10	9.8N	Polyethylene	Plastic	None	60	37 Page 37-F 55 Page 55-E
E32-A09H2 2M	-40 to 300°C *2, *3	0.53N · m	-	R25	10	9.8N	SUS	Glass	None	230	47 Page 47-E 55 Page 55-F
E32-A12 2M	-40 to 70°C	0.53N · m	-	R25	10	9.8N	Polyethylene	Plastic	None	60	37 Page 37- 0
E32-C21N 2M	-40 to 70°C	0.29N · m	3.2 ^{+0.5} ₀ dia. *4	R2	0	9.8N	Polyethylene	Plastic	White line on emitter cable	30	97 Page 97-
E32-C31 2M	-40 to 70°C	0.78N · m	3.2 ^{+0.5} ₀ dia. *4	R25	10	9.8N	Polyethylene	Plastic	White line on emitter cable	40	09 Page 09-
E32-C31M 1M	-40 to 70°C	0.78N · m	3.2 ^{+0.5} ₀ dia. *4	R10	10	9.8N	Polyethylene	Plastic	White line on emitter cable	40	09 Page 09-E
E32-C31N 2M	-40 to 70°C	0.29N · m	3.2 ^{+0.5} ₀ dia. *4	R4	0	9.8N	PVC and Polyethylene	Plastic	White line on emitter cable	40	09 Page 09-
E32-C41 1M	-40 to 70°C	0.78N · m	3.2 ^{+0.5} ₀ dia. *4	R25	10	9.8N	Polyethylene	Plastic	White tube on emitter cable	30	23 Page 23-4
E32-C42 1M	-40 to 70°C	0.29N · m	2.2 ^{+0.5} ₀ dia.	R25	10	9.8N	Polyethylene	Plastic	White tube on emitter cable	30	21 Page 21-A, 21-E
E32-C42S 1M	-40 to 70°C	0.29N · m	3.2 ^{+0.5} ₀ dia.	R25	10	4N	Polyolefin	Plastic	White tube on emitter cable	30	21 Page 21-
E32-CC200 2M	-40 to 70°C	0.98N · m	6.2 ^{+0.5} ₀ dia.	R25	10	29.4N	Polyethylene	Plastic	White line on emitter cable	40	09 Page 09-1
E32-C91N 2M	-40 to 70°C	0.98N · m	6.2 ^{+0.5} ₀ dia.	R4	0	29.4N	Polyethylene	Plastic	White line on emitter cable	36	09 Page 09-1 97 Page 97- 1
E32-D11 2M	-40 to 70°C	0.98N · m	6.2 ^{+0.5} ₀ dia.	R4	10	29.4N	PVC	Plastic	None	50	43 Page 43-1
E32-D11R 2M	-40 to 70°C	0.98N · m	6.2 ^{+0.5} ₀ dia.	R1	0	29.4N	PVC	Plastic	None	50	09 Page 09-0
E32-D11U 2M	-40 to 70°C	0.98N · m	6.2 ^{+0.5} ₀ dia.	R4	10	29.4N	Fluororesin	Plastic	None	60	39 Page 39-
E32-D12F 2M	-40 to 70°C	0.78N · m	6.5 ^{+0.5} ₀ dia.	R40	10	29.4N	Fluororesin	Plastic	None	190	39 Page 39-I
E32-D15XR 2M	-40 to 70°C	0.15N · m	-	R1	0	29.4N	PVC	Plastic	None	60	15 Page 15-E
E32-D15YR 2M	-40 to 70°C	0.15N · m	-	R1	0	29.4N	PVC	Plastic	None	60	15 Page 15-I
E32-D15ZR 2M	-40 to 70°C	0.15N · m	-	R1	0	29.4N	PVC	Plastic	None	60	15 Page 15-0
E32-D16 2M	-40 to 70°C	0.53N · m	-	R4	10	29.4N	PVC	Plastic	None	70	25 Page 25-E
E32-D21 2M	-40 to 70°C	0.78N · m	3.2 ^{+0.5} ₀ dia. *4	R4	10	9.8N	PVC	Plastic	None	20	43 Page 43-E
E32-D211R 2M	-40 to 70°C	0.78N · m	4.2 ^{+0.5} ₀ dia.	R1	0	9.8N	Polyethylene	Plastic	None	40	09 Page 09-1
E32-D21B 2M	-40 to 70°C	0.78N · m	4.2 ^{+0.5} ₀ dia.	R4	10	9.8N	PVC	Plastic	None	40	43 Page 43-I
E32-D21N 2M	-40 to 70°C	0.78N · m	4.2 ^{+0.5} ₀ dia.	R2	0	9.8N	Polyethylene	Plastic	None	30	97 Page 97-1
E32-D21R 2M	-40 to 70°C	0.78N · m	3.2 ^{+0.5} ₀ dia. *4	R1	0	9.8N	Polyethylene	Plastic	None	20	09 Page 09-0
E32-D21-S3 2M	-40 to 70°C	0.78N · m	4.2 ^{+0.5} ₀ dia.	R10	10	9.8N	Polyethylene	Plastic	None	50	19 Page 19-
E32-D221B 2M	-40 to 70°C	0.29N · m	3.2 ^{+0.5} ₀ dia.	R4	10	9.8N	PVC	Plastic	None	40	13 Page 13-0 43 Page 43-0
E32-D22B 2M	-40 to 70°C	0.2N · m	1.7 ^{+0.5} dia.	R4	10	9.8N	PVC	Plastic	None	30	13 Page 13-4 43 Page 43-4

[&]quot;1 Unbendable length of cable from fiber head.
Do not bend the cable for at least 20 mm from where the cable inserts into the Fiber Amplifier Unit.
"2 The heat-resistant rating is not the same for all parts of the Fiber Unit. Refer to the dimensions diagrams for details.
"3 Avoid rapid temperature changes.
"4 For embedded mounting, prepare a hole with a diameter of 2.6 mm.

Weight

(packed state) (g)

40

45

40

55

40

50

35

50

35

40

Emitter/receiver

differentiation

None

None

None

None

None

None

Yellow dotted

line on emitter cable

None

None

Demensions

13 Page (13-C)

19 Page 19-I

19 Page 19-A

19 Page (19-B)

43 Page (43-F)

19 Page 19-L

19 Page 19-G

13 Page 13-E

19 Page (19-F)

13 Page (13-F)

19 Page 19-E

Threaded

Cylindrical

Flat

Power

Installation Information

E32-D331 2M	-40 to 70°C	0.29N · m	2.2 ^{+0.5} ₀ dia.	R4	10	9.8N	Polyethylene	Plastic	None	30	19 Page (19-D)	Sleeved
E32-D36P1 2M	-40 to 70°C	0.78N · m	-	R4	10	29.4N	Polyethylene	Plastic	None	60	49 Page (49-E)	
E32-D36T 2M	-40 to 70°C	-	-	R4	10	29.4N	Polyethylene	Plastic	None	190	51 Page (51-C)	Small Spot
E32-D43M 1M	-40 to 70°C	0.29N · m	1.7 ^{+0.5} dia.	R4	10	9.8N	Polyethylene	Plastic	None	30	13 Page (13-B) 19 Page (19-C)	High Power
E32-D51 2M	-40 to 150°C *3	0.98N · m	6.2 ^{+0.5} dia.	R35	10	29.4N	Fluororesin	Plastic	None	60	47 Page 47-B	Narrow view
E32-D51R 2M	-40 to 100°C *4	0.98N · m	6.2 ^{+0.5} dia.	R2	0	29.4N	Polyurethane	Plastic	None	60	47 Page 47-A	
E32-D61-S 2M	−60 to 350°C *5	0.98N · m	6.2 ^{+0.5} dia.	R25	10	29.4N	sus	Glass	None	190	47 Page 47-G	BGS
E32-D611-S 2M	−60 to 350°C *5	0.98N · m	4.2 ^{+0.5} ₀ dia.	R25	10	29.4N	SUS	Glass	None	170	47 Page 47-F	Retro- reflective
E32-D73-S 2M	-40 to 400°C *5	0.78N · m	4.2 ^{+0.5} ₀ dia.	R25	10	29.4N	SUS	Glass	None	170	47 Page (47-H)	Limited- reflective
E32-D81R-S 2M	-40 to 200°C *5	0.78N · m	6.2 ^{+0.5} ₀ dia.	R10	10	9.8N	Fluororesin	Glass	None	70	47 Page 47-C	Chemical
E32-D82F1 4M	-40 to 200°C	0.29N · m	6.5 ^{+0.5} ₀ dia.	R25	10	29.4N	Fluororesin	Plastic	None	450	51 Page (51-D)	resistant, Oil-resistant
E32-DC200BR 2M	-40 to 70°C		6.2 ^{+0.5} ₀ dia.	R1	0	29.4N	PVC	Plastic	None	60	19 Page (19-K)	Bending
E32-DC200F4R 2M	-40 to 70°C	0.78N · m	3.2 ^{+0.5} dia. *2	R1	0	9.8N	Polyethylene	Plastic	None	40	19 Page (19-H)	Heat-
E32-G16 2M	-40 to 70°C	0.53N · m	-	R5	0 *6	29.4N	Polyethylene	Plastic	-	51	49 Page 49-D	resistant
E32-L11FP 2M	-10 to 60°C	0.78N · m	-	R40	10	9.8N	Fluororesin	Plastic	None	310	39 Page 39-F 55 Page 55-G	Area Detection
E32-L11FS 2M	–10 to 85°C	0.78N · m	-	R40	10	9.8N	Fluororesin	Plastic	None	310	39 Page (39-G) 55 Page (55-H)	Liquid-level
E32-L15 2M	-40 to 70°C	0.53N · m	-	R25	10	29.4N	Polyethylene	Plastic	White tube on emitter cable	60	21 Page 21-F	Vacuum
E32-L16-N 2M	-40 to 70°C	0.29N · m	-	R25	10	29.4N	Polyethylene	Plastic	None	60	33 Page 33-A 37 Page 37-B 55 Page 55-A	FPD, Semi, Solar
E32-L24S 2M	-40 to 70°C	0.29N · m	_	R10	10	9.8N	Polyethylene	Plastic	None	40	33 Page 33-B 37 Page 37-A	Installa
E32-L25L 2M	-40 to 105°C *4	0.29N · m	-	R10	10	9.8N	Polyethylene	Plastic	None	40	33 Page (33-C) 37 Page (37-E)	Informa ∞ ≅
E32-L25T 2M	-40 to 70°C	-	-	R10	10	9.8N	Polyethylene	Plastic	None	40	51 Page (51-B)	Fiber Amplifiers, Communications Unit and
E32-LD11 2M	-40 to 70°C	0.98N · m	-	R25	10	29.4N	Polyethylene	Plastic	None	40	09 Page 09-I	Fiber A Commi
E32-LD11N 2M	-40 to 70°C	0.98N · m	6.2 ^{+0.5} ₀ dia.	R2	0	29.4N	Polyethylene	Plastic	None	40	97 Page 97-C	ig ja
E32-LD11R 2M	-40 to 70°C	0.98N · m	-	R1	0	29.4N	Polyethylene	Plastic	None	40	09 Page 09-I	Technical Guide and
*1 Unbendable length of ca Do not bend the cable for 2° For embedded mounting 3° For continuous operatio 4° For continuous operatio 5° The heat-resistant rating 6° The bending radius of the	or at least 20 mm g, prepare a hole on, use the Fiber U on, use the Fiber U g is not the same	from where with a diame Init between Init between for all parts	eter of 2.6 m -40 to 130° -40 to 90°0 of the Fiber	m. °C. C. Unit. Re		·		details.				Te Model Index
											OMRON	59

Cable

Core

material

Plastic

Plastic

Plastic

Plastic

Plastic

Plastic

Plastic

Plastic

Sheath

material

Polvethylene

Polyethylene

Polyethylene

Polyethylene

PVC

Polyethylene

Polyethylene

Polvolefin

Polyethylene

Installation

torque

0.29N · m

0.29N · m

0.29N · m

0.15N · m

0.29N · m

0.78N · m

0.29N · m

0.29N · m

temperature

-40 to 70°C

−40 to 70°C

-40 to 70°C

-40 to 70°C

-40 to 70°C

–40 to 70°C

–40 to 70°C

–40 to 70°C

-40 to 70°C

−40 to 70°C

Mounting

hole

3.2^{+0.5} dia.

4.2^{+0.5} dia.

3.2^{+0.5} dia.

5^{+0.5} dia.

3.2^{+0.5} dia.

3.2^{+0.5} dia.

3.2^{+0.5} dia.

Bending

radius

R1

R10

R1

R25

R4

R10

R4

R25

R4

R25

Unbendable

length*1

0

10

10

10

10

10

10

10

Tensile

strength

9.8N

9.8N

9.8N

19.6N

9.8N

9.8N

9.8N

29.4N

9.8N

9.8N

Models

E32-D22R 2M

E32-D22-S1 2M

E32-D24R 2M

E32-D24-S2 2M

E32-D25XB 2M

E32-D25-S3 2M

E32-D31-S1 0.5M

E32-D32-S1 0.5M

E32-D32L 2M

E32-D33 2M

^{*1} U D *2 F *3 F *4 F

^{*6} T

Cylindrical Flat

> Sleeved **Small Spot**

High Power

Narrow view

BGS

Retro-reflective

reflective Chemicalresistant, Oil-resistant

Bending

Heatresistant

Area Detection

Liquid-level Vacuum

FPD, Semi, Solar

Installation Information

		tallation			I		Cable		I	Weight	Demensions
Models	Ambient temperature	Tightening torque	Mounting hole	Bending radius	Unbendable length*1	Tensile strength	Sheath material	Core material	Emitter/receiver differentiation	(packed state) (g)	Page No.
E32-LR11NP 2M	-40 to 70°C *2	0.98N · m	6.2 ^{+0.5} ₀ dia.	R2	0	29.4N	Polyethylene	Plastic	None	40	35 Page 35-A 97 Page 97-G
E32-LT11 2M	-40 to 70°C	0.78N · m	-	R25	10	29.4N	Polyethylene	Plastic	None	40	07 Page 07-C 25 Page 25-C
E32-LT11N 2M	-40 to 70°C	0.78N · m	4.2 ^{+0.5} ₀ dia.	R2	0	29.4N	Polyethylene	Plastic	None	40	25 Page 25-A 97 Page 97-A
E32-LT11R 2M	-40 to 70°C	0.78N · m	-	R1	0	29.4N	Polyethylene	Plastic	None	40	07 Page 07-C 25 Page 25-C
E32-LT35Z 2M	-40 to 70°C	0.15N · m	-	R1	0	9.8N	Polyethylene	Plastic	None	25	15 Page 15-D
E32-R16 2M	−25 to 55°C	0.54N · m	-	R25	10	29.4N	Polyethylene	Plastic	None	220 (E39-R1 included.)	35 Page 35-B
E32-R21 2M	-40 to 70°C	0.39N · m	6.2 ^{+0.5} ₀ dia.	R10	10	9.8N	Polyethylene	Plastic	None	70 (E39-R3 included.)	35 Page 35-C
E32-T10V 2M	–25 to 70°C	0.3N · m	-	R25	10	29.4N	Fluororesin	Plastic	None	170	53 Page 53-D
E32-T11 2M	-40 to 70°C	0.78N · m	4.2 ^{+0.5} ₀ dia.	R4	10	29.4N	PVC	Plastic	None	40	41 Page 41-0
E32-T11F 2M	-40 to 70°C	0.29N · m	-	R4	10	29.4N	Fluororesin	Plastic	None	60	39 Page 39-0
E32-T11N 2M	-40 to 70°C	0.78N · m	4.2 ^{+0.5} ₀ dia.	R1	0	29.4N	PVC	Plastic	None	70	07 Page 07-A
E32-T11NF 2M	−25 to 70°C	12N · m	8.5 ^{+0.5} ₀ dia.	R1	0	29.4N	Fluororesin	Plastic	None	80	39 Page 39-A
E32-T11R 2M	-40 to 70°C	0.78N · m	4.2 ^{+0.5} ₀ dia.	R1	0	29.4N	PVC	Plastic	None	50	07 Page 07-B
E32-T12F 2M	-40 to 70°C	0.78N · m	5.5 ^{+0.5} ₀ dia.	R40	10	29.4N	Fluororesin	Plastic	None	210	39 Page 39-B
E32-T12R 2M	-40 to 70°C	0.29N · m	3.2 ^{+0.5} dia.	R1	0	29.4N	PVC	Plastic	None	60	11 Page 11-0
E32-T14 2M	-40 to 70°C	0.49N · m	-	R25	10	29.4N	Polyethylene	Plastic	None	60	25 Page 25- D
E32-T14F 2M	-40 to 70°C	0.78N · m	5.5 ^{+0.5} ₀ dia.	R40	10	29.4N	Fluororesin	Plastic	None	220	39 Page 39- D
E32-T14LR 2M	-40 to 70°C	0.29N · m	3.2 ^{+0.5} ₀ dia.	R1	0	29.4N	PVC	Plastic	None	60	11 Page 11-D
E32-T15XR 2M	-40 to 70°C	0.15N · m	-	R1	0	29.4N	PVC	Plastic	None	60	15 Page 15-A
E32-T15YR 2M	-40 to 70°C	0.15N · m	-	R1	0	29.4N	PVC	Plastic	None	60	15 Page (15-B
E32-T15ZR 2M	-40 to 70°C	0.15N · m	-	R1	0	29.4N	PVC	Plastic	None	60	15 Page 15-0
E32-T16JR 2M	-40 to 70°C	0.29N · m	-	R1	0	29.4N	PVC	Plastic	None	60	49 Page 49-B
E32-T16PR 2M	-40 to 70°C	0.29N · m	-	R1	0	9.8N	PVC	Plastic	None	60	49 Page 49-A
E32-T16WR 2M	−25 to 55°C	0.29N · m	-	R1	0	9.8N	PVC	Plastic	None	60	49 Page 49-0
E32-T17L 10M	-40 to 70°C	0.78N · m	14.5 ⁺¹ dia.	R25	10	29.4N	Polyethylene	Plastic	None	240	25 Page 25-B
E32-T21 2M	-40 to 70°C	0.78N · m	3.2 ^{+0.5} dia. *3	R4	10	9.8N	PVC	Plastic	None	30	41 Page 41-B
E32-T21-S1 2M	-40 to 70°C	0.78N · m	3.2 ^{+0.5} ₀ dia. *3	R10	10	9.8N	Polyethylene	Plastic	None	45	17 Page 17-D
E32-T223R 2M	-40 to 70°C	0.20N · m	1.2 ^{+0.5} dia.	R1	20	9.8N	Polyethylene	Plastic	None	40	11 Page 11-A
E32-T22B 2M	-40 to 70°C	0.20N · m	1.7 ^{+0.5} dia.	R4	10	9.8N	PVC	Plastic	None	40	11 Page 11-E 41 Page 41-A
E32-T22S 2M	-40 to 70°C	0.29N · m	3.2 ^{+0.5} ₀ dia.	R10	10	29.4N	PVC	Plastic	None	60	31 Page 31-F
E32-T24E 2M	-40 to 70°C	0.29N · m	2.7 ^{+0.5} ₀ dia.	R10	10	9.8N	Polyethylene	Plastic	None	40	17 Page 17-B
E32-T24R 2M	-40 to 70°C	0.29N · m	2.2 ^{+0.5} ₀ dia.	R1	0	9.8N	Polyethylene	Plastic	None	40	17 Page 17-A
E32-T24S 2M	-40 to 70°C	0.29N · m	-	R10	10	29.4N	PVC	Plastic	None	60	31 Page 31-E 57 Page 57-E
E32-T24SR 2M	-40 to 70°C	0.29N · m	_	R1	0	9.8N	PVC	Plastic	None	60	31 Page 31-D 57 Page 57-D
E32-T25XB 2M	-40 to 70°C	0.15N · m	_	R4	10	9.8N	PVC	Plastic	None	40	41 Page (41-D

^{*1} Unbendable length of cable from fiber head.
Do not bend the cable for at least 20 mm from where the cable inserts into the Fiber Amplifier Unit.
*2 Ambient operating temperature of the recommended reflector (E39-RP1) is -40 to 60°C.
*3 For embedded mounting, prepare a hole with a diameter of 2.6 mm.

Threaded

Flat

Cylindrical

Sleeved

Small Spot

High Power Narrow

view BGS

Retro-reflective Limited-

reflective Chemicalresistant, Oil-resistant

Bending

Heatresistant

Area Detection

Liquid-level

Vacuum

FPD, Semi, Solar

Installation Information

	Ins	tallation					Cable			Weight	Demensions
Models	Ambient temperature	Tightening torque	Mounting hole	Bending radius	Unbendable length*1	Tensile strength	Sheath material	Core material	Emitter/receiver differentiation	(packed state) (g)	Page No.
E32-T33 1M	-40 to 70°C	0.29N · m	3.2 ^{+0.5} ₀ dia.	R10	10	9.8N	Polyethylene	Plastic	None	40	17 Page 17-C
E32-T51 2M	-40 to 150°C *2	0.78N · m	4.2 ^{+0.5} ₀ dia.	R35	10	29.4N	Fluororesin	Plastic	None	70	45 Page 45-B
E32-T51F 2M	-40 to 150°C *2	0.78N · m	5.5 ^{+0.5} ₀ dia.	R40	10	29.4N	Fluororesin	Plastic	None	220	39 Page 39-E
E32-T51R 2M	-40 to 100°C	0.78N · m	4.2 ^{+0.5} ₀ dia.	R2	0	29.4N	Polyurethane	Plastic	None	60	45 Page (45-A)
E32-T51V 1M	-25 to 120°C	0.29N · m	4.2 ^{+0.5} ₀ dia.	R30	10	29.4N	Fluororesin	Glass	None	160	53 Page 53-A
E32-T61-S 2M	-60 to 350°C *4	0.78N · m	4.2 ^{+0.5} ₀ dia.	R25	10	29.4N	SUS	Glass	None	200	45 Page 45-D
E32-T81R-S 2M	-40 to 200°C *4	0.78N · m	4.2 ^{+0.5} ₀ dia.	R10	10	9.8N	Fluororesin	Glass	None	60	45 Page 45-C
E32-T84SV 1M	-25 to 200°C	0.29N · m	4.5 ^{+0.5} ₀ dia.	R25	10	29.4N	SUS	Glass	None	190	53 Page 53-C
E32-TC200BR 2M	-40 to 70°C	0.78N · m	4.2 ^{+0.5} ₀ dia.	R1	0	29.4N	PVC	Plastic	None	60	17 Page 17-E
E32-VF1	−25 to 70°C	-	-	-	-	-	_	-	-	240	53 Page 53-F
E32-VF4	−25 to 70°C	-	-	-	-	-	-	-	-	280	53 Page 53-E
E39-F1	-40 to 200°C	-	-	-	-	-	-	-	-	2	26 Page 26-A 27 Page 27-A to 27-C 28 Page 28-A 29 Page 29-A to 29-C
E39-F1-33	-40 to 200°C	-	-	-	-	-	-	-	-	3	28 Page 28-D
E39-F11	-	-	-	-	-	-	-	-	-	30	-
E39-F16	-40 to 350°C	-	-	-	-	-	-	-	-	15	26 Page (26-B) 27 Page (27-D) to (27-F) 28 Page (28-B) 29 Page (29-D) to (29-F), (29-K)
E39-F17	-25 to 70°C	-	-	-	-	-	-	-	-	10	21 Page 21-B
E39-F18	-40 to 70°C	-	-	-	-	-	-	-	_	5	23 Page 23-G), 23-H)
E39-F1V	-25 to 120°C	-	-	-	_	-	_	-	-	3	53 Page 53-B
E39-F2	-40 to 200°C	-	-	-	-	-	-	-	-	2	26 Page 26-C 27 Page 27-G, (27-H) 28 Page 28-C 29 Page 29-G to 29-I
E39-F32A 1M	-40 to 150°C	-	-	R30	-	-	-	-	-	70	43 Page (43-G)
E39-F32C 1M	-40 to 150°C	-	-	R30	-	-	-	-	-	110	41 Page (41-E) 43 Page (43-G)
E39-F32D 1M	-40 to 150°C	-	-	R30	_	_	-	_	-	80	43 Page 43-G
E39-F3A	-40 to 70°C	-	_	-	_	_	-	-	-	2	21 Page 21-A
E39-F3A-5	-40 to 70°C	_	_	-	-	-	_	_	_	1	23 Page (23-A), (23-B), (23-C)
E39-F3B	-25 to 55°C	_	_	-	_	_	-	-	-	2	23 Page (23-D), (23-E), (23-F)
E39-F3C	−25 to 55°C	_	_	_	_	-	_	_	_	1	21 Page (21-C), (21-D)
E39-R1	-25 to 55°C	_	_	_	_	_	_	_	_	20	35 Page 35-B
E39-R3	-25 to 55°C	_	_	_	_	_	_	_	_	20	35 Page 35-C
E39-RP1	-40 to 60°C	_	_	-	_	_	_	_	_	25	35 Page (35-A) 97 Page (97-G)
E39-RP37	−25 to 55°C	_	_	-	_	_	-	_	-	4	97 Fage (97-G)
E39-RSP1	-25 to 55°C	_	_	_	_	_	_	_	_	4	_

^{*1} Unbendable length of cable from fiber head.

To interioanie length of capie from fiber nead.

Do not bend the cable for at least 20 mm from where the cable inserts into the Fiber Amplifier Unit.

*2 For continuous operation, use the Fiber Unit between –40 to 130°C.

*3 For continuous operation, use the Fiber Unit between –40 to 90°C.

*4 The heat-resistant rating is not the same for all parts of the Fiber Unit. Refer to the dimensions diagrams for details.

election uide

Fiber Units

Threaded

Cylindrical

Flat Sleeved

Small Spot

Narrow view

reflective Limitedreflective

Chemicalresistant.

Liquid-level

Vacuum

BGS

Retro-

Transparent 0

resistant,
Oil-resistant

Bending

Heatresistant

Area

Detection

lications

FPD, Semi, Solar

Installation Information

Fiber Amplitiers, Communications Unit, and Accessories

> echnical tuide and recautions

> > Model Index

Smart Fiber Amplifier Units

Main Features

E3NX-FA Series NEW

A Smart Fiber Amplifier Unit with Ultra-stable Detection and Ultra-easy Setup

Expanded Application Response Capabilities Advanced Basic Performance

Improvements in the sensing distance and minimum sensing object have increased the range of application for stable detection.





Achieve Easy Detection in Many Applications

Advanced Smart Tuning

Just press the Stune button once with a workpiece and once without a workpiece to automatically set the optimum incident level and threshold. Consistent settings are achieved for all users with this ultra-easy procedure.





Optimum Light Intensity Adjustment from Transparent Objects to Black Workpieces

The incident level is optimized to enable stable detection even for saturated or insufficient incident levels.



64

Sensor Communications Units for E3NX-FA

E3NW Series NEV

The Next-generation E3NW Sensor Network Units Revolutionize On-site Sensing

The Sensor Communications Unit with a master function and the Distributed Sensor Units with slave functions enable N-Smart Sensors communication over open networks.



Greatly Reduced Machine Manufacturing Costs

There is no need to change the current distributed installation to introduce a network without increasing costs.

Greatly Reduced Machine Commissioning Time

All of the settings can be made at the same time from a Touch Panel.

Greatly Improved Machine Productivity

EtherCAT.

CompoNet

CC-Link V2

Realtime monitoring lets you perform maintenance before malfunctions occur.

Small Spot

Sleeved

High Power

Narrow view

BGS

Retroreflective

Limitedreflective

Chemicalresistant, Oil-resistant

Bending

resistant Area

Detection
Liquid-level

FPD, Semi.

Solar

Installation Information

lber Amplifiers, ommunications nit, and

> chnical iide and ecautions

> > Model Inde

Smart Fiber Amplifier Units

E3X-HD Series

Affordable Amplifier Units with Simple Operation and Stable Detection Capabilities



Sensor Communications Units for E3X-HD

E3X-ECT / E3X-CRT

Sensor Communications Units for CompoNet and EtherCAT



Compoi\et

Ether CAT.

78 Page

<Fiber Amplifier Unit Comparison>

	· · · · · · · · · · · · · · · · · · ·						
			E3NX-FA Series <u>NEW</u>	E3X-HD Series			
	Output		1 or 2 outputs (depending on the model)	1 output			
	External input		Supported or not supported (depending on the model)	Not supported			
Fiber Amplifier	Response time		30 μs (32 μs)/250 μs/1 ms/16 ms (Default: 250 μs)	50 μs (55 μs)/250 μs/1 ms/16 ms (Default: 250 μs)			
Unit specifications	Sensing distance	E32-T11R	3,000 mm	2,000 mm			
0,000,000,000	(Giga-power mode)	E32-D11R	1,260 mm	840 mm			
	Minimum sensing object	E32-T11R	2 μm dia.	5 μm dia.			
Sensor Communications	Communications m (Sensor Communica		EtherCAT (E3NW-ECT) CompoNet (E3NW-CRT) CC-Link (E3NW-CCL)	EtherCAT (E3X-ECT) CompoNet (E3X-CRT)			
Unit application	Applicable Sens	sors	Fiber Sensor (E3NX-FA0) Laser Sensors (E3NC-LA0, E3NC-SA0) Contact-Type Sensor (E9NC-TA0) *	Fiber Sensor (E3X-HD0) Fiber Sensor (E3X-MDA0) Laser Photoelectric Sensor (E3C-LDA0) Proximity Sensor (E2C-EDA0)			
	Ordering Information		64 Page	78 Page			
Page listings	Ratings and Sp	ecifications	66 Page	80 Page			
	Dimensions		68 Page	80 Page			

^{*} E3NW-CRT Sensor Communications Units (CompoNet) cannot be used.

Fiber Amplifier Unit Accessories

65, 79 Page eatures

selection suide

Fiber Units

ce Standard Installatio

Cylindrical

Flat

Sleeved

Small Spot

nts Saving Spa

High Power

Narrow view

BGS

Retro-reflective
Limited-

Chemical-resistant,
Oil-resistant

Bending

Heatresistant

Area

Detection

Liquid-level

FPD, Semi, Solar

Installation

riber Ampliners, Communications Unit, and Accessories

echnical Juide and Precautions

Model Index

E3NX-FA Fiber Amplifier Units and Related Products NEW

Fiber Amplifier Units E3NX-FA Series

E3NX-FA Series Products

_			Inputs/	Мо	dels	Ratings and	
Туре	Appearance	Connecting method	outputs	NPN output	PNP output	Specifications	Dimensions
Standard		Pre-wired (2 m)	1 output	E3NX-FA11 2M	E3NX-FA41 2M		Page 68 68-A
models		Wire-saving Connector	1 output	E3NX-FA6	E3NX-FA8		Page 68 68-B
		Pre-wired (2 m)	2 outputs + 1 input	E3NX-FA21 2M	E3NX-FA51 2M	Page 66	Page 68 68-A
Advanced models		Wire-saving Connector		E3NX-FA7	E3NX-FA9	. ago oo	Page 68
models			2 outputs	E3NX-FA7TW	E3NX-FA9TW		68-B
	Mo Conn	M8 Connector	1 output + 1 input	E3NX-FA24	E3NX-FA54		Page 69
	2 outputs —		_	E3NX-FA54TW		69-A	
Model for Sensor Communications Unit*		Connector for Sensor Communications Unit	_	E3NX-FA0			Page 69 69-B

^{*} A Sensor Communications Unit is required if you want to use the Fiber Amplifier Unit on a network.

Sensor Communications Unit

Sensor Communications Unit

Communication method	Appearance	Applicable Fiber Amplifier Model	Model	Ratings and Specifications	Dimensions
EtherCAT			E3NW-ECT	Page 76	Page 77 (77-A)
CompoNet		E3NX-FA0	E3NW-CRT		
CC-Link			E3NW-CCL		

^{*} For details, refer to your OMRON website.

Distributed Sensor Unit

Appearance	Applicable Fiber Amplifier Model	Model	Ratings and Specifications	Dimensions
	E3NX-FA0	E3NW-DS	Page 76	Page 77 77-B

Note. The Distributed Sensor Unit can be connected to any of the Sensor Communications Units.

iber Sensc

election

Fiber Units

Cylindrical

Flat Sleeved

Small Spot
High Power

Narrow view

> BGS Retro-

Limitedreflective

Chemicalresistant, Oil-resistant

Bending

Area

Detection

Liquid-level

Vacuum FPD,

Semi.

Installation

er Amplifiers, nmunications t, and

> echnical uide and recautions

> > odel Inde

Accessories (sold separately)

Wire-saving connectors (Required for models for Wire-saving Connectors.)

Connectors are not provided with the Fiber Amplifier Unit and must be ordered separately. * Protective stickers: provided.

Туре	Appearance	Cable length	Number of conductors	Applicable Fiber Amplifier Units	Models	Ratings, Specifications and Dimensions
Master Connector			4	E3NX-FA7 E3NX-FA7TW	E3X-CN21	Page 88 88-A
Slave Connector		2 m	2	E3NX-FA9 E3NX-FA9TW	E3X-CN22	Page 88 88-B
Master Connector		2 111	3	E3NX-FA6	E3X-CN11	Page 88 88-A
Slave Connector			1	E3NX-FA8	E3X-CN12	Page 88 (88-B)

Sensor I/O Connectors (Required for models with M8 Connectors.)

Connectors are not provided with the Fiber Amplifier Unit and must be ordered separately. * Protective stickers: provided.

Appearance	Cable length	Number of conductors	Models	Ratings and Specifications	Dimensions
Straight	2 m		XS3F-M421-402-A		Page 88
	5 m		XS3F-M421-405-A	David 00	88-C
L-shaped	2 m	4	XS3F-M422-402-A	Page 88	Page 88
	5 m		XS3F-M422-405-A		88-D

Mounting Bracket

A Mounting Bracket is not provided with the Fiber Amplifier Unit and must be ordered separately as required.

Appearance	Model	Quantity	Dimensions
	E39-L143	1	Page 89 89-A

DIN Track

A Din Track is not provided with the Fiber Amplifier Unit and must be ordered separately as required.

Appearance Type		Models	Quantity	Dimensions
	Shallow type, total length: 1 m	PFP-100N		Page 89
	Shallow type, total length: 0.5 m	PFP-50N	1	89-B
	Deep type, total length: 1 m	PFP-100N2		Page 89 89-C

End Plate

Two End Plates are provided with the Sensor Communications Unit. End Plates are not provided with the Fiber Amplifier Unit and must be ordered separately as required.

Appearance	Model	Quantity	Dimensions
	PFP-M	1	Page 89 89-D

Cover

Attach these Covers to Amplifier Units.

Order a Cover when required, e.g., if you lose the covers.

Appearance	Model	Quantity
	E39-G25 FOR E3NX-FA	1

Flat

Sleeved

Small Spot

High Power Narrow view

BGS

Retro-reflective

Limited-

Heatresistant

Area Detection Liquid-level

resistant, Oil-resistant Bendina

Vacuum FPD, Semi. Solar

Ratings and Specifications

		Туре	Stan	dard			Advanced			Model for Sensor Communications Unit
		NPN output	E3NX-FA11	E3NX-FA6	E3NX-FA21	E3NX-FA7	E3NX-FA7TW	E3NX-FA24	_	E3NX-FA0
	PNP output		E3NX-FA41	E3NX-FA8	E3NX-FA51	E3NX-FA9	E3NX-FA9TW	E3NX-FA54	E3NX-FA54TW	ESINX-FAU
Item		Connecting method	Pre-wired	Wire-saving Connector	Pre-wired	Wire-savin	g Connector	M8 Cor	nector	Connector for Sensor Communications Unit
Inputs /	Output		1 0	ıtput	2 outputs	1 output	2 outputs	1 output	2 outputs	*4
Outputs	External	input	-	_	1 input	1 input	_	1 input	_	— * 1
Light source	e (wavelen	gth)	Red, 4-eleme	nt LED (625 n	m)					
Power supp	oly voltage		10 to 30 VDC	, including 10 ^t	% ripple (p-p)					Supplied from the connector through the Sensor Communications Unit
Power cons	sumption *	2	Standard Mo Normal mod Eco function Eco function Advanced Mo Normal mod Eco function	e : 840 mW ON : 650 mW LO : 750 mW odels or Model e : 920 mW ON : 680 mW	I max. (Curren I max. (Curren I max. (Curren for Sensor Co I max. (Curren I max. (Curren	at consumption to consumption mmunications at consumption to consumption	at 35 mA max. at 27 mA max. at 31 mA max. Unit: at 38 mA max. at 28 mA max. at 33 mA max)))		
Control output			Load current: Gr (Residual vol	oad power supply voltage: 30 VDC max., open-collector output oad current: Groups of 1 to 3 Amplifier Units: 100 mA max., Groups of 4 to 30 Amplifier Units: 20 mA max. Residual voltage: At load current of less than 10 mA: 1 V max., At load current of 10 to 100 mA: 2 V max.) DEF current: 0.1 mA max.						
External inp	out		-	_	Refer	to *3.	_	Refer to *3.		_
Indicators			7-segment displays (Sub digital display: green, Main digital display: white) Display direction: Switchable between normal and reversed. OUT indicator (orange), L/D indicator (orange), ST indicator (blue), DPC indicator (green) OUT Selection Indicator (orange)(only on models with 2 outputs)							
Protection of	circuits		Power supply reverse polarity protection, output short-circuit protection, and output reverse polarity protection							Power supply reverse polarity protection and output short-circuit protection
D	Super-hi (SHS) *4	gh-speed mode	Operate or reset for model with 1 output: 30 μ s, with 2 outputs: 32 μ s							
Response time	High-spe	ed mode (HS)	Operate or re	set: 250 µs						
	Standard	I mode (Stnd)	Operate or re	set: 1 ms						
	Giga-pov	ver mode (GIGA)	Operate or re	set: 16 ms						
Sensitivity a	adjustmen	t					ning, maximum		ng,	
Maximum connectable Units			30 units	30 units						With E3NW-ECT: 30 units *5 With E3NW-CRT: 16 units With E3NW-CCL: 16 units
Mutual	Super-hi (SHS) *4	-high-speed mode								
interference	High-spe	ed mode (HS)	Possible for up to 10 units							
prevention	Standard	l mode (Stnd)	Possible for u	p to 10 units						
	Giga-pov	ver mode (GIGA)	Possible for u	p to 10 units						
	Auto pov	ver control (APC)	Always ON							
	Dynamic									
	Functions Select from timer disabled, OFF-delay, ON-delay, one-shot, or ON-delay + OFF-delay timer.									
Functions		power control (DPC)		,	OFF-delay, ON	N-delay, one-sl	not, or ON-dela	y + OFF-delay	timer.	
Functions			Select from ti 1ms to 9999n	,				y + OFF-delay	timer.	

*1. Two sensor outputs are allocated in the programmable logic controller PLC I/O table.

PLC operation via Communications Unit enables reading detected values and changing settings.

*2. At Power Supply Voltage of 10 to 30 VDC.

Standard Models:

Normal mode : 990 mW max. (Current consumption: 33 mA max. at 30 VDC, 65 mA max. at 10 VDC)
Eco function ON : 780 mW max. (Current consumption: 26 mA max. at 30 VDC, 42 mA max. at 10 VDC) Eco function LO : 840 mW max. (Current consumption: 28 mA max. at 30 VDC, 45 mA max. at 10 VDC) Advanced Models:

Normal mode : 1,020 mW max. (Current consumption: 34 mA max. at 30 VDC, 67 mA max. at 10 VDC)

Eco function ON : 810 mW max. (Current consumption: 27 mA max. at 30 VDC, 44 mA max. at 10 VDC)

Eco function LO : 870 mW max. (Current consumption: 29 mA max. at 30 VDC, 48 mA max. at 10 VDC)

*3. The following details apply to the input.

	Contact input (relay or switch)	Non-contact input (transistor)	Input time*3-1
NPN type	ON: Shorted to 0V (Sourcing current: 1 mA max.). OFF: Open or shorted to Vcc.	ON: 1.5V max. (Sourcing current: 1 mA max.). OFF: Vcc – 1.5 V to Vcc (Leakage current: 0.1 mA max.)	ON : 9ms min.
PNP type	ON: Shorted to Vcc (Sinking current: 3 mA max.). OFF: Open or shorted to 0V.	ON: Vcc – 1.5 V to Vcc (Sinking current: 3 mA max.). OFF: 1.5V max.(Leakage current: 0.1 mA max.)	OFF : 20ms min.

- *3-1. Input time is 25 ms (ON)/(OFF) only when (in tUnE) or (in PtUn) input is selected.
 *4. The mutual interference prevention function is disabled if the detection mode is set to super-high-speed mode.
- *5. When connected to an OMRON NJ-series Controller.

 *6. The bank is not reset by the user reset function or saved by the user save function.

	Туре		Stan	dard			Advanced			Model for Sensor Communications Unit	
	NPN outpo	ıt	E3NX-FA11	E3NX-FA6	E3NX-FA21	E3NX-FA7	E3NX-FA7TW	E3NX-FA24	_	E3NX-FA0	
	PNP outpu	ıt	E3NX-FA41	E3NX-FA8	E3NX-FA51	E3NX-FA9	E3NX-FA9TW	E3NX-FA54	E3NX-FA54TW	LOITA-I AO	
Item	Connecting	g method	Pre-wired	Wire-saving Connector	Pre-wired	Wire-saving	Connector	M8 Cor	nector	Connector for Sensor Communications Unit	
Functions Eco mode *7			Select from C	OFF (digital dis	plays lit), Eco	ON (digital disp	olays not lit) or	Eco LO (digita	l displays dimr	ned)	
Bank switching			Select from b	anks 1 to 4.							
	Power tuning		Select from C	ON or OFF.							
	Output 1		Select from n	ormal detectio	n mode, or are	a detection mo	ode.				
	Output 2		-	_	Select from normal detection mode, alarm output mode, or error output mode.	_	Select from normal detection mode, alarm output mode, or error output mode.		Select from no mode, alarm or error outpu		
	External input		-	_	Select from inp power tuning, zero reset, or I		_	Select from input OFF, tuning, power tuning, emission OFF, zero reset, or bank switching.		_	
	Hysteresis width		Select from s	Select from standard setting or user setting. For a user setting, the hysteresis width can be set to from 0 to 9,999.							
Ambient III	umination (Receiver s	de)	Incandescent lamp: 20,000 lx max., Sunlight: 30,000 lx max.								
Ambient te	mperature range		Groups of 3 t Groups of 11 Groups of 17	o 10 Amplifer to 16 Amplifer to 30 Amplifer	nits: –25 to 55 Units: –25 to 5 Units: –25 to 5 Units: –25 to 6 Units: –25 to 6 Units: –25 to 6 Units: –25 to 7	0°C, 45°C, 40°C				Operating: Groups of 1 to 2 Amplifer Units: 0 to 55°C, Groups of 3 to 10 Amplifer Units: 0 to 50°C, Groups of 3 to 10 Amplifer Units: 0 to 50°C, Groups of 11 to 16 Amplifer Units: 0 to 45°C, Groups of 17 to 30 Amplifer Units: 0 to 40°C Storage: -30 to 70°C (with no icing or condensation)	
Ambient hu	ımidity range		Operating an	d storage: 35 t	o 85% (with no	condensation) within the sur	rounding air te	emperature ran	ge shown above	
Altitude			2,000 m max								
Installation	environment		Pollution degree 3 (as per IEC 60947-1)								
Insulation r	esistance		20 MΩ min. (at 500 VDC)								
Dielectric s	strength		1,000 VAC a	t 50/60 Hz for	1 min						
Vibration re	esistance (destruction)	10 to 55 Hz v	vith a 1.5-mm	double amplitu	de for 2 hours	each in X, Y, a	nd Z directions	3		
Shock resistance (destruction)			500 m/s² for	3 times each ir	n X, Y, and Z d	irections				150 m/s ² for 3 times each in X, Y and Z directions	
Weight (pa	cked state/unit only)		Approx. 115 g/ Approx. 75 g	Approx. 60 g/ Approx. 20 g	Approx. 115 g/ Approx. 75 g	Approx. 60 g	/Approx. 20 g	Approx. 65	g/Approx. 25 g		
	Case		Polycarbonat	te (PC)							
Materials	Cover		Polycarbonat	e (PC)							
	Cable		PVC								
	Gubic										

^{*7.} Eco LO is supported for Amplifier Units manufactured in July 2014 or later.

Flat

Sleeved

Small Spot

High Power

Narrow

view

BGS

Retroreflective

Limitedreflective

Chemical-

resistant, Oil-resistant

Bendina

Heat-

Area

resistant

E3NX-FA

(Unit: mm)


Tolerance class IT16 applies to demmensions in this date sheet unless otherwise specified.


Dimensions

Dillicipions












	Cable Specifications					
Ī	Models		Number of conductors			
	E3NX-FA11 E3NX-FA41	4.0 dia.		Conductor cross-section: 0.2 mm Insulator dia.: 0.9 mm Standard length: 2 m Minimum bending radius: 12 mm		
	E3NX-FA21 E3NX-FA51	4.0 dia.				




Amplifier Units with Wire-saving Connectors







Cable Specifications			
Models	Outer diameter	Number of conductors	
E3X-CN12	2.6 dia.	1	
E3X-CN22	4.0 dia.	2	
E3X-CN11		3	
E3X-CN21		4	





Liquid-level
Vacuum

FPD, Semi, Solar

Installation Information

Fiber Amplifiers, Communications Unit, and Accessories


> ecnnical Guide and Precautions

> > Model Index


OMRON

E3NX-FA `

Amplifier Units with M8 Connector



Amplifier Unit with Connector for Sensor Communications Unit



iber Sensc

selection.

nits S

Ē —

Threaded ____

Cylindrical

Flat

Sleeved
Small Spot

High Power

Narrow view

BGS

Retroreflective

Limitedreflective Chemical-

resistant, Oil-resistant

Bending

resistant

Area Detection

Liquid-level

Vacuum

FPD, Semi, Solar

Installation

iber Amplifiers, ommunications nit, and

> echnical Juide and Precautions

> > **Todel Index**

70

Fiber Amplifiers, Communications Unit and Accessories

E3NX-FA

ber Sensor atures

election uide

Fiber Units

Threaded
Cylindrical

Flat

Sleeved

Small Spot

High Power
Narrow
view

Retroreflective

BGS

Chemicalresistant, Oil-resistant

Bending

Heatresistant Area

Detection
Liquid-level

FPD, Semi, Solar

Installation Information

riber Ampliners, Communications Unit, and Accessories

Technical Suide and Precautions

Model Index

I/O Circuit Diagrams

NPN Output

Models	Operation mode	Timing chart	L/D indicators	Output circuit
E3NX-FA11	Light-ON	Incident light No incident light OUT indicator Lit (orange) Output ON transistor Load Set (e.g., relay) Reset (Between brown and black leads)	L lit.	Display OUT indicator (orange) Brown Black Control output
E3NX-FA6	Dark-ON	Incident light No incident light OUT indicator Lit (orange) Not lit Output ON transistor OFF Load Set (e.g., relay) Reset (Between brown and black leads)	D lit.	Photoelectric Sensor main circuit Blue
E3NX-FA21	Light-ON	ch1/ Incident light ch2 No incident light OUT indicator (orange) Not lit Output ON transistor OFF Load Set (e.g., relay) Reset (Between brown and black (orange) leads)	L/lit.	Display OUT1 indicator OUT2 indicator (orange) Photoelectric Sensor main circuit Pink ch2 External intput
	Dark-ON	ch1/ Incident light ch2 No incident light OUT indicator (orange) Not lit Output ON transistor Load Set (e.g., relay) Reset (Between brown and black (orange) leads)	D lit.	
E3NX-FA7	Light-ON	Incident light No incident light OUT indicator (orange) Not lit Output ON transistor Load (e.g., relay) Reset (Between brown and black leads)	L lit.	Display OUT indicator (orange) Brown Black Control output 10 to 30 VDC Orange
E3NX-FA24	Dark-ON	Incident light No incident light OUT indicator (orange) Not lit Output ON transistor Laad Set (e.g., relay) Reset (Between brown and black leads)	D lit.	• M8 Connector Pin Arrangement 2 4
E3NX-FA7TW	Light-ON	ch1/ Incident light ch2 No incident light OUT indicator (orange) Not lit Output ON transistor Load Set (e.g., relay) Reset (Between brown and black (orange) leads)	L lit.	Display OUT1 indicator OUT2 indicato
	Dark-ON	ch1/ Incident light ch2 No incident light OUT indicator (orange) Not lit Output ON transistor OFF Load Set (e.g., relay) Feset (Between brown and black (orange) leads)	D lit.	Photoelectric Sensor main circuit Dynamic Control output chi2 Blue

ber Senso

Selectio

Fiber Units

Cylindrical

Flat

Small Spot

Sleeved

High Power

Narrow view BGS

Retroreflective

Chemicalresistant,

Limited-

Oil-resistant

Bending

Heatresistant

Area Detection

Liquid-level

Vacuum FPD.

Semi

Solar


Installation

r Amplifiers, munications and


> chnical iide and ecautions

> > Model Inde

PNP Output



Plug (Sensor I/O Connector)



Wire color	Connection pin	Application
Brown	1	Power supply (+V)
White	2	External input / Output
Blue	3	Power supply (0 V)
Black	4	Output

Flat Sleeved

Small Spot **High Power** Narrow

BGS Retroreflective

view

Limitedreflective Chemicalresistant. Oil-resistant

> Bending Heatresistant


> > Area Detection

Liquid-level


Vacuum FPD. Semi Solar

Nomenclature

E3NX-FA11/FA41/FA6/FA8/FA7/FA9/FA24/FA54



E3NX-FA21/FA51/FA7TW/FA9TW/FA54TW/FA0



Used to fine-tune the threshold or change set values. The indicator for the selected output channel is lit.

Operating Procedures

Basic Settings

Output switching

1. Press D button.

Through-beam:

Set to "Dark ON" to turn the output ON with a workpiece in the detection area. [L/D Indicator] turns D ON.

Reflective:

Set to "Light ON" to turn the output ON with a workpiece in the detection area.




Smart Tuning [Easy Sensitivity Setting]

(1) Detect for Workpiece Presence/Absence

2-point Tuning

1. Press o button with a workpiece in the detection area.



2. Press button again without a workpiece in the detection area. Release the button when [33772] is displayed. Setting is Completed

Incident light level setting:

The larger incident level of the Step 1 and 2 values is adjusted to the power tuning level. Threshold setting

Set to the middle between the Step 1 and 2 incident light levels.




Step 1 and Step 2 can be reversed.

(2) Enhance Durability of the Fiber Head against Dust and Dirt

Maximum Sensitivity Tuning

1. Hold button for 3 seconds or longer with/without workpiece as shown below.

Release the button when [Fift] is displayed





Incident light level setting: The incident level in Step 1 is adjusted to "0" Threshold setting

The value is set to approx. 7% of the incident light level of 1.

➡ Setting is Completed

However, the Sensor becomes more susceptible to the influence of background objects.

(3) Adjust for Moving Workpiece without Stopping Line

Full Auto Tuning

1. Hold the button without the presence of a workpiece, and pass the workpiece through while $[3333] \rightarrow [3332] \rightarrow [3332]$ is displayed in green digital.



(Keep holding the button while the workpiece passes through, and hold 7 seconds or longer until [838 a] is displayed in green digital. After the workpiece passes through, release your finger from the button.)





Incident light level setting: Adjust the max. incident light level on Step 1 as the power tuning level Threshold setting: Set to the middle between max. and min. incident light levels on Step 1.

Basic Settings

(4) Determine Workpiece Position

Position Tuning


1. Turn ON power tuning in SET mode.

Refer to "Detailed Settings"

2. Press button without a workpiece in the area



3. Place the workpiece at the desired position and hold button.



Incident light level setting: The Step 3 incident level is adjusted to half the power tuning level. Threshold setting: Set to the same value as the Step 3 incident level.

(5) Detect Transparent or Small Workpiece

(Set Threshold by incident light level percentage)

Percentage Tuning

1. Turn ON Percentage Tuning in SET mode.

Refer to "Detailed Settings" 2. Press button without a workpiece in the area.





Setting is Completed

Setting is Completed

The Step 2 incident light level is adjusted to the power tuning level. Threshold setting:

Set to the value obtained by [Incident Level at Step 2 x (1 + Percentage Tuning Level)].




No Smart Tuning other than Power Tuning can be used if Percentage Tuning is set.

(6) Restore from the Incident Level Changed due to Dust and Dirt

Power Tuning

1. Hold and buttons for 1 second or longer without a workpiece in the area



Incident light level setting: The Step 1 incident level is adjusted to the power tuning level. Threshold setting: Not changed



Perform the procedure with a workpiece in the area for reflective model setting If the setting is made after position tuning, set both the through-beam model and reflective model with a workpiece.



Smart Tuning Error

Error / Display / Cause	Error Origin Tuning Type	Remedy
Near Error The light level difference between Points 1 and 2 are extremely small.	2-point Tuning Full Auto Tuning	Change the detection function mode to a slower response time mode. Reduce the distance between the emitter and receiver. (Through-beam) Place the Fiber Head closer to the sensing object. (Reflective)
Over Error Incident light level is too high.	All	Use a thin-diameter fiber. Widen the emitter and receiver distance. (Through-beam) Distance the Fiber Head from the sensing object. (Reflective)
Low Error Low Error Incident light level is too low.	Tuning other than Maximum Sensitivity Tuning	Reduce the distance between the emitter and receiver. (Through-beam) Place the Fiber Head closer to the sensing object. (Reflective)


Refer to " Detailed Settings " to change the power tuning level.

Channel switching

Fiber Amplifiers, Communications Unit and Accessories

/ Models with 2 Outputs: E3NX-FA21,E3NX-FA51,E3NX-FA7TW, E3NX-FA9TW and E3NX-FA54TW

- The OUT selection indicators and the settings will change.
- 1. Press button for 1 second.
- 2. The OUT selection indicators (OUT1/OUT2) switch.



In the detailed settings, the OUT selection indicators will each light whenever the output (OUT1/OUT2) is set.

Minute Adjustment of Threshold Level

1. Press 🖶 🖹 button to adjust the threshold level.

The threshold level becomes higher. 🔲 🚇 130 🕕 🖳 Hold the key for high-speed level adjustment.

Convenient Setting Features

(1) Stable Detection Regardless of Incident Level Change due to Dust and Dirt

 DPC Function (Use of the function with Through-beam model or Retro-reflective model is recommended)

The DPC indicator

turns ON when the


DPC function is effective

#####

1. Perform Smart Tuning

Refer to "Smart Tuning"
Refer to "Power Tuning"

2. Set the DPC function ON in SET mode. Refer to "Detailed Settings"



(2) Reset Settings

Setting Reset

Initializes all the settings by returning them to the factory defaults.

1. Hold button and then hold button for 3 seconds or longer.

2. Select [-56] in and press putton.

3. Select [₹\$\$ + ∞ \$] in ⊕ and press ☐ button.

(3) Save or Read Settings

- 1. Hold button and then hold button for 3 seconds or longer.
 - User Save Function Saves the current settings
 - 2. Select [58uE] in 🖶 and press 🗓 button.
 - 3. Select [5₽JE YE5] in (∰ |= and press 🗖 button.
- User Reset Function Reads out the saved settings

Hold both for 3 sec

- 2. Select [-5+] in [and press 🗐 button.
- 3. Select [-5₺ #5₺-] in ⊕ 🗐 and press 🗖 button.

(4) Prevent Mistake-operation

Key Lock Function

Disables all button operations. [LoC on] is displayed when the button is pressed.

Enable/Cancel (This procedure)

20 **()** Hold both for 3 sec or longer * Press either of UP/DOWN

Threaded

Cylindrical

Flat

Sleeved

Small Spot

High Power

Narrow view

BGS

Retroreflective

Limitedreflective

Chemicalresistant. Oil-resistant

Bending

resistant Area Detection

Liquid-level

Vacuum FPD.

> Semi. Solar

Cylindrical

Flat

Sleeved

Small Spot

Narrow

BGS

Retro-

reflective

Limited-

reflective

Chemical-

resistant.

Bending

Heat-

Area

resistant

Detection

Liquid-level

Vacuum

FPD.

Semi.

Solar

High Power view


Oil-resistant

Convenient Setting Features

(5) Reset Incident Light Level to "0"

Zero Reset Function

Changes the incident light level to "0". The threshould level is also shifted accordingly. The lower limit of the threshold is -1,999.



(6) Producing an Output When the Incident Level Is within an Area

Area Detection Mode

- 1. Select [SET Mode] [OUT1 Mode] -[Area Detection Mode]. Press 📶 button for at least 3 seconds to leave the SET mode
- 2. Press Dutton in [Detection Mode] LOW. "HIGH" and "LOW" will appear control output OFF on the green digital display.
- 3. Press button for the high and low thresholds to execute smart tuning.
- Percentage Tuning: The thresholds are set as follows: High: Incident level from step 3 + Incident level from step 3 × Percentage tuning level Low: Incident level from step 3 - Incident level from step 3 x Percentage tuning level

(7) Monitoring the Incident Level for Sensing Objects Passing at High Speed

Change Finder

- 1. Select [SET Mode]→[Digital Display] to set [4 59 054-].
- The maximum value and minimum value are displayed with Light-ON and Dark-ON
- 2. Press Dutton for 3 seconds or longer to leave the SET mode.
- 3. Send a workpiece past the Fiber Unit.
- The maximum and minimum incident levels will be displayed for 0.5 seconds when the workpiece passes



(8) Determining If the Workpiece Can Be Detected

- Solution Viewer 1. Press ☐ button and ☐ button threshold together for 3 seconds or longer to set To clear the setting, press D button Incident level Passing time(ms or µs) and button together for 3 seconds or longer to set [Sat Bass].
- 2. Send a workpiece past the Fiber Unit.
- 3. Displaying the Passing Time and Difference in Incident Levels.
- 4. Press 🗐 button and 🖺 button together for 3 seconds or longer to leave SET mode



Detailed Settings

3. DPC

4. Timer

5. Power

Tuning

A Function Selection:

P-1.5555

Function

Function

_ΦFF

ontd

Hold Dutton for 3 seconds or longer to enter SET mode. SET mode provides the function settings described hereafter. The initial display shown after transition from

one function to another represents the factory default.


Function Setting

The OUT selection indicators shows items for output 1 or output 2 individually for each output.





Description



68 4000

<u>o</u>n


SHS

Response Time


	Detection Function	Response Time	Light Level
(a)	HS High-speed mode	250 μs	1(Standard)
(b)	STND Standard mode	1ms	1 time
	GIGA Giga mode	16ms	8 times
(d)	SHS Super-high- speed mode*	30µs	0.25 times
	Smart Tuning is ca detection mode is		he

- The communication and mutual interference prevention functions are disabled when the detection mode is set to super-high-speed mode. The response time for models with 2 outputs is 32 μs
- The incident light level in SET mode is a reference value. It may be changed when switched to detection mode.

Stable Detection Regardless of Incident Light Level Change







A timer value can be set after pressing button when a timer menu (other display than "---") is displayed. Use button to set the time. (1 to 9999 ms in 1 ms steps; the

D-ON ON -- Ta --


initial value: 10 ms) **Changing the Target Incident**

Light Level (Power Tuning Level) Use 🖶 🖹 button to set the power tuning level.


[833 to 8333 in 1 steps; the initial

value: 333331

Refer to "Convenient Setting Features"







Threaded

High Power

Narrow view

> **BGS** Retro-

reflective Limitedreflective

Chemicalresistant. Oil-resistant

Bending


Area Detection

resistant

Liquid-level


Vacuum FPD. Semi.

Solar



vana 9999

figures for 0.5 seconds.



OMRON

iper sensor eatures

electio iuide

iber Units

Standard Installation

Cylindrical

Flat

Sleeved

saving Space

Small Spot

High Power

Narrow view BGS

Retro-reflective
Limited-

Chemicalresistant, Oil-resistant

Heatresistant

> Area Detection

Liquid-level

FPD, Semi, Solar

Installation Information

riber Amplitiers, Communications Unit, and Accessories

> Technical Guide and Precautions

> > Model Index

Ratings and Specifications

Item Models	E3NW-ECT	E3NW-DS	
Connectable Sensor Amplifier Units	N-Smart Smart Fiber Amplifier Unit: E3NX-FA0 Color Fiber Amplifier Unit: E3NX-CA0 *1 Smart Laser Amplifier Unit: E3NC-LA0 Smart Laser Amplifier Unit (CMOS type): E3NC-SA0 Contact-Type Smart Amplifier Unit: E9NC-TA0 *2		
Power supply voltage	24VDC (20.4 to 26.4 VDC)		
Power and current consumption	2.4 W max. (Not including the power supplied to Sensor.) 100 mA max. (Not including the current supplied to Sensor.)	2 W max. (Not including the power supplied to Sensor.) 80 mA max. (Not including the current supplied to Sensor.)	
Indicators	L/A IN Indicator (Green), L/A OUT Indicator (Green), PWR Indicator (Green), RUN Indicator (Green), ERROR Indicator (Red),and SS (Sensor Status) indicator (Green/Red)	RUN Indicator (Green), and SS (Sensor Status) indicator (Green/Red)	
Vibration resistance (destruction)	10 to 60 Hz with a 0.7-mm double amplitude, 60 to 150 Hz 50 m/s² for 1.5 hours each in X, Y, and Z directions		
Shock resistance (destruction)	Destruction: 150 m/s² for 3 times each in X, Y, and Z direction	ons	
Ambient temperature range	Operating: 0 to 55°C, *3 Storage: –30 to 70°C (with no icing	or condensation)	
Ambient humidity range	Operating and storage: 25% to 85% (with no condensation)		
Maximum connectable Sensors	30 *4	10	
Maximum connectable Distributed Sensor units	8	_	
Insulation resistance	20 $M\Omega$ min. (at 500 VDC)		
Dielectric strength	500 VAC 50/60Hz 1 min		
Mounting method	35-mm DIN track-mounting		
Weight (packed state/unit only)	Approx. 185 g/Approx. 95 g	Approx. 160 g/Approx. 40 g	
Materials	Polycarbonate		
Accessories	Power supply connector,Communications connector for E3NW-DS DIN Track End Plates (2) and Instruction manual	, Power supply/communications connector, DIN Track End Plates (2), Ferrite cores (2) and Instruction manual	

- *1. The E3NX-CA0 is supported for firmware version 1.06 or higher (Sensor Communications Units manufactured in June 2016 or later).
- *2. The E9NC-TA0 is supported for firmware version 1.03 or higher (Sensor Communications Units manufactured in July 2014 or later).
- *3. Temperature Limitations Based on Number of Connected Amplifier Units:
- Groups of 1 or 2 Amplifiers: 0 to 55°C, Groups of 3 to 10 Amplifiers: 0 to 50°C, Groups of 11 to 16 Amplifiers: 0 to 45°C, Groups of 17 to 30 Amplifiers: 0 to 40°C
- *4. A maximum total of 30 Sensors can be connected to a Sensor Communications Unit and Distributed Sensor Units.

Communications Specifications

Item	Specifications
Protocol	EtherCAT
Modulation	Baseband
Baud rate	100 Mbps
Physical layer	100Base-TX (IEEE802.3u)
Topology	Daisy chain
Communications media	STP category 5 or higher
Communications distance	100 m max. between nodes
Noise immunity	Compliant with IEC 61000-4-4, 1 kV min.
Node address setting method	Set the decimal rotary switches or software *1
Node address range	000 to 192 *2

- *1. The software setting is used when the node address setting switches are set to 0.
- *2. The range depend on the EtherCAT master that is used. Refer to the E3NW-ECT EtherCAT Sensor Communications Unit Operation Manual for details.

CompoNet-compatible and CC-Link-compatible products are also available. Refer to your OMRON website for details.

E3NW \

(Unit: mm)

Fiber Sens Features

> selectio Suido

its G

Fiber Un

hreaded

Cylindrical

Flat

Small Spot

Sleeved

High Power

Narrow view

BGS

Retroreflective

Limitedreflective

Chemicalresistant, Oil-resistant

Bending

resistant

Area Detection

Liquid-level

Vacuum


FPD, Semi, Solar

Installation Information

Fiber Amplifiers, Communications Unit, and


> chnical iide and ecautions


> > Model Inde



Distributed Sensor Unit







E3NW

iber Sensor eatures

Selection Suide

Fiber Units

Threaded

Cylindrical

Flat

Sleeved

se Standard Installati

Saving Space

Small Spot

High Power

Narrow

BGS

Retroreflective

view

Limited-reflective

Chemical-resistant,
Oil-resistant

Bending Heat-

Area Detection

Liquid-level

FPD, Semi,

Installation Information

Hber Amplitiers, Communications Unit, and Accessories

> echnical iuide and recautions

> > Model Index

78

E3X-HD Fiber Amplifier Units and Related Products

Fiber Amplifier Units E3X-HD Series

			Мо	Models		
Туре	Appearance	Connecting method	NPN output PNP output		Ratings and Specifications	Dimensions
		Pre-wired (2 m)	E3X-HD11 2M	E3X-HD41 2M		Page 80 80-A
Standard models		Wire-saving Connector	E3X-HD6	E3X-HD8	Dogo 90	Page 81 81-A
		M8 Connector	E3X-HD14	E3X-HD44	- Page 80	Page 81 81-B
Model for Sensor Communications Unit		Connector for Sensor Communications Unit	E3X-HD0			Page 81 81-C

Sensor Communications Unit

Communication method	Appearance	Applicable Fiber Amplifier Model	Models	Ratings and Specifications	Dimensions
CompoNet	Townson .	E3X-HD0	E3X-CRT	Page 86	Page 87
EtherCAT		E3X-MDA0	E3X-ECT	rage ou	Page 87

E3NW

Accessories (sold separately)

Wire-saving connectors (Required for models for Wire-saving Connectors.)

Connectors are not provided with the Fiber Amplifier Unit and must be ordered separately. * Protective stickers: provided.

Туре	Appearance	Cable length	Number of conductors	Models	Ratings and Specifications	Dimensions
Master Connector		0	3	E3X-CN11	B	Page 88
Slave Connector		- 2m -	1	E3X-CN12	Page 88	Page 88 88-B

Sensor I/O Connectors (Required for models with M8 Connectors.)

Connectors are not provided with the Fiber Amplifier Unit and must be ordered separately. * Protective stickers: provided.

Appearance	Cable length	Number of conductors	Models	Ratings and Specifications	Dimensions
Straight	2m		XS3F-M421-402-A		Page 88
	5m		XS3F-M421-405-A	Dana 00	88-C
L-shaped	2m	4	XS3F-M422-402-A	Page 88	Page 88
	5m		XS3F-M422-405-A		88-D

Mounting Bracket

A Mounting Bracket is not provided with the Fiber Amplifier Unit and must be ordered separately as required.

Appearance	Model	Quantity	Dimensions
	E39-L143	1	Page 89 89-A

DIN Track

A Din Track is not provided with the Fiber Amplifier Unit and must be ordered separately as required.

Appearance	Туре	Models	Quantity	Dimensions
	Shallow type, total length: 1 m	PFP-100N		Page 89
	Shallow type, total length: 0.5 m	PFP-50N	1	89-B
	Deep type, total length: 1 m	PFP-100N2		Page 89 89-C

End Plate

Two End Plates are provided with the Sensor Communications Unit.

End Plates are not provided with the Fiber Amplifier Unit and must be ordered separately as required.

Appearance	Model	Quantity	Dimensions
5	PFP-M	1	Page 89 89-D

Fiber Sens

Selection Guide

Fiber Unit

Threaded

Cylindrical

Flat

Sleeved

Small Spot

High Power

Narrow view

BGS

Retroreflective Limitedreflective

Chemicalresistant, Oil-resistant

Bending

Heatresistant

Area Detection

Liquid-level

FPD, Semi.

Solar Installatio

iber Amplifiers, Jommunications Init and

> echnical uide and recautions

> > odel Inde

Fiber Amplifiers, Communications Unit and Accessories

Cylindrical

Flat

Sleeved

Small Spot

Narrow

BGS

High Power view

Retroreflective Limitedreflective

Chemicalresistant, Oil-resistant Bendina

Heatresistant Area Detection

Liquid-level

Vacuum

FPD,

Semi. Solar

Ratings and Specifications

	Туре		Standard			Model for Sensor Communications Unit *1	
		NPN output	E3X-HD11	E3X-HD6	E3X-HD14	E3X-HD0	
		PNP output	E3X-HD41	E3X-HD8	E3X-HD44	E3A-HD0	
Item		Connecting method	Pre-wired	Wire-saving Connector *2	M8 Connector	Connector for Sensor Communications Unit	
Light source	(wavelength)		Red, 4-element LED (625	nm)			
Power supply	y voltage		12 to 24 VDC ±10%, ripple	e (P-P) 10% max.		Supplied from the connector through the Sensor Communications Unit	
Power	Normal mod	le	720 mW max. (Current cor	nsumption: 30 mA max. at 2	24 VDC, 60 mA max. at 12	DVC)	
consumption Eco ON			nsumption: 22 mA max. at 2				
	Eco LO		,	sumption: 26 mA max. at 24 \		_	
Control outp	ut		Load current: Groups of 1 Groups of 4 Residual voltage: At load of	e: 26.4 VDC max., open-collicto 3 Amplifier Units: 100mA to 16 Amplifier Units: 20mA current of less than 10 mA: 1 current of 10 to 100 mA: 2 V	max., max. V max.,	_	
Protection ci	rcuits		Power supply reverse polarity pro	rity protection, output short tection	-circuit protection and	Power supply reverse polarity protection and output short-circuit protection	
Response	Super-high- mode (SHS)	•	NPN outputs: Operate or r PNP outputs: Operate or r			_	
time High-speed mode (HS)		Operate or reset: 250 µs (Operate or reset: 250 µs (default setting)				
Standard mode (Stnd)		ode (Stnd)	Operate or reset: 1 ms				
	Giga-power	mode (GIGA)	Operate or reset: 16 ms				
Maximum co	nnectable Un	its	16 units			with E3X-CRT: 16 units with E3X-ECT: 30 units *3	
Mutual interfe	erence preve	ntion	Possible for up to 10 units (optical communications sync) *4				
Auto power of	control (APC)		Always ON				
Other function	ns		Power tuning, differential detection, DPC, timer (OFF-delay, ON-delay, or one-shot), zero reset, resetting settings, and Eco mode				
Ambient Illun	nination (Rec	eiver side)	Incandescent lamp: 20,000	0 lx max., Sunlight: 30,000 l	x max.		
Ambient temperature range Groups of 3 to 10 Amplifier Units: -25 to 50°C, Groups of 11 to 16 Amplifier Units: -25 to 45°C Groups of 11 to 16 Amplifier Units: -25 to 45°C Storage: -30 to 70°C (with no icing or condensation) Groups of 17 to 30 Amplifier Units: -25 to 45°C Groups of 17 to 30 Amplifier Units: -25 to 45°C Groups of 17 to 30 Amplifier Units: -25 to 50°C, Groups of 11 to 16 Amplifier Units: -25 to 45°C Groups of 11 to 16 Amplifier Units: -25 to 45°C Groups of 11 to 16 Amplifier Units: -25 to 45°C Groups of 11 to 16 Amplifier Units: -25 to 45°C Groups of 11 to 16 Amplifier Units: -25 to 45°C		Operating: Groups of 1 to 2 Amplifier Units: 0 to 55°C, Groups of 3 to 10 Amplifier Units: 0 to 50°C, Groups of 11 to 16 Amplifier Units: 0 to 45°C, Groups of 17 to 30 Amplifier Units: 0 to 40°C Storage: –30 to 70°C (with no icing or condensation)					
Ambient hum	nidity range		Operating and storage: 35	% to 85% (with no condens	ation)		
Insulation res	sistance		20 MΩ min. (at 500 VDC)				
Dielectric str	ength		1,000 VAC at 50/60 Hz for	1 min			
Vibration res	istance (dest	ruction)	10 to 55 Hz with a 1.5-mm double amplitude for 2 hours each in X, Y, and Z directions			10 to 150 Hz with a 0.7-mm double amplitude for 80 minutes each in X, Y, and Z directions	
Shock resista	ance (destruc	tion)	500 m/s² for 3 times each in X, Y, and Z directions			150 m/s² for 3 times each in X, Y, and Z directions	
Degree of pro	otection		IEC 60529 IP50 (with Prot	ective Cover attached)			
Weight (pack	ed state/unit	only)	Approx. 105 g/Approx. 65 g	Approx. 60 g/Approx. 20 g	Approx. 70 g/Approx. 25 g	Approx. 65 g/Approx. 25 g	
	Case		Polycarbonate (PC)	0		Heat-resistant ABS (connector: PBT)	
Materials	Cover		Polycarbonate (PC)				
	Cable		PVC				
			Instruction Manual				


- *1.The E3X-ECT EtherCAT Sensor Communications Unit and the E3X-CRT CompoNet Sensor Communications Unit can be used.
- *2. Use either the E3X-CN11 (master connector, 3 conductors) or the E3X-CN12 (slave connector, 1 conductor).
- When connected to an OMRON NJ-series Controller.
 When connected to an OMRON NJ-series Controller.
 The communications function and matual interference prevention function are disabled when the detection mode is set to Super-high-speed mode (SHS). When including E3X-DA-S with activated power tuning the maximum number of mutual interference prevention is up to 6.
 When including E3X-MDA with activated power tuning the maximum number of mutual interference prevention is up to 5.

Dimensions

Tolerance class IT16 applies to demmensions in this date sheet unless otherwise specified.

(Unit: mm)

Pre-wired Amplifier Units



E3X-HD



election

Fiber Units

Threaded

Cylindrical

Flat Sleeved

Small Spot

High Power

Narrow

view

Retroreflective

Limitedreflective

Chemicalresistant, Oil-resistant

Bending

....

resistant Area

Detection

Liquid-level

Vacuum

FPD, Semi, Solar

Installation Information


ber Amplifiers, ommunications nit, and

> chnical ide and ecautions

> > Model Inde

Amplifier Units with Wire-saving Connectors







Amplifier Unit with Connector for Sensor Communications Unit









E3X-HD

ner sensor eatures

Selection Suide

Fiber Units

Threaded

Cylindrical

Sleeved Sleeved

High Power

Narrow
view

BGS

Small Spot

Retroreflective

Limitedreflective

Transparent Objects

Chemical-resistant,
Oil-resistant

Bending

Heatresistant Area

Detection

Liquid-level

Vacuum

FPD, Semi, Solar

Installation Information

riber Amplitiers, Communications Unit, and Accessories

> Fechnical Suide and Precautions

> > Model Index


I/O Circuit Diagrams

NPN Output

Models	Operation mode	Timing chart	L/D indicators	Output circuit
E3X-HD11 E3X-HD6 E3X-HD14	Light-ON	Incident light No incident light OUT indicator (orange) Not lit Output transistor OFF Load Set (e.g., relay) Reset (Between brown and black leads)	L lit.	Display OUT indicator (orange) Brown Black Control output T 12 to 24 VDC
	Dark-ON	Incident light No incident light OUT indicator (orange) Not lit Output Unitransistor OFF Load (e.g., relay) Reset (Between brown and black leads)	D lit.	M8 Connector Pin Arrangement Note: Pin 2 is not used.


PNP Output

	The Output				
Models	Operation mode	Timing chart	L/D indicators	Output circuit	
E3X-HD41 E3X-HD8 E3X-HD44	Light-ON	Incident light No incident light OUT indicator Lit (orange) Not lit Output ON transistor OFF Load Set (e.g., relay) Reset (Between blue and black leads)	L lit.	Display OUT indicator (orange) Display OUT indicator (orange) Display OUT indicator (orange) Brown Brown Brown Black Control output Sensor main circuit Load 12 to 24 VDC	
	Dark-ON	Incident light No incident light OUT indicator Lit (orange) Not lit Output ON transistor OFF Load Set (e.g., relay) Reset (Between blue and black leads)	D lit.	M8 Connector Pin Arrangement Note: Pin 2 is not used. Blue 3 Blue 3 Blue	



Note: Timing Charts for Timer Settings (T: Set Time)

Plug (Sensor I/O Connector)



 Wire color
 Connection pin
 Application

 Brown
 1
 Power supply (+V)


 White
 2
 --

 Blue
 3
 Power supply (0 V)

 Black
 4
 Output

Note: Pin 2 is not used.

Nomenclature



Operating Procedures

Basic Settings


Output switching

1. Press Dutton.

Through-beam:

Set to "Dark ON" to turn the output ON with a workpiece in the detection area. [L/D Indicator] turns D ON.

Set to "Light ON" to turn the output ON with a workpiece in the detection area. [L/D Indicator] turns (L) ON.




Setting is Completed

Smart Tuning [Easy Sensitivity Setting]

(1) Detect for Workpiece Presence/Absence

2-point Tuning

1. Press D button with a workpiece in the detection area



2. Press button again without a workpiece in the detection

Incident light level setting:

The larger incident level of the Step 1 and 2 values is adjusted to the power tuning level. Threshold setting: Set to the middle between the Step 1 and 2 incident light levels.

Step 1 and Step 2 can be reversed.


(2) Enhance Durability of the Fiber Head against Dust and Stain

Maximum Sensitivity Tuning


1. Hold button for 3 seconds or longer with/without workpiece

Release the button when [33 + 10.1] is displayed.

Through-beam: Workpiece is present



Reflective: Workpiece is absent





Incident light level setting:

The incident level in Step 1 is adjusted to "0". Threshold setting


The value is set to approx. 7% of the incident liaht level of 1

If the incident light level of 1 is smaller during long distance detection, the minimum value by which an output is correctly turned ON will be set.

(3) Adjust for Moving Workpiece without Stopping Line

Full Auto Tuning

1. Hold the o button without the presence of a workpiece, and pass the workpiece through while [!Pn₺] → $[FULL] \rightarrow [RUE_0]$ is displayed in red digital.



(Keep holding the button while the workpiece passes through, and hold 7 seconds or longer until [RUL a] is displayed in red digital. After the workpiece passes through,



Incident light level setting:

Adjust the max, incident light level on Step 1 as the power tuning level. Threshold setting

Set to the middle between max. and min. incident light levels on Step 1.


(4) Determine Workpiece Position

Position Tuning

1. Press D button without a workpiece in the area.



2. Place the workpiece at the desired position and hold button.



The red digital display changes $[P \cap P] \rightarrow [P \cap P]$.

➡ Setting is Completed

Incident light level setting:

The Step 2 incident level is adjusted to half the power tuning level. Threshold setting: Set to the same value as the Step 2 incident level.


(5) Detect Transparent or Small Workpiece (Set Threshold by incident light level percentage)

Percentage Tuning

1. Turn ON Percentage Tuning in SET mode

Refer to "Detailed Settings".

2. Press button without a workpiece in the area.



Incident light level setting:

The Step 2 incident light level is adjusted to the power tuning level. Threshold setting: Set to the value obtained by [Incident Level at Step 2 × Percentage Tuning Level + Incident Level at Step 2].

No Smart Tuning other than Power Tuning can be used if Percentage Tuning is set

Smart Tuning Error

Error / Display / Cause	Error Origin Tuning Type	Remedy
Near Error The light level difference between Points 1 and 2 are extremely small.	2-point Tuning Full Auto Tuning Positioning Tuning	Change the detection function mode to a slower response time mode. Reduce the distance between the light emitting and light receiving surfaces. (Through-beam) Place the Fiber Head closer to the sensing object. (Reflective)
Over Error DUET Error Incident light level is too high.	All	Enhance the power tuning level. Use a thin-diameter fiber. Widen the emitter and receiver distance (Through-beam) Distance the Fiber Head from the sensing object(Reflective)
Low Error Lo Err Incident light level is too low.	Tuning other than Maximum Sensitivity Tuning	Decrease the power tuning level. Reduce the distance between the ligh emitting and light receiving surfaces. (Through-beam) Place the Fiber Head closer to the sensing object. (Reflective)



The adjustment range of smart tuning is approx. 20 to 1/100 times When selecting giga mode as detection function, the range will be approx. 2 to 1/100 times due to the large initial value.

Refer to "Detailed Settings" to change the power tuning level.

Minute Adjustment of Threshold Level

1. Press 🖶 button to adjust the threshold level.





Hold the key for high-speed level adjustment.

Threaded

Cylindrical

Flat

Sleeved

Small Spot

High Power

Narrow view

BGS

Retroreflective Limited-

Chemical-

Oil-resistant

Bending

resistant

Detection

Liquid-level

Vacuum FPD. Semi.

Solar

Cylindrical

Flat

Sleeved

Small Spot

view

BGS

Retro-

reflective

Limited-

reflective

Chemical-

resistant.

Heat-

Area

Liquid-level

High Power Narrow

Oil-resistant Bending

resistant Detection

Vacuum FPD. Semi.


Solar

Convenient Setting Features

(1) Restore from the Incident Level Changed due to Dust and Dirt

Power Tuning

1. Hold and d buttons for 1 second or longer without a



Incident light level setting:

The Step 1 incident level is adjusted to the power tuning level. Threshold setting:

Not changed. If the value is low, it will be set to the minimum value in which an output is turned ON/OFF correctly.



Perform the procedure with a workpiece in the area for reflective model setting. If the setting is made after position tuning, set both the through-beam model and reflective model with a workpiece.




Refer to "Smart Tuning Error" for error displays.

(2) Stable Detection Regardless of Incident Level Change due to Dust and Dirt

- DPC Function (Use of the function with Through-beam model or Retro-reflective model is recommended)
 - 1. Perform Smart Tuning


Refer to "Smart Tuning" Refer to "Power Tuning"



2. Set the DPC function ON in SET mode. Refer to "Detailed Settings"



- Steps 1 and 2 can be reversed.
- · The DPC function will be disabled when a smart tuning error occurs, differential function with maximum sensitivity tuning is performed, or the first incident light level of the positioning tuning is low.
- The incident light level is corrected to the power tuning level to maintain stable threshold and incident light levels. This provides stable detection regardless of the incident level changes caused by dirty sensor head, position error, or temperature changes.




The displayed incident level decreases and the DPC indicator starts blinking when incident level correction is not possible.

(3) Reset Settings

Setting Reset

Initializes all the settings by returning them to the factory defaults.

1. Hold o button and then hold button for 3 seconds or longer.



- 2. Select [5] in and press button.
- 3. Select [55 in the] in the and press the button.

Item	Initial Value
Threshold Value	55
Control Output	L-ON

Settings for other functions are returned to the detailed setting initial values User-saved settings are retained. Smart Tuning is canceled



Caution is required; the output is inverted if button is pressed first.

(4) Save or Read Settings

- 1. Hold button and then hold button for 3 seconds or longer.
 - User Save Function Saves the current settings.
 - 2. Select [58LE] in A and press 🗐 button.
 - Select [5868 485] in 🔠 🗐 and press 🔲 button.
- User Reset Function

Reads out the saved settings.

- 2. Select [-5] in [and press 🗐 button.
- 3. Select [-5₺ <u>#5₺</u>-] in ∰ and press 🗖 button.



(5) Prevent Mistake-operation

Key Lock Function

Disables all button operations. [Lac an] is displayed when the button is pressed.

Enable/Cancel (This procedure)



* Press either of UP/DOWN.

(6) Reset Incident Light Level to "0"

Zero Reset Function

Changes the incident light level to "0". The threshold level is also shifted accordingly.

Enable



Cancel






The zero reset function is canceled when either of the DPC function/differential function/Smart Tuning is performed.




Hold 🗓 button for 3 seconds or longer to enter SET mode.

SET mode provides the function settings described hereafter. The initial display



(A)



Threaded

Cylindrical

Flat

Sleeved

Small Spot

High Power

Narrow view

BGS

Retroreflective

reflective Chemicalresistant.

Limited-

Oil-resistant

Bending

resistant

Area Detection

Liquid-level

Vacuum FPD. Semi.

Solar

E3X-CRT and ECT

ber Sensol eatures

n Fibe Feat

Selection Guide

Fiber Units

Standard Installat

Saving Space

Flat

Sleeved

Small Spot

High Power

Narrow view

BGS

Retroreflective

Limitedreflective

Chemicalresistant, Oil-resistant

Bending Heat-

Area Detection

Liquid-level

Vacuum FPD, Semi.

Solar

Installation

riber Ampliners, Communications Unit, and Accessories

Technical Guide and Precautions

Model Index

Ratings and Specifications

E3X-CRT

Item	Specifications		
Communication method	CompoNet Communications		
Connectable Sensors	Fiber Sensors: E3X-HD0 and E3X-MDA0 Laser Sensor Head with Separate Digital Amplifier: E3C-LDA0 Proximity Sensor with Separate Amplifier: E2C-EDA0		
Communications power supply voltage	14 to 26.4 VDC (Communications Unit draws power from the communications power supply.)		
Power and current consumption	2.4 W max. (Not including the power supplied to Sensor.) 100 mA max. at 24 VDC (Not including the current supplied to Sensor.)		
Functions	I/O communications, message communications, and Sensor error output		
Indicators	MS Indicator (Green/Red), NS indicator (Green/Red), and SS (Sensor Status) indicator (Green/Red)		
Vibration resistance	10 to 150 Hz with double amplitude of 0.7 mm, or 50 m/s ² 80 min each in X, Y, and Z directions		
Shock resistance	150 m/s ² 3 times each in X, Y, and Z directions		
Dielectric strength	500 VAC 50/60Hz 1 min		
Insulation resistance	20 Μ Ω min.		
Ambient operating temperature	0 to 55°C (with no icing or condensation) * The temperature is limited by the number of connected Fiber Amplifier Units.		
Ambient operating humidity	25% to 85% (with no icing or condensation)		
Storage temperature	_30 to 70°C (with no icing or condensation)		
Storage humidity	25% to 85% (with no condensation)		
Mounting method	35-mm DIN track-mounting		
Weight (packed state/unit only)	Approx. 220 g/Approx. 95 g		
Accessories	Connector cover, DIN track End Plates and Instruction manual		

Note. The E3X-CRT has two operating modes: I/O mode 1 and I/O mode 2. The following table gives the differences between these modes.

	I/O classification	Number of allocated points	Maximum number of interconnected
I/O mode 1	Input Unit	Input: 32	15
I/O mode 2	I/O Unit	Input: 64 Output: 64	16

Read the User's Manual for precautions on using this Unit. (E412)

 * Temperature Limitations Based on Number of Connected Fiber Amplifier Units: Groups of 1 to 2 Amplifier Units: 0 to 55°C,
 Groups of 3 to 10 Amplifier Units: 0 to 50°C,
 Groups of 11 to 16 Amplifier Units: 0 to 45°C

E3X-ECT

Item	Specifications		
Communication method	EtherCAT		
Connectable Sensors	Fiber Sensor E3X-HD0 and E3X-MDA0 Laser Sensor Head with Separate Digital Amplifier: E3C-LDA0 Proximity Sensor with Separate Amplifier: E2C-EDA0		
Power supply voltage	20.4 to 26.4 VDC		
Power and current consumption 2.4 W max. (Not including power the supplied to Sensor.) 100 mA max. at 24 VDC (Not including the current supplied to Sensor.)			
Functions	DC (synchronous) mode, Free run mode, PDO communications,* 1 SDO communications, Sensor error output		
Indicators	L/A IN indicator (Yellow), L/A OUT indicator (Yellow), PWR indicator (Green), RUN indicator (Green), ERROR indicator (Red), and SS (Sensor Status) indicator (Green/Red)		
Vibration resistance	10 to 150 Hz with double amplitude of 0.7 mm, or 50 m/s² 80 min each in X, Y, and Z directions		
Shock resistance	150 m/s ² 3 times each in X, Y, and Z directions		
Dielectric strength 500 VAC 50/60 Hz 1 min			
Insulation resistance	20MΩ min.		
Ambient operating temperature	0 to 55°C (with no icing or condensation) * The temperature is limited by the number of connected Fiber Amplifier Units.		
Ambient operating humidity	25% to 85% (with no condensation)		
Storage temperature	-30 to 70°C (with no icing or condensation)		
Storage humidity	25% to 85% (with no condensation)		
Mounting method	35-mm DIN track-mounting		
Weight (packed state/unit only)	nly) Approx. 220 g/Approx. 95 g		
Accessories	Power supply connector, connector cover, DIN track End Plates and Instruction manual		

^{1.} Data Size Assignable to the PDO (Process Data Object):

Groups of 1 to 2 Amplifier Units: 0 to 55°C, Groups of 3 to 10 Amplifier Units: 0 to 50°C, Groups of 11 to 16 Amplifier Units: 0 to 45°C, Groups of 17 to 30 Amplifier Units: 0 to 40°C Read the User's Manual for precautions on using this Unit. (E413)

There is a maximum data size that can be assigned. The maximum size is 36 bytes.

^{*2.} Temperature Limitations Based on Number of Connected Fiber Amplifier Units:

E3X-CRT and **ECT**

(Unit: mm)

tion

Selecti Guide

Fiber Unit

Threaded

Cylindrical

Flat

Small Spot

Sleeved

High Power

Narrow view

BGS

Retroreflective

Limitedreflective

Chemicalresistant, Oil-resistant

Bending

Heatresistant

Area Detection

Liquid-level

Vacuum FPD,

Semi, Solar

Installation

Fiber Amplifiers Communications Unit, and

> echnical uide and ecautions


> > lodel Inde


Dimensions


Tolerance class IT16 applies to demmensions in this date sheet unless otherwise specified.


















Fiber Amplifiers, Communications Unit and Accessories

Accessories (sold separate)

Threaded Cylindrical

Flat Sleeved

Small Spot High Power Narrow view

Retroreflective reflective

BGS

Chemicalresistant. Oil-resistant Bending

Heatresistant Area Detection

Liquid-level Vacuum FPD, Semi.

Solar

Ratings and Specifications

Wire-saving Connectors

Item	Тур	Master C	Connector	Slave Co	onnector	
пеш	Mode	s E3X-CN21	E3X-CN11	E3X-CN22	E3X-CN12	
Number (of conducto	s 4	3	2	1	
Diameter of cable		4 dia.			2.6 dia.	
Rated current		2.5A	2.5A			
Rated voltage		50VDC				
Contact resistance		$20~\text{m}\Omega$ max. (20 mVDC max., 100 mA max.) (The above figure is for connection to the Amplifier Unit and the adjacent Connector. It does not include the conductor resistance of the cable.)				
Number of insertions		Destruction: 50 times (for connection to the Amplifier Unit and the adjacent Connector)				
Material Housing		Polybutylene terephthalate (PBT)				
Contact Phosphor bronze/gold-plated nickel						
Weight (p	oacked state	Approx. 55 g	Approx. 55 g Approx. 25			

Sensor I/O Connectors

Item	Models	XS3F-M42□-40□-A
Number of conductors		4
Diameter of cable		4 dia.
Rated current		1A
Rated voltage		125VDC
Contact resistance		40 mΩ max. (20 mVDC max., 100 mA max.)
Number of insertions		Destruction: 200 times

(Unit: mm)

Dimensions

Tolerance class IT16 applies to demmensions in this date sheet unless otherwise specified.


Wire-saving Connectors (for Models with Wire-saving Connectors)

Master Connector



88-A E3X-CN21 **E3X-CN11**






Slave Connector

88-B E3X-CN22 E3X-CN12






Sensor I/O Connectors (for Models with M8 Connectors)




88-C XS3F-M421-402-A XS3F-M421-405-A





88-D XS3F-M422-402-A XS3F-M422-405-A




Accessories (sold separately)


Mounting Brackets




89-A E39-L143








Material: Stainless steel (SUS304)



DIN track








Material: Aluminum









Material: Aluminum

End Plate









Material: Iron, zinc plating

Threaded

Cylindrical

Flat

Sleeved

Small Spot

High Power

Narrow view

BGS

Retroreflective

Limitedreflective

Chemicalresistant, Oil-resistant

Bending

Heatresistant

Area Detection

Liquid-level

Vacuum

FPD, Semi. Solar

90

iber Sensoi eatures

election iuide

Fiber Units

Threaded

Cylindrical

Saving Space

Small Spot

Flat

Sleeved

Narrow view

BGS

Retroreflective Limited-

Chemicalresistant, Oil-resistant

reflective

Bending

Heatresistant

Area Detection

Liquid-level

Vacuum

FPD, Semi, Solar

Installation Information

iber Amplitiers, Sommunications Juit, and Accessories

> Fechnical Suide and Precautions

> > Model Index

Reference Information for Fiber Units


Influence of Fiber Cable Length

The sensing distance listed in the Fiber Units specifications are based on the fiber cable lengths found in the suffix of the model number. The sensing distance will change if the fiber cable is cut or extended.

The following graph shows the percentage change of the various fiber cable length, where 100% is the sensing distance for a fiber cable with a length of 2 m.

Use this as a guideline for installation distances.

Keep in mind that extending the cable with a fiber connector will result in even shorter sensing distances than the value given in the graph.




* The 100% value is for a fiber cable with a length of 2 m (same for Through-beam and Reflective Models).

Reflective Models: Sensing Distance Ratios by Workpiece Materials

The following graph shows the percentage change of the various workpieces, where 100% is the sensing distance for white paper, the standard sensing object.

Refer to the value of the material that looks like your workpiece.



* White paper is 100%

Types of Fiber Cables

This section describes the features of different types of fiber cables.


(This is given in the Fiber Unit specifications as either Flexible or Bend-resistant for the cable bending radius, and Coaxial for the appearance.

If no difinition is given, a standard cable is used.)

Flexible Fibers

The flexible fiber has a small bending radius for easy routing without easily breaking.

It is easy to use because the cable can be bent without significantly reducing light intensity.



Break-resistant Fibers

This fiber is resistant to repeated bends for use on moving parts.



Standard Fibers

This fiber have a large bending radius compared with bend-resistant or flexible fiber.

Use this fiber where the bending radius is large, or on non-moving parts.

Structure only of one fiber

Coaxial Reflective Fibers

These fibers are suitable for sensing small objects at close range.



Q&A

Category	Question	Answer	
	How do I interpret the optical axis diameter in the Fiber Unit specifications?	The optical axis diameter is the beam size that the Through-beam Fiber Unit uses for detection. If you are detecting objects larger than the optical axis diameter, you can expect stable detection performance because the object will block all of the beams of light that are used for detection. The incident level may fluctuate, however, if the workpiece passes the beam at high speed. In this case, it is best to select a Fiber Unit with a smaller optical axis diameter, or change the response time of the Fiber Amplifier Unit to High-speed mode or to Super-high-speed mode setting. Beam spread of 60°	
Fiber Units	Are there any differences between the Fiber Units that are used for emitter and receiver?	With Through-beam Fiber Units, there is no difference between emitter fibers and receiver fibers. With Reflective Fiber Units, the emitter fibers and receiver fibers are different on Coaxial Reflective Models. Emitter fiber cables have identification marks. Refer to the individual dimensions diagrams of Fiber Units for details.	
	What size must the hole be to mount a Threaded or Cylindrical Fiber Unit?	Refer to the recommended mounting hole dimensions given on pages 58 to 61.	
	Are Fiber Cables available in different lengths?	Some models are available with either 5-m or 10-m cable. Ask your OMRON representative for details.	
	What is the aperture angle?	The aperture angle is the angle at which the emitter beam spreads out.	
	Are these Fiber Units CE certified?	Fiber Units do not have any electrical components and therefore are exempt from CE certification.	
	Can these Fiber Units be used in explosionproof areas?	The Fiber Units can be used in an explosion-proof area. Install only the Fiber Unit in the explosion-proof area and install the Fiber Amplifier Unit outside the explosion-proof area.	
	What the Fiber Units with built-in lenses?	These highly recommended Fiber Units have built-in lenses that achieve stable detection with high-power beams.	
Fiber Amplifier Units	Can the Fiber Amplifier Units be linked with other models?	The E3X-HD Series can be connected only with the E3X-DA-S and MDA Series.	
	Can the Fiber Amplifier Unit be operated from a mobile console?	Mobile consoles cannot be used with either the E3NX-FA Series or the E3X-HD Series.	
	Can a Sensor Communications Unit be used?	If you use E3NX-FA0 Amplifier Units, you can use the E3NW-ECT(EtherCAT), E3NW-CRT(CompoNet) or E3NW-CCL (CC-Link). If you use E3X-HD0 Amplifier Units, you can use the E3X-CRT (CompoNet) or E3X-ECT (EtherCAT).	

iber Sens

electio

Fiber Unit

Threaded

Cylindrical

Flat

Sleeved

Small Spot

High Power

Narrow view

BGS

Retroreflective

Limitedreflective

Chemicalresistant, Oil-resistant

Bending

Heatresistant

Area Detection

Liquid-level

iquiu-icvci

Vacuum

FPD, Semi, Solar

Installation Information

Fiber Amplifiers Communications Ilnit and

> ecnnical Suide and Precautions

> > **Todel Index**

or fire.

iper sensol eatures

selectio Auide

Fiber Units

Threaded

Cylindrical

Flat

Sleeved

Small Spot

High Power

Narrow

view

BGS

Retro-

reflective

Limited-

reflective

Chemical-

resistant.

Oil-resistant

Bendina

Heatresistant

Area

Detection

Liquid-level

Vacuum

FPD.

Semi.

Solar

Saving Spac

Beam Improvement

ransparent Objects

ironmental Immuni

suon

Applicat

nstallation nformation

riber Ampiniers Communication Unit, and Accessories

Technical Guide and Precautions

Model Index

For common precautions, refer to www.ia.omron.com

Fiber Amplifier Unit

⚠ Warning

This product is not designed or rated for ensuring safety of persons either directly or indirectly.

Do not use it for such purposes.



Do not use the product with voltage in excess of the rated voltage.

Excess voltage may result in malfunction



Never use the product with AC power supply. Otherwise, explosion may result.



Precautions for Safe Use

The following precautions must be observed to ensure safe operation of the product. Doing so may cause damage or fire.

- (1) Do not install the product in the following locations.
 - · Locations subject to direct sunlight
 - · Locations subject to condensation due to high humidity
 - · Locations subject to corrosive gas
 - Locations subject to vibration or mechanical shocks exceeding the rated values
 - · Locations subject to exposure to water, oil, chemicals
 - · Locations subject to stream
- · Locations subjected to strong magnetic field or electric field
- (2) Do not use the product in environments subject to flammable or explosive gases.
- (3) Do not use the product in any atmosphere or environment that exceeds the ratings.
- (4) To secure the safety of operation and maintenance, do not install the product close to high-voltage devices and power devices
- (5) High-Voltage lines and power lines must be wired separately from this product. Wiring them together or placing them in the same duct may cause induction, resulting in malfunction or damage.
- (6) Do not apply load exceeding the ratings. Otherwise, damage or fire may result.
- (7) Do not short the load. Otherwise, damage or fire may result.
- (8) Connect the load correctly.
- (9) Do not miswire such as the polarity of the power supply.
- (10) Do not use the product if the case is damaged.
- (11) Burn injury may occur. The product surface temperature rises depending on application conditions, such as the ambient temperature and the power supply voltage. Attention must be paid during operation or cleaning.
- (12) When setting the Sensor, be sure to check safety, such as by stopping the equipment.
- (13) Be sure to turn off the power supply before connecting or disconnecting wires.
- (14) Do not attempt to disassemble, repair, or modify the product Unit in any way.
- (15) When disposing of the product, treat it as industrial waste.
- (16) Do not use the Sensor in water, rain, or outdoors.

Precautions for Correct Use

- (1) Be sure to mount the unit to the DIN track until it clicks.
- (2) When using Amplifier Units with Wire-saving Connectors, attach the protective stickers (provided with E3X-CN-series Connectors) on the unused power pins to prevent electrical shock and short circuiting. When using Amplifier Units with Connectors for Communications Units, attach the protective caps (provided with Sensor Communications Unit).

Amplifier Unit with
Wire-saving Connector

Protective Sticker
Power Supply
Connecting Terminal



(3) <E3NX-FA series>

The length for the cable extension must be 30 m or less (or less than 10 m for S-mark certified models).

Be sure to use a cable of at least 0.3 mm² for extension.

The power voltage must be 24 to 30 V when connecting amplifier units with extension cable and wire-saving connector. <E3X-HD series>

The length for the cable extension must be 100 m or less. Be sure to use a cable of at least 0.3 mm² for extension.

- (4) Do not apply the forces on the cord exceeding the following limits: Pull: 40N; torque: 0.1N⋅m; pressure: 20N; bending: 29.4N
- (5) Do not apply excessive force such as tension, compression or torsion to the Amplifier Unit with the Fiber Unit fixed to the Amplifier Unit.
- (6) Always keep the protective cover in place when using the Amplifier Unit. Not doing so may cause malfunction.
- (7) It may take time until the received light intensity and measured value become stable immediately after the power is turned on depending on use environment.
- (8) The product is ready to operate 200 ms after the power supply is turned ON.
- (9) The Mobile Console E3X-MC11, E3X-MC11-SV2 and E3X-MC11-S cannot be connected.
- (10) Mutual interference prevention on the E3NX-FA Series does not function among the E3X-HD, E3X-DA-S, E3X-DA-N, E3X-SD, or E3X-NA Fiber Amplifier Units.
 - Mutual interference prevention on the E3X-HD Series does not function among the E3NX-FA, E3X-DA-N, E3X-SD, or E3X-NA Fiber Amplifier Units.
 - Mutual interference prevention on the E3X-HD Series does function among the E3X-DA-S and E3X-MDA Fiber Amplifier Units.
- (11) If the unit receives excessive sensor light, the mutual interference prevention function may not work properly, resulting in malfunction of the unit. In such case, increase the threshold.
- (12) The E3NW-ECT Sensor Communications Unit can be used with the E3NX-FA0, but the E3X-DRT21-S, E3X-CRT, and E3X-ECT Sensor Communications Units cannot be used. The E3X-CRT and E3X-ECT Sensor Communications Unit can be used with the E3X-HD0, but the E3X-DRT21-S and E3NW-ECT Sensor Communications Units cannot be used.
- (13) If you notice an abnormal condition such as a strange odor, extreme heating of the unit, or smoke immediately stop using the product, turn off the power, and consult your dealer.
- (14) Do not use thinner, benzine, acetone, and lamp oil for cleaning.

Mounting the Fiber Amplifier Units

■ Mounting on DIN Track

1. Let the hook on the Amplifier Unit's Fiber Unit connection side catch the track and push the unit until it clicks.




■ Removing from DIN Track

- 1. Push the unit in the direction 1.
- 2. Lift it up in the direction 2.




Refer to "I/O Circuit Diagrams" or check the side of the unit for wire color and role indications.



■ Mounting Amplifier Units in Group (Wire-saving Connector Type Models)

- 1. Mount the Fiber Amplifier units one at a time onto the DIN track and push them until they click.
- 2. Slide the Fiber Amplifier units in the direction 2.
- 3. Use End Plates (PFP-M: separately sold) at the both ends of the grouped Fiber Amplifier units to prevent them from separating due to vibration or other cause.
- 4. Tighten the screw on the End Plates using a driver.





- Under environments such as vibration, use an end plates even with a single Fiber Amplifier Unit.
- The maximum numbers of connectable Amplifier Units are given in the following table.

		Maximum number of interconnected	Maximum number of mutual interference prevention
E3NX-FA	E3NX-FA series*		10
	E3X-HD series standard models* (E3X-HD11/HD41/HD6/HD8)		10
E3X-HD0	With E3X-ECT	30	10
E3X-HD0	With E3X-CRT	16	10

- If Units are to be connected, the ambient temperature will change with the number of Units that are connected. Check the Ratings and Characteristics specifications.
- · Always turn OFF the power before connecting or disconnecting Units.
- * The mutual interference prevention function cannot be used if the detection mode is set to super-high-speed mode (SHS).

Mounting Fiber Units

Use Fiber Cutter


Cut a thin fiber as follows.

For standard fibers, insert to the desired cutting position and cut.

(1)	The fiber is shipped loosely tightened as shown in the figure at the right	Thin Fiber Attachment (E39-F9) 11.7 mm Loosely tighten.
(2)	Adjust the fiber to the desired length and fully tighten.	
(3)	Insert the Fiber Unit into E39-F4 and cut it.	Fiber Cutter E39-F4 Thin-diameter Fiber Unit Hole × 2 Standard Fiber Unit Hole (dia. 2.2 mm) × 3
(4)	Finished state. (Correctly cut end)	About 0.5 mm Insertion direction Note: The insertion direction into the Fiber Amplifier Unit is shown in the above figure.

Mount Fiber Unit

- 1. Open the protective cover.
- 2. Raise the lock lever.
- 3. Insert the Fiber Unit in the fiber unit hole to the bottom.
- 4. Return the lock lever to the original position and fix the Fiber Unit.





- When mounting a coaxial reflective Fiber Unit, insert the single-core Fiber Unit to the upper hole (Emitter side) and the multi-core
- Fiber Unit to the lower hole (Receiver side).
- The cables for the Single-core Fiber Units (Emitters) have identification marks. Refer to the dimensions diagrams for details.

Multi Core

- · When removing the Fiber Unit, follow the above steps in reverse
 - To maintain the characteristics of the Fiber Unit, make sure the lock is released before removing the Fiber Unit.

Cylindrical

Small Spot

High Power

Narrow view

BGS

Retroreflective

Limited-

Chemical-Oil-resistant

Bending

resistant

Solar

OMRON

Flat

Sleeved

Small Spot

BGS

Retro-

reflective

Limited-

reflective

Chemical-

resistant.

Oil-resistant

Bendina


Heat-

Area

Semi

Fiber Units

This product is not designed or rated for ensuring safety of persons either directly or indirectly.





Precautions for Correct Use


Do not use the Fiber Unit in atmospheres or environments that exceed product ratings.


Mounting

Tightening Force

Refer to pages 58 to 61 for the tightening torque to apply when mounting a Fiber Unit.

<Threaded Models>






<Chemical and Oil-resistant Models>

The following method is recommended for mounting Fiber Units with fluororesin-covered sensing heads (E32-T□F and E32-D□F) to prevent from cracking the fluororesin case.

If you use a set screw to secure the Fiber Unit, tighten it with care to prevent from cracking the case.



Connections

· Do not subject the Fiber Unit to excessive force, such as tension or compression.

Refer to pages 58 to 61 for tensile strengths.


· Make sure any bend in the Fiber Unit is larger than the allowable bending radius.

Refer to pages 58 to 61 for bending radius ratings and length of unbendable sections at the base of the Fiber Unit.

· Do not compress or place heavy loads on the fibers.




· The method shown below is an effective way to prevent the Fiber Unit from breaking due to vibration.



Sleeve Bender (E39-F11)

- · The bending radius of the stainless steel tube should be as large as possible. The smaller the bending radius is, the shorter the sensing distance will be. 1.2 mm dia. max.
- Insert the tip of the stainless steel tube in the Sleeve Bender and slowly bend the tube along the curve of the Sleeve Bender.



Heat-resistant Fiber Units (E32-D51(R) and E32-T51(R))

The fibers of these Units cannot be extended using the E39-F10 Fiber Connector.

E32-T14


90° max

10 mr

These Units may enter the light-ON state if there are reflective objects at the end of the lenses.

If reflection is a problem, attach the black stickers provided to the ends of the lenses.

E32-T16PR



To use the provided slit, peel off the backing sheet, align the slit with the edges of the sensing surface, and attach it to the sensing head.

Use the slit in applications where saturation occurs (i.e., changes in incident level cannot be detected) due to short sensing distances.

Vacuum-resistant Fiber Units (E32- UV)

Although the Flanges, the Fiber Units on the vacuum side, and the Lens Units have been cleaned, as an extra precaution, clean these with alcohol before using them in high-vacuum environments to ensure that they are properly degreased.

Liquid-level Detection Fiber Unit (E32-D82F1)

- · Secure the Fiber Unit using the unbendable section. Otherwise, the liquid-level detection position may be displaced.
- · For applications in hazardous environments, install the Fiber Unit in the hazardous environment but install the Amplifier Unit in a safe environment.

Liquid-level Detection Fiber Units (Tube-mounting Models)

· Make sure that the tube is not deformed when using a band to secure the Fiber Unit.

Threaded

Flat


Model Inde

Adjustment

Detection Position for Liquid-level Detection Fiber Unit (E32-D82F1)

The liquid-level detection position is 5.2 ± 2 mm from the end of the fluororesin section. (Refer to the diagram on the right.)

diagram on the right.)
The liquid-level detection position varies with the surface tension of the liquid and the degree of wetness at the Fiber Unit's detection position.



Other Precautions

Liquid-level Detection Fiber Unit (E32-D82F1)

- · Operation may become unstable in the following cases:
 - 1. Bubbles stick to the cone of the sensing head.
 - 2. Solute deposits on the cone of the sensing head.
 - 3. The liquid has a high viscosity.
- There are some liquids, such as milky white liquids, for which detection is not possible.
- Do not let the end of the fluororesin section bump into other objects.
 - Damage to or deformation of the sensing head may cause unstable operation.
- The product shall be used in the following conditions.
 Ambient pressure: -50 to +500 kPa
- To use one-point teach mode (without object)
 Please carry out teaching where the detecting head is sunk into liquid. The sensitivity is set to 10% upper to the incident level in the liquid. This setting method is effective in high degree of viscosity, because it becomes stable to the fluctuation of incident level when the liquid drops from the tip.
- To use two-point teach mode (with/without object)
 Please teach where the detecting head is pulled up from liquid and next teach where it is sunk into liquid. This setting method is effective to a liquid which is easy to bubble at high temperature.
- Don't use maximum sensitivity mode because a liquid may be undetectable

Chemical and Oil-resistant, Liquid-level Detection Fiber Unit (E32-D82F1)

Fluororesin shows strong chemical-resistant properties but is permeable if exposed to atmospheres with gaseous chemicals or water vapors, resulting in failure or damage.

Confirm applicability sufficiently before using the Fiber Unit in these environments.

Accessories

Use of E39-R3 Reflector Provided with E32-R21


- Use detergent to remove any dust or oil from the surfaces where tape is applied. Adhesive tape will not be attached properly if oil or dust remains on the surface.
- The E39-R3 cannot be used in areas that are exposed to oil or chemicals.

Mounting method of Disconnection-resistant Protective Spiral Tubes (E39-F32□)


- 1.Insert the Fiber Unit into the Protective Spiral Tube from the head connector (threaded).
 - Protective Fiber Unit

mmmmm

Push the fiber into the Protective Spiral Tube. The tube must be straight so that the fiber enters without twisting. Turn the Protective Spiral Tube, not the fiber.




Secure the Protective Spiral Tube to the mounting panel with the provided nuts.



 Use the provided saddle to secure the end cap of the Protective Spiral Tube.


(To secure the Protective Spiral Tube at a position other than the end cap, apply tape to the tube so that the portion becomes thicker in diameter.)



Attaching the E39-F10 Fiber Connector

Attach the Fiber Connecter as shown in the following figures.

- 1. Insert the Fiber Unit in the retention clip.
- 2. Insert the retention clip into the splice.



 The Fiber Units should be as close as possible when they are connected.

The sensing distance is reduced by approximately 25% when Fiber Units are extended by the connector.

· Only 2.2-mm-diameter fibers can be connected.

Hex-shaped Models

Cylindrical

Flat

Small Spot

Sleeved

High Power Narrow

view

BGS

Retroreflective Limited-

Chemical-

Oil-resistant Bendina

resistant

Area Detection

Liquid-level

Vacuum FPD, Semi.

Solar



- · You can easily mount these Fiber Units by making a hole in the bracket and tightening just one nut.
- · The cable follows the wall, so extra space is not required, and the cable will not get caught on other objects.



• Build-in Lens

A Fiber Unit with Build-in Lens is the new standard in fiber units. We recommend this new standard Fiber Unit that achieves stable detection with a high-power beam.

You don't have to worry about the lens falling off and getting lost. Through-beam Flat Fiber Units are also available. (→ 14 page)

Specifications

■→■ Through-beam Fiber Units

	Size	Appearance (mm)	Bending radius of cable	Sensing distance (mm)				Optical axis		
Aperture angle				E3X-HD		E3NX-FA <u>NEW</u>		diameter (minimum sensing	Models	97 Page Dimensions No.
			01 00.010	■GIGA =HS	Other modes	■GIGA =HS	Other modes			1101
Approx.	M4	14.4 Build-in Lens IP50	Flexible, R2	4,000*	ST : 3,500 SHS: 920	4,000* 3,450	ST : 4,000* SHS: 920	2.3 dia. (0.1 dia./ 0.03 dia.)	E32-LT11N 2M <u>NEW</u>	97-A
Approx.	1414	14.7 M4	Flexible, R1	2,000	ST : 1,000 SHS: 280	3,000	ST : 1,500 SHS: 280	1 dia. (5 μm dia./ 2 μm dia.)	E32-T11N 2M	97-B

Reflective Fiber Units

			Bending radius of cable	Se	Sensing distance (mm)					
Aperture angle	Size	Appearance (mm)		ЕЗХ-Н	E3X-HD		E3NX-FA <u>NEW</u>		Models	97 Page Dimensions No.
				■GIGA =HS	Other modes	■GIGA = HS	Other modes	sensing object)		140.
Approx.	M6	15.8 Build-in Lens M6		840	ST : 350 SHS: 100	1,260	ST : 520 SHS: 100	(0.1 dia./ 0.03 dia.)	E32-LD11N 2M <u>NEW</u>	97-C
	M3	Coaxial 18.5	Flexible, R2	290 190	ST : 130 SHS: 39	440 1 130	ST : 190 SHS: 39	(5 μm dia./	E32-C21N 2M <u>NEW</u>	97-D
Approx. 60°	M4	13.5 M4 IP67		840	ST : 350 SHS: 100	1,260	ST : 520 SHS: 100	2 μm dia.)	E32-D21N 2M <u>NEW</u>	97-E
	M6	Coaxial 24 M6 IP67	Flexible, R4	780	ST : 350 SHS: 100	1,170	ST : 520 SHS: 100	(5 μm dia./ 2 μm dia.)	E32-C91N 2M <u>NEW</u>	97-F

Retro-reflective Fiber Units (With M.S.R. Function)

			D	Sensing distance (mm)				Optical axis		
Aperture angle	Size	Appearance (mm)	Bending radius of cable	ЕЗХ-Н	ID	E3NX-FA	<u>NEW</u>	diameter (minimum sensing	Models	97 Page Dimensions No.
				■GIGA =HS	Other modes	■GIGA =HS	Other modes	object)		1101
Approx. 15°	М6	8.5, 44 15.8 80 M6 Baukkai ens	Flexible, R2	1,350	ST : 1,200 SHS: 550	2,020	ST : 1,800 SHS: 550	_	E32-LR11NP 2M + E39-RP1 <u>NEW</u>	97-G

* The optical fiber is 2 m long on each side, so the sensing distance is 4,000 mm.

The following mode names and response times apply to the modes given in the Sensing distance column.

[E3X-HD] GIGA: Giga-power mode (16 ms), HS: High-speed mode (250 μs), ST: Standard mode (1 ms), and SHS: Super-high-speed mode (NPN output: 50 μs, PNP output: 55 μs)

[E3NX-FA] GIGA: Giga-power mode (16 ms), HS: High-speed mode (250 μs), ST: Standard mode (1 ms), and SHS: Super-high-speed mode (30 μs)

The values for the minimum sensing object are reference values that indicate values obtained in standard mode with the sensing distance and sensitivity set to the optimum values. The first value is for the E3X-HD and the second value is for the E3NX-FA.


The sensing distances for Reflective Sensors are for white paper. (The sensing distances for the E32-LD11N 2M are for glossy white paper).
 With Retro-reflective Models, objects with a high reflection factor may cause the Fiber Sensor to detect reflected light as incident light. Also, stable detection may not be possible for transparent objects. Check suitability beforehand.


Dimensions

Installation Information → 58, 59, 60, 61 Page


Standard Installation

Through-beam Fiber Units






Reflective Fiber Units



97-D E32-C21N 2M (Free Cutting)



Note: There is a white line on the emitter fiber.


* Applicable Fiber Amplifier Units: ESNX-FA, E3NX-CA, E3X-HD, and E3X-DA-S.
Use the enclosed E39-F9-7 Fiber Attachment for other models, such as the
E3X-MDA with two channels, and for the E3X-SD, E3X-NA, and other models that

97-E E32-D21N 2M (Free Cutting) Fiber attachment (E39-F9W13) provided * Hexagonal nut Opposite side: 7, Thickness: 2.4 (Nickel-plated brass) M4×0.7 (Trivalent chrome-plated zinc alloy) 4.5 Sensing surface Two, 1 dia


* Applicable Fiber Amplifier Units: E3NX-FA, E3NX-CA, E3X-HD, and E3X-DA-S. Use the enclosed E39-F9-7 Fiber Attachment for other models, such as the E3X-MDA with two channels, and for the E3X-SD, E3X-NA, and other models that have an 8-mm space between the emitter and receiver fiber insertion holes.


97-F E32-C91N 2M (Free Cutting)

(Methacrylate resin)



Retro-reflective Fiber Units (With M.S.R. Function)





- Reference Information for Model Selection -

Features of Coaxial Reflective Type

These Fiber Units offer better detection of small objects at close distances (of 2 mm or less) than Standard Reflective Fiber Units.

They also detect glossy surfaces more reliably than Standard Reflective Fiber Units, even if the surface is tilted.

The receiver fibers are arranged around the emitter fiber as shown below.

Emitter Fiber Receiver Fibers

What Is "Flexible" Fiber?

The flexible fiber has a small bending radius for easy routing without easily breaking. It is easy to use because the cable can be bent without significantly reducing light intensity.



Structure which has a cladding around a large number of ultrafine

Transparent Object Detection

Retro-reflective Models are ideal for detection of transparent objects.

→ 35 Page: Performance Comparison of Transparent Object Detection

And Long-distance Sensing Applications with the E32-T11N

A separate Lens Unit can be attached to extend the sensing distance.

→ 26 Page

Threaded

Cylindrical

Flat

Sleeved

Small Spot

High Power

Narrow view

BGS

Retroreflective Limited-

Chemicalresistant. Oil-resistant

Bending

resistant

Area Detection

Liquid-level

Vacuum

FPD. Semi. Solar

OMRON

Selection by Model

iber Senso eatures

selectic Suide

Fiber Unit

Threaded
Cylindrical
Cylindrical
Flat

Small Spot

High Power

Sleeved

Narrow view BGS

Retroreflective Limitedreflective

Chemicalresistant, Oil-resistant

Heatresistant

Area
Detection
Liquid-level

Vacuum

FPD, Semi, Solar

nformation

riber Amplitier Communication Unit, and Accessories

> Technical Guide and Precaution

> > Model Inde

Specifican			
E32-A01 5M P.50 P.51 61-A E32-A03 2M P.30 P.31 (31-A) P.56 P.57 (57-A) E32-A03-1 2M P.30 P.31 (31-B) P.56 P.57 (57-B) E32-A04 2M P.30 P.31 (31-B) P.56 P.57 (57-B) E32-A08 2M P.30 P.31 (31-C) E32-A08 2M P.36 P.37 (37-C) E32-A08H2 2M P.36 P.37 (37-C) E32-A09 2M P.36 P.37 (37-F) E32-A09 2M P.36 P.37 (37-F) E32-A09H2 2M P.36 P.37 (37-F) E32-A12 2M P.36 P.37 (37-D) E32-CE E32-C21N 2M P.36 P.37 (37-D) E32-C2 P.21 (21-2) E32-C31 2M P.36 P.97 (37-D) E32-C31 2M P.38 P.09 (30-D) E32-C42 1M P.20 P.21 (21-E) E32-C42 1M P.20 P.21 (21-E) E32-C42 1M P.20 P.21 (21-E) E32-C200 2M P.38 P.09 (30-H) (P.20) P.97 (37-F) E32-D E32-D11 2M P.42 P.43 (43-E) E32-D11 2M P.48 P.99 (30-H) E32-D11 2M P.49 P.49 (30-H) E32-D15ZR 2M P.14 P.15 (15-E) E32-D21R 2M P.16 P.19 (15	Models		Dimensions
B32-A01 5M		tions	Dimensions
B32-A03 2M		P.50	P.51 51-A
E32-A03-1 2M P.30 P.31 (31-B) E32-A04 2M P.30 P.31 (31-C) E32-A08 2M P.36 P.57 (57-B) E32-A08 2M P.36 P.37 (37-C) E32-A08H2 2M P.46 P.47 (47-D) P.54 P.55 (55-C) E32-A09 2M P.36 P.37 (37-F) P.54 P.55 (55-C) E32-A09H2 2M P.46 P.47 (47-E) P.54 P.55 (55-E) E32-A12 2M P.36 P.37 (37-D) E32-CE P.54 P.55 (55-E) E32-C21N 2M P.96 P.97 (97-D) E32-C31 2M P.98 P.97 (97-D) P.96 P.97 (97-D) E32-C31 2M P.98 P.99 (90-D) P.96 E32-C31 M 1M P.98 P.99 (90-D) P.20 (22) (22) (22) (22,1,23) E32-C31 N 2M P.08 P.09 (90-D) P.20 (22) (22) (22,1,23) E32-C31 M 1M P.98 P.99 (90-D) P.21 (21-A) E32-C42 1M P.08 P.09 (90-D) P.21 (21-A) E32-C42 1M P.20 P.21 (21-A) P.21 (21-A) </td <td></td> <td>_ ::</td> <td>$-\sim$</td>		_ ::	$-\sim$
E32-A04 2M		P.56	P.57 57-A
B32-A04 2M	E32-A03-1 2M	P.30	P.31 31-B
E32-A08 2M P.36 P.37 37-C E32-A08H2 2M P.36 P.37 37-C E32-A09H2 2M P.36 P.37 37-F P.54 P.55 65-C E32-A09H2 2M P.36 P.37 37-F P.54 P.55 65-E E32-A12 2M P.36 P.37 37-F E32-C E32-C21N 2M P.36 P.37 37-D P.54 P.55 65-D E32-C E32-C31 2M P.36 P.37 37-D E32-C31 2M P.38 P.99 69-D E32-C31N 2M P.08 P.09 69-A E32-C31N 2M P.08 P.09 69-A E32-C42 1M P.20 P.21 21-A E32-C42 1M P.20 P.21 21-A E32-C42 1M P.20 P.21 21-A E32-C42 1M P.20 P.21 21-B E32-C42 1M P.20 P.21 21-B E32-C42 1M P.20 P.21 21-B E32-C42 1M P.38 P.39 39-H E32-D11 2M P.42 P.43 43-E E32-D11 2M P.38 P.39 39-H E32-D11 2M P.38 P.39 39-H E32-D15XR 2M P.14 P.15 65-E E32-D15YR 2M P.14 P.15 65-E E32-D11R 2M P.08 P.09 69-G E32-D11 2M P.42 P.43 43-B E32-D21R 2M P.18 P.19 48-B E32-D22-S1 2M P.18 P.19 48-B E32-D25-S3 2M P.18 P.19 48-B E32-D32-D31 D.5M P.18 P.19 48-B E32-D32-S3 2M P.18 P.19 48-B E32-D33-S3 2		P.56	P.57 57-B
B32-A08 2M	E32-A04 2M	P.30	P.31 31-C
E32-A08H2 2M P.46 P.47 (7-D) P.54 P.55 (85-E) E32-A09 2M P.36 P.37 (37-F) P.54 P.55 (85-E) E32-A09H2 2M P.46 P.47 (47-E) P.54 P.55 (85-E) E32-A12 2M P.36 P.37 (37-D) P.54 P.55 (85-E) E32-C E32-C E32-C E32-C21N 2M P.36 P.97 (87-D) P.54 P.55 (85-E) E32-C31 2M P.36 P.97 (87-D) P.54 P.55 (85-E) E32-C31 2M P.38 P.09 (80-E) E32-C31 M M P.38 P.09 (80-E) E32-C31N 1M P.38 P.09 (80-E) E32-C31N 1M P.20 P.21 (21-E) E32-C42 1M P.20 P.21 (21-E) E32-C42 1M P.20 P.21 (21-E) E32-C42 1M P.38 P.09 (80-E) E32-C42 1M P.38 P.09 (80-E) E32-D11 2M P.38 P.39 (30-E) E32-D15XR 2M P.14 P.15 (15-E) E32-D15XR 2M P.14 P.15 (15-E) E32-D15ZR 2M P.14 P.15 (15-E) E32-D15ZR 2M P.14 P.15 (15-E) E32-D11R 2M P.42 P.43 (43-E) E32-D21 B 2M P.42 P.43 (43-E) E32-D22 B 2M P.42 P.43 (43-E) E32-D23-S3 2M P.18 P.19 (19-E) E32-D3-S3		P.56	P.57 57-C
B32-A08H2 2M	E32-A08 2M	P.36	P.37 37-C
P.54 P.55 F5-C E32-A09 2M		P.54	P.55 55-B
B32-A09 2M	E32-A08H2 2M	P.46	P.47 47-D
E32-A09H2 2M P.46 P.47 (7-E) E32-A12 2M P.55 (85-E) E32-C21N 2M P.54 P.55 (85-D) E32-C21N 2M P.96 P.97 (87-D) E32-C31 2M P.08 P.09 (09-D) E32-C31 M P.08 P.09 (09-D) E32-C31N 2M P.08 P.09 (09-D) E32-C42 1M P.20 P.21 (21-E) E32-C42 1M P.20 P.21 (21-E) E32-C42S 1M P.20 P.21 (21-E) E32-C11 2M P.08 P.09 (09-B) P.96 P.97 (87-F) E32-D E32-D11 2M P.42 P.43 (43-E) E32-D11D 2M P.38 P.39 (39-H) E32-D11D 2M P.38 P.39 (39-H) E32-D15XR 2M P.14 P.15 (15-E) E32-D15XR 2M P.14 P.15 (15-E) E32-D15ZR 2M P.14 P.15 (15-E) E32-D15ZR 2M P.14 P.15 (15-E) E32-D11R 2M P.08 P.09 (09-F) E32-D21 R 2M P.42 P.43 (43-B) E32-D21 R 2M P.42 P.43 (43-B) E32-D21R 2M P.18 P.19 (19-A) E32-D22R 2M P.18 P.19 (19-A) E32-D22R 2M P.18 P.19 (19-A) E32-D24R 2M P.18 P.19 (19-A) E32-D25-S3 2M P.18 P.19 (19-A) E32-D31-S1 0.5M P.18 P.19 (19-A) E32-D32-S1 2M P.18 P.19 (19-A)		P.54	P.55 55-C
E32-A09H2 2M P.46 P.47 (47-E) P.54 P.55 (55-F) E32-A12 2M P.36 P.37 (37-D) P.54 P.55 (56-F) E32-C E32-C21N 2M P.96 P.97 (97-D) P.20 P.21 (21-2) E32-C31 M M P.08 P.09 (90-E) E32-C31N 2M P.08 P.09 (90-E) E32-C31N 2M P.08 P.09 (90-E) E32-C41 1M P.22 P.23 (23-A) E32-C42 1M P.20 P.21 (21-E) E32-C11 2M P.08 P.09 (90-E) E32-D1 2M P.08 P.09 (90-E) E32-D11 2M P.38 P.39 (30-E) E32-D11 2M P.38 P.39 (30-E) E32-D15XR 2M P.14 P.15 (16-E) E32-D15XR 2M P.14 P.15 (16-E) E32-D15YR 2M P.14 P.15 (16-E) E32-D15ZR 2M P.14 P.15 (16-E) E32-D11 2M P.24 P.25 (25-E) E32-D21 R 2M P.24 P.25 (25-E) E32-D21 R 2M P.24 P.33 (30-E) E32-D21 R 2M P.08 P.09 (90-E) E32-D21 R 2M P.42 P.43 (43-E) E32-D21 R 2M P.42 P.43 (43-E) E32-D21 R 2M P.42 P.43 (43-E) E32-D21 R 2M P.18 P.19 (10-E) E32-D22 R 2M P.18 P.19 (10-E) E32-D24 R 2M P.18 P.19 (10-E) E32-D25-S3 2M P.18 P.19 (10-E) E32-D31-S1 0.5M P.18 P.19 (10-E) E32-D32-S1 0.5M P.18 P.19 (10-E) E32-D32-D32-S1 0.5M P.18 P.19 (10-E) E32-D32-S1 0.5M P.18 P.19 (10-E) E32-D33-S1 0.5M P.	E32-A09 2M	P.36	
P.54 P.55 65-F E32-A12 2M			$-\sim$
P.36 P.37 37-D P.54 P.55 65-D P.56 P.97 87-D P.66 P.97 87-D P.66 P.97 87-D P.20 P.21 P.21 P.23 P.2	E32-A09H2 2M		
P.54 P.55 F8-D			$- \sim$
E32-C21N 2M	E32-A12 2M		······
E32-C21N 2M	E00.0	P.54	P.55 (55-D)
E32-C31 2M P.08 P.09 @P-E E32-C31N 1M P.08 P.09 @P-E E32-C31N 2M P.08 P.09 @P-E E32-C42 1M P.22 P.23 23-A E32-C42 1M P.20 P.21 21-A E32-C42 1M P.20 P.21 21-B E32-D11 2M P.20 P.21 21-B E32-D1 2M P.20 P.20 @P-B E32-D11 2M P.20 P.20 @P-B E32-D15 2R 2M P.14 P.15 16-B E32-D15 2R 2M P.14 P.15 16-B E32-D21 2M P.24 P.25 25-B E32-D21 2M P.24 P.25 25-B E32-D21 R 2M P.20 P.20 @P-B E32-D21 R 2M P.20 P.20 @P-B E32-D21 R 2M P.20 P.20 @P-B E32-D21 B 2M P.20 P.20 @P-B E32-D22 B 2M P.20 P.20 @P-B E32-D24 S 2M P.20 P.20 @P-B E32-D25-S3 2M P.18 P.19 @P-B E32-D25-S3 2M P.18 P.19 @P-B E32-D31-S1 0.5M P.18 P.19 @P-B E32-D32-S1 0.5M P.18 P.19 @P-B E32-D33-S1 0.5M P.18 P.19 @P-B			3 45 (S)
E32-C31 2M	E32-021N 2M		
R20, 22 R21, 23 R23, 23 R	F32_C31 2M	, , ,	
E32-C31M 1M P.08 P.09 (00-E) E32-C31N 2M P.08 P.09 (00-A) E32-C41 1M P.22 P.23 (23-A) E32-C42 1M P.20 P.21 (21-A) (21-B) E32-C42S 1M P.20 P.21 (21-E) E32-CC200 2M P.08 P.09 (00-H) (P.22) P.23 (00-H) (P.23) P.09 (00-H) (P.22) P.09 (00-H) (P.23) P.09 (00-H) (P.23) P.09 (00-H) (P.24) P.09 (00-H) E32-D11 2M P.08 P.09 (00-H) E32-D15XR 2M P.14 P.15 (15-E) E32-D15XR 2M P.14 P.15 (15-E) E32-D15XR 2M P.14 P.15 (15-E) E32-D15ZR 2M P.14 P.15 (15-E) E32-D15ZR 2M P.14 P.15 (15-E) E32-D11 2M P.09 P.09 (00-F) E32-D21 B.2M P.09 (00-F) E32-D21 B.2M P.09 (00-F) E32-D21 B.2M P.09 (00-F) E32-D21B 2M P.09 (00-F) E32-D21B 2M P.09 (00-F) E32-D21B 2M P.18 P.19 (10-B) E32-D22B 2M P.12 P.13 (13-A) P.42 P.43 (43-A) E32-D22R 2M P.18 P.19 (10-B) E32-D24R 2M P.18 P.19 (10-B) E32-D25-S3 2M P.18 P.19 (10-B) E32-D25-S3 2M P.18 P.19 (10-B) E32-D31-S1 0.5M P.18 P.19 (10-B) E32-D32-S1 0.5M P.18 P.19 (10-F) E32-D33-S1 0.5M P.18 P.19 (10-F)	L32-C31 ZIVI		
E32-C31N 2M P.08 P.09 (9-A) E32-C42 1M P.20 P.21 (21-A) (21-B) E32-C42S 1M P.20 P.21 (21-E) E32-CC200 2M P.08 P.09 (9-A) E32-D1 P.20 P.21 (21-E) E32-D11 2M P.08 P.09 (9-B) E32-D11 2M P.08 P.09 (9-B) E32-D11 2M P.08 P.09 (9-G) E32-D11 2M P.08 P.09 (9-G) E32-D11 2M P.08 P.09 (9-G) E32-D15XR 2M P.14 P.15 (15-E) E32-D15XR 2M P.14 P.15 (15-E) E32-D15ZR 2M P.14 P.15 (15-E) E32-D15ZR 2M P.14 P.15 (15-E) E32-D18 2M P.24 P.25 (25-E) E32-D21 R.2M P.26 P.37 (37-E) E32-D21 R.2M P.26 P.37 (37-E) E32-D21 R.2M P.26 P.37 (37-E) E32-D21 R.2M P.29 P.37 (37-E) E32-D21 R.2M P.38 P.39 (39-E) E32-D21 R.2M P.39 P.39 (39-E) E32-D22 R.2M P.39 P.39 (39-E) E32-D22 R.2M P.39 P.39 (39-E) E32-D22 R.2M P.39 P.39 P.39 P.39 P.39 P.39 P.39 P.39	F32-C31M 1M		
E32-C41 1M P.22 P.23 23-A E32-C42 1M P.20 P.21 21-A E32-C42S 1M P.20 P.21 21-E E32-CC200 2M P.08 P.09 (00-B) E32-D1 P.20 P.21 21-E E32-D11 2M P.42 P.43 43-E E32-D11 2M P.38 P.39 30-H E32-D11 2M P.38 P.39 30-H E32-D11 2M P.38 P.39 30-H E32-D15XR 2M P.14 P.15 16-E E32-D15XR 2M P.14 P.15 16-E E32-D15ZR 2M P.14 P.15 16-E E32-D15ZR 2M P.14 P.15 16-E E32-D12 P.18 P.19 10-E E32-D21 R.2 P.25 25-E E32-D21 R.2 P.25 25-E E32-D21 R.2 P.2 P.3 43-B E32-D21 R.2 P.3 43-B E32-D22 R.2 P.12 P.13 13-B E32-D22 R.2 P.12 P.13 13-B E32-D22 R.2 P.12 P.13 13-B E32-D24-S2 P.18 P.19 10-B E32-D25-S3 P.18 P.19 10-B E32-D31-S1 0.5 P.18 P.19 10-B E32-D31-S1 0.5 P.18 P.19 10-B E32-D32-S1 0.5 P.18 P.19 10-F E32-D32-S1 0.5 P.18 P.19 10-F E32-D33-S1 0.5 P.18 P.19 10-F			-
E32-C42 1M P.20 P.21 21-A E32-C42S 1M P.20 P.21 21-B E32-CC200 2M P.08 P.09 69-H (P.22) E32-C91N 2M P.08 P.09 69-H (P.23) E32-D11 2M P.42 P.43 43-E E32-D11 2M P.38 P.39 39-H E32-D11 2M P.38 P.39 39-H E32-D15XR 2M P.14 P.15 16-E E32-D15XR 2M P.14 P.15 16-E E32-D15ZR 2M P.14 P.15 16-E E32-D15ZR 2M P.14 P.15 16-E E32-D12R 2M P.24 P.25 25-E E32-D21 2M P.24 P.25 25-E E32-D21 2M P.24 P.33 43-B E32-D21R 2M P.08 P.09 69-F E32-D21B 2M P.42 P.43 43-B E32-D21B 2M P.42 P.43 43-B E32-D21B 2M P.42 P.43 43-B E32-D21B 2M P.18 P.19 36-B E32-D22B 2M P.18 P.19 36-B E32-D22B 2M P.18 P.19 38-B E32-D22R 2M P.18 P.19 19-A E32-D24R 2M P.18 P.19 19-A E32-D25XB 2M P.18 P.19 19-B E32-D25XB 2M P.18 P.19 19-B E32-D31-S1 0.5M P.18 P.19 19-B E32-D32-S3 2M P.18 P.19 19-B E32-D32-S3 2M P.18 P.19 19-B E32-D32-S3 2M P.18 P.19 19-B E32-D31-S1 0.5M P.18 P.19 19-B E32-D32-S3 2M P.18 P.19 19-B E32-D33-S3 2M P.18 P.19 19-B E32-D33-S3 2M P.18 P.19 19-F			$-\sim$
E32-C42S 1M P.20 P.21 21-E E32-CC200 2M P.08 P.09 69-H (P.22) P.97 67-F E32-D E32-D11 2M P.42 P.43 43-E E32-D11 2M P.38 P.39 39-H E32-D11 2M P.38 P.39 39-H E32-D15XR 2M P.14 P.15 15-E E32-D15XR 2M P.14 P.15 15-E E32-D15XR 2M P.14 P.15 15-E E32-D15ZR 2M P.14 P.15 15-E E32-D15ZR 2M P.14 P.15 15-E E32-D121 R P.24 P.25 25-E E32-D21 2M P.42 P.43 43-B E32-D21 R 2M P.42 P.43 43-B E32-D21 R 2M P.42 P.43 43-B E32-D21 R 2M P.45 P.47 83-B E32-D21 R 2M P.46 P.47 83-B E32-D21 R 2M P.47 P.48 83-B E32-D21 R 2M P.48 P.49 83-B E32-D21 R 2M P.49 P.49 83-B E32-D21 R 2M P.18 P.19 83-B E32-D22 R 2M P.12 P.13 13-A P.42 P.43 43-A E32-D22R 2M P.18 P.19 19-B E32-D24-S2 2M P.18 P.19 19-B E32-D25-S3 2M P.18 P.19 19-B E32-D31-S1 0.5M P.18 P.19 19-B E32-D31-S1 0.5M P.18 P.19 19-B E32-D32-S1 0.5M P.18 P.19 19-B E32-D33-S1 0.5M P.18 P.19 19-B			\sim
E32-C42S 1M P.20 P.21 (21-E) E32-CC200 2M P.08 P.09 (09-H) (P.22) P.09 (09-H) (P.23) E32-C91N 2M P.08 P.09 (09-B) P.96 P.97 (97-F) E32-D E32-D11 2M P.42 P.43 (43-E) E32-D11 2M P.08 P.09 (09-G) E32-D11 2M P.38 P.39 (39-H) E32-D15XR 2M P.14 P.15 (15-E) E32-D15XR 2M P.14 P.15 (15-E) E32-D15YR 2M P.14 P.15 (15-F) E32-D15ZR 2M P.14 P.15 (15-F) E32-D16 2M P.24 P.25 (25-E) E32-D21 2M P.42 P.43 (43-B) E32-D21R 2M P.42 P.43 (43-B) E32-D21R 2M P.69 P.97 (97-E) E32-D21R 2M P.16 P.19 (15-E) E32-D21R 2M P.17 P.18 P.19 (15-E) E32-D22B 2M P.18 P.19 (15-E) E32-D22B 2M P.19 P.19 (15-E) E32-D24R 2M P.18 P.19 (15-E) E32-D25-S3 2M P.18 P.19 (15-E) E32-D31-S1 0.5M P.18 P.19 (15-E) E32-D31-S1 0.5M P.18 P.19 (15-E) E32-D32-S1 0.5M P.18 P.19 (15-E) E32-D33-S1 0.5M P.18 P.19 (15-E)	E32-C42 1M	P.20	P.21 21-A
E32-CC200 2M P.08 P.09 (B-H) (P22) (P23) E32-C91N 2M P.08 P.09 (B-B) P.96 P.97 (97-F) E32-D1 W P.42 P.43 (43-E) E32-D11 2M P.42 P.43 (43-E) E32-D11 2M P.38 P.39 (39-H) E32-D15ZR 2M P.14 P.15 (15-E) E32-D16 2M P.24 P.25 (25-E) E32-D21 2M P.42 P.43 (43-B) E32-D21R 2M P.42 P.43 (43-B) E32-D21R 2M P.96 P.97 (97-E) E32-D21R 2M P.16 P.19 (15-E) E32-D21R 2M P.17 P.18 P.19 (15-E) E32-D22B 2M P.18 P.19 (15-E) E32-D22B 2M P.19 P.19 (15-E) E32-D22R 2M P.19 P.19 (15-E) E32-D22R 2M P.19 P.19 (15-E) E32-D22R 2M P.18 P.19 (15-E) E32-D24R 2M P.18 P.19 (15-E) E32-D25-S3 2M P.18 P.19 (15-E) E32-D25-S3 2M P.18 P.19 (15-E) E32-D31-S1 0.5M P.18 P.19 (15-E) E32-D31-S1 0.5M P.18 P.19 (15-E) E32-D32-S1 0.5M P.18 P.19 (15-E) E32-D33-S1 0.5M P.18 P.19 (15-E)			21-B
E32-D11 2M P.42 P.43 43-E E32-D11 2M P.38 P.39 39-I E32-D11 2M P.48 P.39 39-I E32-D11 2M P.38 P.39 39-I E32-D11 2M P.38 P.39 39-I E32-D15ZR 2M P.14 P.15 15-E E32-D18 2M P.42 P.43 43-B E32-D21R 2M P.90 P.97 97-E E32-D21R 2M P.90 P.97 97-E E32-D21R 2M P.90 P.97 97-E E32-D21R 2M P.18 P.19 15-B E32-D22B 2M P.12 P.13 13-D E32-D22B 2M P.12 P.13 13-D E32-D22R 2M P.12 P.13 13-C E32-D22R 2M P.18 P.19 19-A E32-D24R 2M P.18 P.19 19-A E32-D25-S3 2M P.18 P.19 19-A E32-D25-S3 2M P.18 P.19 19-A E32-D31-S1 0.5M P.18 P.19 19-B E32-D31-S1 0.5M P.18 P.19 19-B E32-D32-S1 0.5M P.18 P.19 19-B E32-D33-S1 0.5M P.18 P.19 19-B	E32-C42S 1M	P.20	P.21 21-E
E32-C91N 2M P.08 P.09 (9-B) P.96 P.97 (97-F) E32-D E32-D11 2M P.42 P.43 (43-E) E32-D11R 2M P.08 P.09 (90-6) E32-D11U 2M P.38 P.39 (39-H) E32-D15XR 2M P.14 P.15 (15-E) E32-D15XR 2M P.14 P.15 (15-F) E32-D15ZR 2M P.14 P.15 (15-F) E32-D16 2M P.24 P.25 (25-E) E32-D21 2M P.42 P.43 (43-B) E32-D21R 2M P.08 P.09 (90-F) E32-D21B 2M P.42 P.43 (33-D) E32-D21R 2M P.08 P.09 (90-F) E32-D21R 2M P.08 P.09 (90-F) E32-D21R 2M P.18 P.19 (15-F) E32-D22B 2M P.12 P.13 (13-D) E32-D22B 2M P.12 P.13 (13-D) E32-D22B 2M P.12 P.13 (13-D) E32-D22R 2M P.12 P.13 (13-C) E32-D22R 2M P.18 P.19 (10-A) E32-D24R 2M P.18 P.19 (10-A) E32-D25-S3 2M P.18 P.19 (10-A) E32-D31-S1 0.5M P.18 P.19 (10-A) E32-D31-S1 0.5M P.18 P.19 (10-A) E32-D32-S1 0.5M P.18 P.19 (10-A) E32-D33-S1 0.5M P.18 P.19 (10-A)	E32-CC200 2M	P.08	P.09 (09-H)
B32-D11 2M P.42 P.43 43-E B32-D11 2M P.38 P.39 39-I B32-D11U 2M P.38 P.39 39-I B32-D15XR 2M P.14 P.15 15-E B32-D15YR 2M P.14 P.15 15-E B32-D15ZR 2M P.14 P.15 15-E B32-D18 2M P.42 P.43 43-B B32-D21R 2M P.98 P.99 (99-F B32-D21B 2M P.99 (99-F B32-D21R 2M P.99 (99-F B32-D21R 2M P.99 (99-F B32-D21R 2M P.18 P.19 15-B B32-D22B 2M P.12 P.13 13-D P.42 P.43 43-A B32-D22B 2M P.12 P.13 13-C B32-D22R 2M P.12 P.13 13-C B32-D24R 2M P.18 P.19 (99-I B32-D25-S3 2M P.18 P.19 (19-I B32-D25-S3 2M P.18 P.19 (19-I B32-D31-S1 0.5M P.18 P.19 (19-I B32-D31-S1 0.5M P.18 P.19 (19-I B32-D32-S1 0.5M P.18 P.19 (19-I B32-D33-S1 0.5M P.18 P.19 (19-I B32-D33-S		(P.22)	(P.23)
E32-D1 2M P.42 P.43 (3-E) E32-D11R 2M P.38 P.39 (39-I) E32-D15F 2M P.38 P.39 (39-I) E32-D15YR 2M P.14 P.15 (15-E) E32-D15YR 2M P.14 P.15 (15-E) E32-D15ZR 2M P.14 P.15 (15-E) E32-D15ZR 2M P.14 P.15 (15-E) E32-D16 2M P.24 P.25 (25-E) E32-D21 2M P.42 P.43 (43-B) E32-D21 1R 2M P.08 P.09 (19-F) E32-D21 R 2M P.42 P.43 (43-B) E32-D21R 2M P.45 P.47 (43-B) E32-D21R 2M P.46 P.47 (43-B) E32-D21R 2M P.47 P.48 P.49 (13-B) E32-D21R 2M P.48 P.49 (13-B) E32-D21R 2M P.18 P.19 (19-B) E32-D22R 2M P.12 P.13 (13-B) E32-D22R 2M P.12 P.13 (13-B) E32-D24R 2M P.18 P.19 (19-B) E32-D24R 2M P.18 P.19 (19-B) E32-D25-S3 2M P.18 P.19 (19-B) E32-D25-S3 2M P.18 P.19 (19-B) E32-D31-S1 0.5M P.18 P.19 (19-B) E32-D31-S1 0.5M P.18 P.19 (19-B) E32-D32-S1 0.5M P.18 P.19 (19-B) E32-D32-S1 0.5M P.18 P.19 (19-B) E32-D32-S1 0.5M P.18 P.19 (19-F) E32-D32-S1 0.5M P.18 P.19 (19-F) E32-D33-S1 0.5M P.18 P.19 (19-F)	E32-C91N 2M	P.08	P.09 09-B
E32-D11 2M P.42 P.43 (3-E) E32-D11R 2M P.08 P.09 (00-G) E32-D11U 2M P.38 P.39 (30-H) E32-D15XR 2M P.14 P.15 (15-E) E32-D15YR 2M P.14 P.15 (15-E) E32-D15ZR 2M P.14 P.15 (15-E) E32-D16 2M P.24 P.25 (25-E) E32-D16 2M P.24 P.25 (25-E) E32-D21 2M P.42 P.43 (43-B) E32-D21 1R 2M P.08 P.09 (00-F) E32-D21 1R 2M P.08 P.09 (00-F) E32-D21R 2M P.42 P.43 (43-D) E32-D21R 2M P.08 P.09 (00-F) E32-D21R 2M P.08 P.09 (00-F) E32-D21R 2M P.18 P.19 (10-F) E32-D22R 2M P.12 P.13 (13-F) E32-D22R 2M P.12 P.13 (13-F) E32-D22R 2M P.18 P.19 (10-F) E32-D25-S3 2M P.18 P.19 (10-F) E32-D32-S1 0.5M P.18 P.19 (10-F) E32-D33 2M P.12 P.13 (13-F)		P.96	P.97 97-F
E32-D11R 2M P.08 P.09 (9-6) E32-D11U 2M P.38 P.39 39-1 E32-D15XR 2M P.14 P.15 (15-6) E32-D15YR 2M P.14 P.15 (15-6) E32-D15ZR 2M P.14 P.15 (15-6) E32-D15ZR 2M P.14 P.15 (15-6) E32-D16 2M P.24 P.25 (25-6) E32-D21 2M P.42 P.43 (43-8) E32-D211R 2M P.08 P.09 (9-6) E32-D21R 2M P.08 P.09 (9-6) E32-D21R 2M P.08 P.09 (9-6) E32-D21R 2M P.18 P.19 (15-6) E32-D21R 2M P.18 P.19 (15-6) E32-D22R 2M P.12 P.13 (13-6) E32-D22R 2M P.12 P.13 (13-6) E32-D22R 2M P.12 P.13 (13-6) E32-D22R 2M P.13 P.19 (15-6) E32-D24R 2M P.18 P.19 (15-6) E32-D24R 2M P.18 P.19 (15-6) E32-D25XB 2M P.18 P.19 (15-6) E32-D25XB 2M P.18 P.19 (15-6) E32-D31-S1 0.5M P.18 P.19 (15-6) E32-D31-S1 0.5M P.18 P.19 (15-6) E32-D32-S1 0.5M P.18 P.19 (15-6) E32-D33 2M P.12 P.13 (13-6)	E32-D		
E32-D11U 2M P.38 P.39 39-H E32-D12F 2M P.38 P.39 39-H E32-D15XR 2M P.14 P.15 16-E E32-D15YR 2M P.14 P.15 16-F E32-D15ZR 2M P.14 P.15 16-G E32-D16 2M P.24 P.25 25-E E32-D21 2M P.42 P.43 43-B E32-D211R 2M P.08 P.09 69-F E32-D21B 2M P.42 P.43 43-D E32-D21R 2M P.08 P.09 69-F E32-D21R 2M P.08 P.09 69-C E32-D21R 2M P.08 P.09 69-C E32-D21R 2M P.18 P.19 36-G E32-D22B 2M P.12 P.13 13-D P.42 P.43 43-C E32-D22B 2M P.12 P.13 13-C E32-D22B 2M P.12 P.13 13-C E32-D22R 2M P.18 P.19 19-A E32-D24R 2M P.18 P.19 19-A E32-D24R 2M P.18 P.19 19-A E32-D25XB 2M P.18 P.19 19-B E32-D25XB 2M P.18 P.19 19-B E32-D31-S1 0.5M P.18 P.19 19-C E32-D31-S1 0.5M P.18 P.19 19-C E32-D32-S1 0.5M P.18 P.19 19-F E32-D33-S1 0.5M P.18 P.19 19-F	E32-D11 2M	P.42	$-\sim$
E32-D12F 2M P.38 P.39 39-H E32-D15XR 2M P.14 P.15 15-E E32-D15YR 2M P.14 P.15 16-F E32-D15ZR 2M P.14 P.15 16-F E32-D15ZR 2M P.14 P.15 16-F E32-D16 2M P.24 P.25 25-E E32-D21 2M P.42 P.43 43-B E32-D211R 2M P.08 P.09 09-F E32-D21B 2M P.42 P.43 43-D E32-D21R 2M P.08 P.09 09-F E32-D21R 2M P.08 P.09 09-C E32-D21R 2M P.08 P.09 09-C E32-D21R 2M P.18 P.19 35-B E32-D22B 2M P.12 P.13 13-D P.42 P.43 43-A E32-D22B 2M P.12 P.13 13-C E32-D22B 2M P.12 P.13 13-C E32-D22R 2M P.18 P.19 19-A E32-D24R 2M P.18 P.19 19-A E32-D25-S3 2M P.18 P.19 19-B E32-D25-S3 2M P.18 P.19 19-B E32-D31-S1 0.5M P.18 P.19 19-B E32-D31-S1 0.5M P.18 P.19 19-B E32-D32-S1 0.5M P.18 P.19 19-F E32-D33 2M P.12 P.13 13-F		P.08	P.09 09-G
E32-D15XR 2M P.14 P.15 15-E E32-D15YR 2M P.14 P.15 15-F E32-D15ZR 2M P.14 P.15 15-F E32-D16 2M P.24 P.25 25-E E32-D21 2M P.42 P.43 43-B E32-D211R 2M P.08 P.09 (99-F E32-D21B 2M P.42 P.43 (33-D E32-D21R 2M P.08 P.09 (99-F E32-D21R 2M P.12 P.13 (13-D E32-D21R 2M P.12 P.13 (13-D E32-D22B 2M P.12 P.13 (13-D E32-D22B 2M P.12 P.13 (13-D E32-D22R 2M P.12 P.13 (13-C E32-D22R 2M P.12 P.13 (13-C E32-D24R 2M P.18 P.19 (19-A E32-D24R 2M P.18 P.19 (19-A E32-D25XB 2M P.18 P.19 (19-B E32-D35XB 2M P.18 P.19 (19-B E32-D31-S1 0.5M P.18 P.19 (19-B E32-D31-S1 0.5M P.18 P.19 (19-B E32-D32-S1 0.5M P.18 P.19 (19-F) E32-D33 2M P.12 P.13 (13-F) E32-D33 2M P.12 P.13 (13-F)			$-\sim$
E32-D15YR 2M P.14 P.15 15-F E32-D15ZR 2M P.14 P.15 15-G E32-D16 2M P.24 P.25 25-F E32-D21 2M P.42 P.43 43-B E32-D211R 2M P.08 P.09 (99-F E32-D21B 2M P.42 P.43 (33-D E32-D21R 2M P.08 P.09 (99-F E32-D21R 2M P.12 P.13 (13-D E32-D22B 2M P.12 P.13 (13-D E32-D22B 2M P.12 P.13 (13-D E32-D22R 2M P.12 P.13 (13-D E32-D22R 2M P.12 P.13 (13-C E32-D22R 2M P.12 P.13 (13-C E32-D24R 2M P.18 P.19 (19-A E32-D24R 2M P.18 P.19 (19-A E32-D25XB 2M P.18 P.19 (19-B E32-D25-S3 2M P.18 P.19 (19-B E32-D31-S1 0.5M P.18 P.19 (19-B E32-D32-S1 0.5M P.18 P.19 (19-F) E32-D33 2M P.12 P.13 (13-F) E32-D33 2M P.12 P.13 (13-F)			$-\sim$
E32-D15ZR 2M P.14 P.15 15-6 E32-D16 2M P.24 P.25 25-E E32-D21 2M P.42 P.43 43-B E32-D211R 2M P.08 P.09 09-F E32-D21B 2M P.42 P.43 43-D E32-D21R 2M P.08 P.09 09-C E32-D21R 2M P.08 P.09 09-C E32-D21R 2M P.08 P.09 09-C E32-D21B 2M P.18 P.19 15-B E32-D22B 2M P.12 P.13 13-A P.42 P.43 43-A E32-D22B 2M P.12 P.13 13-C E32-D22R 2M P.12 P.13 13-C E32-D22R 2M P.12 P.13 13-C E32-D22R 2M P.18 P.19 19-A E32-D24-S2 2M P.18 P.19 19-A E32-D25-S3 2M P.18 P.19 19-A E32-D25-S3 2M P.18 P.19 19-B E32-D31-S1 0.5M P.18 P.19 19-B E32-D31-S1 0.5M P.18 P.19 19-G E32-D32-S1 0.5M P.18 P.19 19-G E32-D33 2M P.12 P.13 13-F			$-\sim$
E32-D16 2M P.24 P.25 25-E E32-D21 2M P.42 P.43 (43-B) E32-D211R 2M P.08 P.09 (99-F) E32-D21B 2M P.42 P.43 (43-D) E32-D21N 2M P.96 P.97 (97-E) E32-D21R 2M P.08 P.09 (69-C) E32-D21-S3 2M P.18 P.19 (15-D) E32-D221B 2M P.12 P.13 (13-D) P.42 P.43 (43-C) E32-D22B 2M P.12 P.13 (13-C) E32-D22R 2M P.12 P.13 (13-C) E32-D22R 2M P.12 P.13 (13-C) E32-D22R 2M P.12 P.13 (13-C) E32-D24R 2M P.18 P.19 (19-A) E32-D24R 2M P.18 P.19 (19-A) E32-D25-S3 2M P.18 P.19 (19-A) E32-D25-S3 2M P.18 P.19 (19-A) E32-D31-S1 0.5M P.18 P.19 (19-A) E32-D31-S1 0.5M P.18 P.19 (19-A) E32-D32-S1 0.5M P.18 P.19 (19-A) E32-D33-S1 0.5M P.18 P.19 (19-F)			-
E32-D21 2M P.42 P.43 (43-B) E32-D211R 2M P.08 P.09 (90-F) E32-D21B 2M P.42 P.43 (43-D) E32-D21R 2M P.08 P.09 (90-C) E32-D21R 2M P.08 P.09 (90-C) E32-D21-S3 2M P.18 P.19 (10-C) E32-D22B 2M P.12 P.13 (13-D) P.42 P.43 (43-C) E32-D22B 2M P.12 P.13 (13-A) E32-D22B 2M P.12 P.13 (13-A) E32-D22R 2M P.12 P.13 (13-C) E32-D22R 2M P.12 P.13 (13-C) E32-D24-S2 2M P.18 P.19 (10-B) E32-D25-S3 2M P.18 P.19 (10-B) E32-D31-S1 0.5M P.18 P.19 (10-G) E32-D32-S1 0.5M P.18 P.19 (10-G) E32-D33 2M P.18 P.19 (10-G) E32-D33 2M P.18 P.19 (10-G) E32-D33 2M P.18 P.19 (10-G)			$\overline{}$
E32-D211R 2M P.08 P.09 09-F E32-D21B 2M P.42 P.43 43-D E32-D21R 2M P.08 P.09 09-C E32-D21-S3 2M P.18 P.19 09-C E32-D21B 2M P.42 P.43 43-C E32-D22B 2M P.12 P.13 13-D P.42 P.43 43-C E32-D22B 2M P.12 P.13 13-D P.42 P.43 43-C E32-D22R 2M P.12 P.13 13-C E32-D22R 2M P.12 P.13 13-C E32-D22R 2M P.18 P.19 19-D E32-D24R 2M P.18 P.19 19-D E32-D25-S3 2M P.18 P.19 19-D E32-D31-S1 0.5M P.18 P.19 19-D E32-D31-S1 0.5M P.18 P.19 19-D E32-D32-S1 0.5M P.18 P.19 19-D E32-D33-S1 0.5M P.18 P.19 19-D			$\overline{}$
E32-D21B 2M P.42 P.43 43-D E32-D21R 2M P.96 P.97 97-E E32-D21R 2M P.08 P.09 69-C E32-D21-S3 2M P.18 P.19 69-C E32-D22B 2M P.12 P.13 13-D P.42 P.43 43-C E32-D22B 2M P.12 P.13 13-A P.42 P.43 43-A E32-D22R 2M P.12 P.13 13-C E32-D22R 2M P.12 P.13 13-C E32-D22-S1 2M P.18 P.19 19-A E32-D24R 2M P.18 P.19 19-A E32-D25-S3 2M P.18 P.19 19-B E32-D25-S3 2M P.18 P.19 19-L E32-D31-S1 0.5M P.18 P.19 19-L E32-D31-S1 0.5M P.18 P.19 19-L E32-D32-S1 0.5M P.18 P.19 19-F E32-D33 2M P.18 P.19 19-F E32-D33 2M P.18 P.19 19-F E32-D33 2M P.18 P.19 19-F			
E32-D21N 2M P.96 P.97 87-E E32-D21R 2M P.08 P.09 69-C E32-D21-S3 2M P.18 P.19 69-C E32-D221B 2M P.12 P.13 13-D P.42 P.43 43-C E32-D22B 2M P.12 P.13 13-A P.42 P.43 43-A E32-D22R 2M P.12 P.13 13-C E32-D22R 2M P.12 P.13 13-C E32-D22R 2M P.18 P.19 19-A E32-D24R 2M P.18 P.19 19-A E32-D24-S2 2M P.18 P.19 19-B E32-D25-S3 2M P.18 P.19 19-B E32-D31-S1 0.5M P.18 P.19 19-C E32-D31-S1 0.5M P.18 P.19 19-C E32-D32-S1 0.5M P.18 P.19 19-C E32-D33-S1 0.5M P.18 P.19 19-F			$-\sim$
E32-D21R 2M P.08 P.09 (9-C) E32-D21-S3 2M P.18 P.19 (15-B) E32-D22B 2M P.12 P.13 (13-D) P.42 P.43 (43-A) P.42 P.43 (43-A) E32-D22B 2M P.12 P.13 (13-A) P.42 P.43 (43-A) E32-D22R 2M P.12 P.13 (13-C) E32-D22-S1 2M P.18 P.19 (19-A) E32-D24R 2M P.18 P.19 (19-A) E32-D25-S3 2M P.18 P.19 (19-B) E32-D25-S3 2M P.18 P.19 (19-B) E32-D31-S1 0.5M P.18 P.19 (19-G) E32-D32-S1 0.5M P.18 P.19 (19-G) E32-D32-S1 0.5M P.18 P.19 (19-G) E32-D32-S1 0.5M P.18 P.19 (19-F) E32-D33 2M P.12 P.13 (13-F) E32-D33 2M P.12 P.13 (13-F)			$- \sim$
E32-D221B 2M P.12 P.13 (3-D) P.42 P.43 (43-A) P.44 P.45 P.45 P.45 P.45 P.45 P.45 P.45			
E32-D221B 2M P.12 P.13 (13-D) P.42 P.43 (43-C) P.42 P.43 (43-A) P.44 P.45 P.45 P.45 P.45 P.45 P.45 P.45			\rightarrow
P.42 P.43 43-6 E32-D22B 2M P.12 P.13 13-A P.42 P.43 43-A 13-A 13-A E32-D22R 2M P.12 P.13 13-C			$-\sim$
E32-D22B 2M P.12 P.13 (3-A) P.42 P.43 (43-A) P.42 P.43 (43-A) P.42 P.13 (13-C) P.12 P.13 (13-C) P.12 P.13 (13-C) P.14 P.15 P.19 (19-A) P.18 P.19 (19-B) P.19 P.19 P.19 P.19 P.19 P.19 P.19 P.19			
P.42 P.43 48-A E32-D22R 2M P.12 P.13 13-C E32-D22-S1 2M P.18 P.19 19-I E32-D24R 2M P.18 P.19 19-A E32-D24-S2 2M P.18 P.19 19-B E32-D25XB 2M P.42 P.43 43-F E32-D25-S3 2M P.18 P.19 19-L E32-D31-S1 0.5M P.18 P.19 19-G E32-D32L 2M P.12 P.13 13-F E32-D33 2M P.12 P.13 13-F	E32-D22B 2M		$-\sim$
E32-D22R 2M P.12 P.13 13-C E32-D22-S1 2M P.18 P.19 19-I E32-D24R 2M P.18 P.19 19-I E32-D24-S2 2M P.18 P.19 19-B E32-D25-S3 2M P.42 P.43 43-F E32-D31-S1 0.5M P.18 P.19 19-I E32-D32-L 2M P.12 P.13 13-E E32-D32-S1 0.5M P.18 P.19 19-F E32-D33 2M P.12 P.13 13-F			
E32-D24R 2M P.18 P.19 (19-A) E32-D24-S2 2M P.18 P.19 (19-B) E32-D25XB 2M P.42 P.43 (43-F) E32-D25-S3 2M P.18 P.19 (19-A) E32-D31-S1 0.5M P.18 P.19 (19-A) E32-D32L 2M P.12 P.13 (13-E) E32-D32-S1 0.5M P.18 P.19 (19-F) E32-D33 2M P.12 P.13 (13-F)	E32-D22R 2M		-
E32-D24-S2 2M P.18 P.19 19-B E32-D25XB 2M P.42 P.43 (43-F) E32-D25-S3 2M P.18 P.19 19-L E32-D31-S1 0.5M P.18 P.19 19-G E32-D32L 2M P.12 P.13 13-E) E32-D32-S1 0.5M P.18 P.19 19-F) E32-D33 2M P.12 P.13 13-F)	E32-D22-S1 2M	P.18	P.19 19-I
E32-D25XB 2M P.42 P.43 (43-F) E32-D25-S3 2M P.18 P.19 (19-L) E32-D31-S1 0.5M P.18 P.19 (19-G) E32-D32L 2M P.12 P.13 (13-E) E32-D32-S1 0.5M P.18 P.19 (19-F) E32-D33 2M P.12 P.13 (13-F)	E32-D24R 2M	P.18	-
E32-D25-S3 2M P.18 P.19 19-L E32-D31-S1 0.5M P.18 P.19 10-G E32-D32L 2M P.12 P.13 13-E E32-D32-S1 0.5M P.18 P.19 19-F E32-D33 2M P.12 P.13 13-F	E32-D24-S2 2M	P.18	P.19 19-B
E32-D31-S1 0.5M P.18 P.19 19-6 E32-D32L 2M P.12 P.13 13-E E32-D32-S1 0.5M P.18 P.19 19-F E32-D33 2M P.12 P.13 13-F	E32-D25XB 2M	P.42	P.43 43-F
E32-D32L 2M P.12 P.13 13-E E32-D32-S1 0.5M P.18 P.19 19-F E32-D33 2M P.12 P.13 13-F	E32-D25-S3 2M	P.18	P.19 19-L
E32-D32-S1 0.5M P.18 P.19 19-F E32-D33 2M P.12 P.13 13-F	E32-D31-S1 0.5M	P.18	P.19 19-G
E32-D33 2M P.12 P.13 13-F	E32-D32L 2M	P.12	P.13 13-E
			$-\sim$
P.18 P.19 19-E	E32-D33 2M		
		P.18	P.19 (19-E)

Models	Specifica- tions	Dimensions
E32-D331 2M	P.18	P.19 (19-D)
E32-D36P1 2M	P.48	P.49 49-E)
E32-D36T 2M	P.50	P.51 51-C
E32-D43M 1M	P.12	P.13 (13-B)
E32-D43W TW		
	P.18	P.19 (19-C)
E32-D51 2M	P.46	P.47 (47-B)
E32-D51R 2M	P.46	P.47 (47-A)
E32-D61-S 2M	P.46	P.47 47-G
E32-D611-S 2M	P.46	P.47 47-F
E32-D73-S 2M	P.46	P.47 47-H
E32-D81R-S 2M	P.46	P.47 47-C
E32-D82F1 4M	P.50	P.51 (51-D)
E32-DC200BR 2M	P.18	P.19 (19-K)
E32-DC200F4R 2M	P.18	P.19 (19-H)
E32-G	1110	1110 (11)
	D 40	D 40 (49-D)
E32-G16 2M	P.48	P.49 49-D
E32-L	B 4 4	Doc 65
E32-L11FP 2M	P.38	P.39 39-F
	P.54	P.55 55-G
E32-L11FS 2M	P.38	P.39 39-G
	P.54	P.55 55-H
E32-L15 2M	P.20	P.21 21-F
E32-L16-N 2M	P.32	P.33 33-A
	P.36	P.37 (37-B)
	P.54	P.55 55-A
E32-L24S 2M	P.32	P.33 (33-B)
202 22 10 2111	P.36	P.37 (37-A)
E32-L25L 2M	P.32	P.33 33-C
LOZ-LZOL ZIVI		
	P.36	P.37 (37-E)
E32-L25T 2M	P.50	P.51 (51-B)
E32-LD11 2M	P.08	P.09 (09-I)
E32-LD11N 2M	P.96	P.97 97-C
E32-LD11R 2M	P.08	P.09 09-I
E32-LR11NP 2M	P.34	P.35 35-A
	P.96	P.97 97-G
E32-LT11 2M	P.06	P.07 07-C
	P.24	P.25 25-C
E32-LT11N 2M	P.24	P.25 25-A
	P.96	P.97 97-A
E32-LT11R 2M	P.06	P.07 07-C
	P.24	P.25 25-C
E32-LT35Z 2M	P.14	P.15 (15-D)
E32-R		
E32-R16 2M	P.34	P.35 35-B)
E32-R21 2M	P.34	P.35 35-C
	F.34	P.33 (30-0)
E32-T	D.55	D.F.C. (50.5)
E32-T10V 2M	P.52	P.53 53-D
E32-T11 2M	P.40	P.41 41-C
	(P.26)	(P.27)
E32-T11F 2M	P.38	P.39 39-C
E32-T11N 2M	P.06	P.07 07-A
	(P.26)	(P.27)
E32-T11NF 2M	P.38	P.39 39-A
E32-T11R 2M	P.06	P.07 07-B
	(P.24)	(P.25, 26)
E32-T12F 2M	P.38	P.39 39-B
E32-T12R 2M	P.10	P.11 (11-C)
E32-T14 2M	P.24	P.25 25-D
E32-T14F 2M	P.38	P.39 39-D
E32-T14LR 2M	P.10	P.11 (11-D)
E32-T15XR 2M	P.14	P.15 (15-A)
E32-T15YR 2M	P.14	P.15 (15-B)
		P.15 (15-C)
E32-T15ZR 2M	P.14	=
E32-T16JR 2M	P.48	P.49 49-B

Models	Specifica- tions	Dimensions
E32-T16PR 2M	P.48	P.49 49-A
E32-T16WR 2M	P.48	P.49 49-C
E32-T17L 10M	P.24	P.25 25-B
E32-T21 2M	P.40	P.41 41-B
E32-T21-S1 2M	P.16	P.17 17-D
E32-T223R 2M	P.10	P.11 11-A
E32-T22B 2M	P.10	P.11 (11-B)
	P.40	P.41 41-A
E32-T22S 2M	P.30	P.31 31-F
E32-T24E 2M	P.16	P.17 (17-B)
E32-T24R 2M	P.16	P.17 17-A
E32-T24S 2M	P.30	P.31 31-E
	P.56	P.57 57-E
E32-T24SR 2M	P.30	P.31 31-D
	P.56	P.57 57-D
E32-T25XB 2M	P.40	P.41 (41-D)
E32-T33 1M	P.16	P.17 (17-C)
E32-T51 2M	P.44 (P.28)	P.45 45-B (P.29)
E32-T51F 2M	P.38	P.39 39-E
E32-T51R 2M	P.44 (P.28)	P.45 45-A (P.29)
E32-T51V 1M	P.52	P.53 53-A
E32-T61-S 2M) (
	P.44 (P.28)	P.45 (45-D) (P.29)
E32-T81R-S 2M	P.44 (P.28)	P.45 45-C (P.29)
E32-T84SV 1M	P.52	P.53 53-C
E32-TC200BR 2M	P.16	P.17 17-E
E32-V		
E32-VF1	P.52	P.53 53- F
E32-VF4	P.52 P.52	P.53 53-F P.53 53-E
		\sim
E32-VF4 E39-F E39-F1	P.52 P.26, 28	P.53 53-E P.26 26-A
E32-VF4 E39-F E39-F1 E39-F1-33	P.52 P.26, 28 P.28	P.53 53-E
E32-VF4 E39-F E39-F1 E39-F1-33 E39-F11	P.52 P.26, 28 P.28 P.17	P.53 63-E P.26 26-A P.28 28-D
E32-VF4 E39-F E39-F1 E39-F1-33 E39-F11 E39-F16	P.52 P.26, 28 P.28 P.17 P.26, 28	P.53 63-E P.26 26-A P.28 28-D P.26 26-B
E32-VF4 E39-F E39-F1 E39-F1-33 E39-F11 E39-F16 E39-F17	P.52 P.26, 28 P.28 P.17 P.26, 28 P.20	P.26 26-A P.28 28-D P.26 26-B P.21 21-B
E32-VF4 E39-F E39-F1 E39-F1-33 E39-F11 E39-F16	P.52 P.26, 28 P.28 P.17 P.26, 28	P.53 68-E P.26 28-A P.28 28-D P.26 28-B P.21 21-B P.23 23-G
E32-VF4 E39-F E39-F1 E39-F1-33 E39-F11 E39-F16 E39-F17	P.52 P.26, 28 P.28 P.17 P.26, 28 P.20	P.53 (83-E) P.26 (28-A) P.28 (28-D) P.26 (28-B) P.21 (21-B) P.23 (23-6) (23-H)
E39-F1 E39-F1 E39-F1-33 E39-F11 E39-F16 E39-F17 E39-F18	P.52 P.26, 28 P.28 P.17 P.26, 28 P.20 P.22	P.53 (83-E) P.26 (26-A) P.28 (28-D) P.26 (26-B) P.21 (21-B) P.23 (23-G) (23-H) P.53 (83-B)
E32-VF4 E39-F E39-F1 E39-F1-33 E39-F11 E39-F16 E39-F17 E39-F18	P.52 P.26, 28 P.28 P.17 P.26, 28 P.20 P.22	P.53 (88-A) P.26 (28-A) P.28 (28-D) P.26 (28-B) P.21 (21-B) P.23 (23-G) P.53 (83-B) P.26 (28-C)
E32-VF4 E39-F E39-F1 E39-F1-33 E39-F11 E39-F16 E39-F17 E39-F18 E39-F1V E39-F2	P.52 P.26, 28 P.17 P.26, 28 P.20 P.22 P.52 P.52	P.53 (88-A) P.26 (28-A) P.28 (28-D) P.26 (28-B) P.21 (21-B) P.23 (23-G) P.53 (83-B) P.26 (28-C)
E32-VF4 E39-F E39-F1 E39-F1-33 E39-F11 E39-F16 E39-F17 E39-F18 E39-F1V E39-F2 E39-F32A 1M	P.52 P.26, 28 P.17 P.26, 28 P.20 P.22 P.52 P.42	P.53 (83-E) P.26 (26-A) P.28 (28-D) P.26 (26-B) P.21 (21-B) P.23 (23-G) P.53 (83-B) P.26 (26-C) P.43 (43-G)
E32-VF4 E39-F E39-F1 E39-F1-33 E39-F11 E39-F16 E39-F17 E39-F18 E39-F1V E39-F2 E39-F32A 1M	P.52 P.26, 28 P.27 P.26, 28 P.20 P.22 P.52 P.42 P.40	P.53 (38-E) P.26 (28-A) P.28 (28-D) P.26 (28-B) P.21 (21-B) P.23 (23-G) P.53 (38-B) P.26 (28-C) P.43 (43-G) P.41 (41-E)
E32-VF4 E39-F E39-F1 E39-F1-33 E39-F11 E39-F16 E39-F17 E39-F18 E39-F1V E39-F2 E39-F32A 1M E39-F32C 1M	P.52 P.26, 28 P.27 P.26, 28 P.17 P.26, 28 P.20 P.22 P.52 P.42 P.40 P.42	P.26 28-A P.28 28-D P.26 28-B P.21 21-B P.23 23-0 23-H P.53 63-B P.26 28-C P.43 43-0 P.41 41-B P.43 43-0
E32-VF4 E39-F E39-F1 E39-F1-33 E39-F11 E39-F16 E39-F17 E39-F18 E39-F1V E39-F2 E39-F32A 1M E39-F32C 1M	P.52 P.26, 28 P.27 P.26, 28 P.17 P.26, 28 P.20 P.22 P.52 P.42 P.42 P.42 P.42	P.26 & B P.26 & B P.26 & B P.21 & B P.21 & B P.23 & B P.23 & B P.24 & B P.24 & B P.25 & B P.26 & B P.26 & B P.27 & B P.28 & B P.29 & B P.21 & B P.22 & B P.22 & B P.23 & B P.24 & B P.25 & B P.26 & B P.27 & B P.28 & B P.29 & B P.29 & B P.20 & B P.2
E32-VF4 E39-F E39-F1 E39-F1-33 E39-F11 E39-F16 E39-F17 E39-F18 E39-F1V E39-F2 E39-F32A 1M E39-F32C 1M	P.52 P.26, 28 P.17 P.26, 28 P.20 P.22 P.52 P.42 P.40 P.42 P.42 P.20	P.53 (83-B) P.26 (28-B) P.26 (28-B) P.21 (21-B) P.23 (23-4) P.53 (83-B) P.26 (28-C) P.43 (43-G) P.41 (41-E) P.43 (43-G) P.44 (43-G) P.45 (
E32-VF4 E39-F E39-F1 E39-F1-33 E39-F11 E39-F16 E39-F17 E39-F18 E39-F1V E39-F2 E39-F32A 1M E39-F32C 1M E39-F32D 1M E39-F3A E39-F3A-5	P.52 P.26, 28 P.17 P.26, 28 P.20 P.22 P.52 P.42 P.40 P.42 P.42 P.20 P.22	P.26 28-A P.28 28-D P.26 28-B P.21 21-B P.23 23-G 23-H P.53 83-B P.26 28-C P.43 43-G P.41 41-E P.43 43-G P.43 43-G P.43 43-G P.43 43-G P.21 21-A P.23 23-A 23-B 23-C
E32-VF4 E39-F E39-F1 E39-F1-33 E39-F11 E39-F16 E39-F17 E39-F18 E39-F1V E39-F2 E39-F32A 1M E39-F32C 1M	P.52 P.26, 28 P.17 P.26, 28 P.20 P.22 P.52 P.42 P.40 P.42 P.42 P.20	P.53 (83-B) P.26 (28-B) P.26 (28-B) P.21 (21-B) P.23 (23-4) P.53 (83-B) P.26 (28-C) P.43 (43-G) P.41 (41-E) P.43 (43-G) P.44 (43-G) P.45 (
E32-VF4 E39-F E39-F1 E39-F1-33 E39-F11 E39-F16 E39-F17 E39-F18 E39-F1V E39-F2 E39-F32A 1M E39-F32C 1M E39-F32D 1M E39-F3A E39-F3A-5	P.52 P.26, 28 P.17 P.26, 28 P.20 P.22 P.52 P.42 P.40 P.42 P.42 P.20 P.22	P.53 (88-B) P.26 (88-B) P.26 (88-B) P.21 (21-B) P.23 (23-G) P.26 (88-G) P.43 (43-G) P.44 (41-E) P.45 (43-G) P.45 (
E32-VF4 E39-F E39-F1 E39-F1-33 E39-F11 E39-F16 E39-F17 E39-F18 E39-F1V E39-F2 E39-F32A 1M E39-F32C 1M E39-F32D 1M E39-F3A E39-F3A-5	P.52 P.26, 28 P.17 P.26, 28 P.20 P.22 P.52 P.42 P.40 P.42 P.42 P.20 P.22	P.26 & B P.21 & B P.26 & B P.27 & B P.28 & B P.28 & B P.29 & B P.2
E32-VF4 E39-F E39-F1 E39-F1-33 E39-F11 E39-F16 E39-F17 E39-F18 E39-F1V E39-F2 E39-F32A 1M E39-F32C 1M E39-F3A E39-F3A E39-F3A	P.52 P.26, 28 P.17 P.26, 28 P.20 P.22 P.52 P.42 P.40 P.42 P.42 P.20 P.22	P.53 (88-B) P.26 (88-B) P.26 (88-B) P.21 (21-B) P.23 (23-G) P.26 (88-G) P.43 (43-G) P.44 (41-E) P.45 (43-G) P.45 (
E32-VF4 E39-F E39-F1 E39-F1-33 E39-F11 E39-F16 E39-F17 E39-F18 E39-F1V E39-F2 E39-F32A 1M E39-F32C 1M E39-F32C 1M E39-F3A E39-F3A E39-F3A	P.52 P.26, 28 P.17 P.26, 28 P.20 P.22 P.52 P.42 P.40 P.42 P.42 P.20 P.22	P.53 (83-E) P.26 (28-A) P.28 (28-D) P.26 (28-B) P.21 (21-B) P.23 (23-B) P.26 (28-C) P.43 (43-G) P.41 (41-E) P.43 (43-G) P.44 (41-E) P.45 (43-G) P.46 (43-G) P.47 (41-E) P.48 (43-G) P.49 (
E32-VF4 E39-F E39-F1 E39-F1 E39-F16 E39-F17 E39-F18 E39-F1V E39-F2 E39-F32A 1M E39-F32C 1M E39-F3A E39-F3A E39-F3A E39-F3A	P.52 P.26, 28 P.17 P.26, 28 P.20 P.22 P.52 P.42 P.40 P.42 P.42 P.20 P.22	P.53 (83-E) P.26 (28-A) P.28 (28-D) P.26 (28-B) P.21 (21-B) P.23 (23-G) P.23 (23-G) P.43 (33-G) P.41 (41-E) P.43 (43-G) P.43 (43-G) P.43 (43-G) P.43 (43-G) P.43 (43-G) P.43 (23-E) (23-E) P.21 (21-G) P.25 (35-B) P.25 (35-B) P.26 (28-C) P.27 (21-C) P.28 (21-C) P.29 (21-C) P.35 (35-B)
E32-VF4 E39-F E39-F1 E39-F1-33 E39-F11 E39-F16 E39-F17 E39-F18 E39-F1V E39-F2 E39-F32A 1M E39-F32C 1M E39-F32C 1M E39-F3A E39-F3A E39-F3A	P.52 P.26, 28 P.17 P.26, 28 P.20 P.22 P.52 P.42 P.40 P.42 P.42 P.20 P.22 P.22 P.20 P.22	P.26 28-A P.28 28-D P.26 28-B P.21 21-B P.23 28-G P.23 28-G P.43 48-G P.43 48-G P.43 48-G P.43 48-G P.43 28-B P.21 21-A P.23 28-A P.21 21-A P.23 28-B P.21 21-C P.23 28-B P.21 21-C P.23 28-C P.23 2
E32-VF4 E39-F E39-F1 E39-F1 E39-F16 E39-F17 E39-F18 E39-F1V E39-F2 E39-F32A 1M E39-F32C 1M E39-F3A E39-F3A E39-F3A E39-F3A	P.52 P.26, 28 P.27 P.26, 28 P.20 P.22 P.52 P.26, 28 P.42 P.40 P.42 P.42 P.42 P.20 P.22 P.22 P.31 P.34	P.26 28-A P.28 28-D P.26 28-B P.21 21-B P.23 28-G P.23 28-G P.43 43-G P.41 41-E P.43 43-G P.43 43-G P.41 21-A P.23 28-A P.21 21-A P.23 28-B 28-C P.21 21-C P.23 28-B P.21 21-C P.23 28-B P.21 21-C P.23 38-B P.21 21-C P.23 38-B P.21 21-C P.23 38-B P.21 21-C P.23 38-B P.21 21-C P.35 38-B P.35 38-C P.35 38-B P.35 38-C P.35 38-B
E32-VF4 E39-F E39-F1 E39-F1 E39-F16 E39-F17 E39-F18 E39-F1V E39-F2 E39-F32A 1M E39-F32C 1M E39-F3A E39-F3A E39-F3A E39-F3B E39-F3B E39-F3C E39-R E39-R1 E39-R3 E39-R1	P.52 P.26, 28 P.17 P.26, 28 P.20 P.22 P.52 P.42 P.40 P.42 P.42 P.20 P.22 P.34 P.20 P.22	P.26 28-A P.28 28-D P.26 28-B P.21 21-B P.23 28-G P.23 28-G P.43 48-G P.43 48-G P.43 48-G P.43 48-G P.43 28-B P.21 21-A P.23 28-A P.21 21-A P.23 28-B P.21 21-C P.23 28-B P.21 21-C P.23 28-C P.23 2
E32-VF4 E39-F E39-F1 E39-F1 E39-F16 E39-F17 E39-F18 E39-F1V E39-F2 E39-F32A 1M E39-F32C 1M E39-F3A E39-F3A E39-F3A E39-F3A	P.52 P.26, 28 P.27 P.26, 28 P.20 P.22 P.52 P.26, 28 P.42 P.40 P.42 P.42 P.42 P.20 P.22 P.22 P.31 P.34	P.26 28-A P.28 28-D P.26 28-B P.21 21-B P.23 28-G P.23 28-G P.43 43-G P.41 41-E P.43 43-G P.43 43-G P.41 21-A P.23 28-A P.21 21-A P.23 28-B 28-C P.21 21-C P.23 28-B P.21 21-C P.23 28-B P.21 21-C P.23 38-B P.21 21-C P.23 38-B P.21 21-C P.23 38-B P.21 21-C P.23 38-B P.21 21-C P.35 38-B P.35 38-C P.35 38-B P.35 38-C P.35 38-B

Models	Specifica- tions	Dimensions
E39-L		
E39-L143		P.89 89-A
E3NW		
E3NW-DS	P.76	P.77 77-B
E3NW-ECT	P.76	P.77 77-A
E3NX-FA		
E3NX-FA0	P.66	P.69 69-B
E3NX-FA11 2M	P.66	P.68 68-A
E3NX-FA21 2M	P.66	P.68 68-A
E3NX-FA24	P.66	P.69 69-A
E3NX-FA41 2M	P.66	P.68 68-A
E3NX-FA51 2M	P.66	P.68 68-A
E3NX-FA54	P.66	P.69 69-A
E3NX-FA54TW	P.66	P.69 69-A
E3NX-FA6	P.66	P.68 68-B
E3NX-FA7	P.66	P.68 68-B
E3NX-FA7TW	P.66	P.68 68-B
E3NX-FA8	P.66	P.68 68-B
E3NX-FA9	P.66	P.68 68-B
E3NX-FA9TW	P.66	P.68 68-B
E3X-CN		
E3X-CN11	P.88	P.88 88-A
E3X-CN12	P.88	P.88 88-B
E3X-CN21	P.88	P.88 88-A
E3X-CN22	P.88	P.88 88-B
E3X-CRT		
E3X-CRT	P.86	P.87 87-A
E3X-ECT		
E3X-ECT	P.86	P.87 87-B
E3X-HD		
E3X-HD0	P.80	P.81 81-C
E3X-HD11 2M	P.80	P.80 80-A
E3X-HD14	P.80	P.81 81-B
E3X-HD41 2M	P.80	P.80 80-A
E3X-HD44	P.80	P.81 81-B
E3X-HD6	P.80	P.81 81-A
E3X-HD8	P.80	P.81 81-A
PFP		
PFP-100N	_	P.89 89-B
PFP-100N2		P.89 89-C
PFP-50N	_	P.89 89-B
PFP-M	_	P.89 89-D
XS3F		
XS3F-M421-402-A	P.88	P.88 88-C
XS3F-M421-405-A	P.88	P.88 88-C
XS3F-M422-402-A	P.88	P.88 88-D
XS3F-M422-405-A	P.88	P.88 88-D

Terms and Conditions Agreement

Read and understand this catalog.

Please read and understand this catalog before purchasing the products. Please consult your OMRON representative if you have any questions or comments.

Warranties.

- (a) Exclusive Warranty. Omron's exclusive warranty is that the Products will be free from defects in materials and workmanship for a period of twelve months from the date of sale by Omron (or such other period expressed in writing by Omron). Omron disclaims all other warranties, express or implied.
- (b) Limitations. OMRON MAKES NO WARRANTY OR REPRESENTATION, EXPRESS OR IMPLIED, ABOUT NON-INFRINGEMENT, MERCHANTABILITY OR FITNESS FOR A PARTICULAR PURPOSE OF THE PRODUCTS. BUYER ACKNOWLEDGES THAT IT ALONE HAS DETERMINED THAT THE PRODUCTS WILL SUITABLY MEET THE REQUIREMENTS OF THEIR INTENDED USE.

Omron further disclaims all warranties and responsibility of any type for claims or expenses based on infringement by the Products or otherwise of any intellectual property right. (c) Buyer Remedy. Omron's sole obligation hereunder shall be, at Omron's election, to (i) replace (in the form originally shipped with Buyer responsible for labor charges for removal or replacement thereof) the non-complying Product, (ii) repair the non-complying Product, or (iii) repay or credit Buyer an amount equal to the purchase price of the non-complying Product; provided that in no event shall Omron be responsible for warranty, repair, indemnity or any other claims or expenses regarding the Products unless Omron's analysis confirms that the Products were properly handled, stored, installed and maintained and not subject to contamination, abuse, misuse or inappropriate modification. Return of any Products by Buyer must be approved in writing by Omron before shipment. Omron Companies shall not be liable for the suitability or unsuitability or the results from the use of Products in combination with any electrical or electronic components, circuits, system assemblies or any other materials or substances or environments. Any advice, recommendations or information given orally or in writing, are not to be construed as an amendment or addition to the above warranty.

See http://www.omron.com/global/ or contact your Omron representative for published information.

Limitation on Liability; Etc.

OMRON COMPANIES SHALL NOT BE LIABLE FOR SPECIAL, INDIRECT, INCIDENTAL, OR CONSEQUENTIAL DAMAGES, LOSS OF PROFITS OR PRODUCTION OR COMMERCIAL LOSS IN ANY WAY CONNECTED WITH THE PRODUCTS, WHETHER SUCH CLAIM IS BASED IN CONTRACT, WARRANTY, NEGLIGENCE OR STRICT LIABILITY.

Further, in no event shall liability of Omron Companies exceed the individual price of the Product on which liability is asserted.

Suitability of Use.

Omron Companies shall not be responsible for conformity with any standards, codes or regulations which apply to the combination of the Product in the Buyer's application or use of the Product. At Buyer's request, Omron will provide applicable third party certification documents identifying ratings and limitations of use which apply to the Product. This information by itself is not sufficient for a complete determination of the suitability of the Product in combination with the end product, machine, system, or other application or use. Buyer shall be solely responsible for determining appropriateness of the particular Product with respect to Buyer's application, product or system. Buyer shall take application responsibility in all cases.

NEVER USE THE PRODUCT FOR AN APPLICATION INVOLVING SERIOUS RISK TO LIFE OR PROPERTY OR IN LARGE QUANTITIES WITHOUT ENSURING THAT THE SYSTEM AS A WHOLE HAS BEEN DESIGNED TO ADDRESS THE RISKS, AND THAT THE OMRON PRODUCT(S) IS PROPERLY RATED AND INSTALLED FOR THE INTENDED USE WITHIN THE OVERALL EQUIPMENT OR SYSTEM.

Programmable Products.

Omron Companies shall not be responsible for the user's programming of a programmable Product, or any consequence thereof.

Performance Data.

Data presented in Omron Company websites, catalogs and other materials is provided as a guide for the user in determining suitability and does not constitute a warranty. It may represent the result of Omron's test conditions, and the user must correlate it to actual application requirements. Actual performance is subject to the Omron's Warranty and Limitations of Liability.

Change in Specifications.

Product specifications and accessories may be changed at any time based on improvements and other reasons. It is our practice to change part numbers when published ratings or features are changed, or when significant construction changes are made. However, some specifications of the Product may be changed without any notice. When in doubt, special part numbers may be assigned to fix or establish key specifications for your application. Please consult with your Omron's representative at any time to confirm actual specifications of purchased Product.

Errors and Omissions.

Information presented by Omron Companies has been checked and is believed to be accurate; however, no responsibility is assumed for clerical, typographical or proofreading errors or omissions.





Oil resistant types E32-T11NF

→ 38 Page

Build-in Lens



Oil-resistant Fiber Unit E32-T11NF (http://www.ia.omron.com/)

Hex shaped models E32-C91N

→ 96 Page

Grooved types E32-G16

→ 48 Page



Color Mark Sensors E3S-DC/ E3NX-CA Series Cat. No. Y216



EtherCAT® is a registered trademark and patented technology, licensed by Beckhoff Automation GmbH, Germany. CompoNet is a registered trademark of the ODVA.

CC-Link is a registered trademark of Mitsubishi Electric Corporation. The trademark is managed by the CC-Link Partner Association.

OMRON Corporation Industrial Automation Company

Kyoto, JAPAN

Contact: www.ia.omron.com

Regional Headquarters OMRON EUROPE B.V. Sensor Business Unit

Carl-Benz-Str. 4, D-71154 Nufringen, Germany Tel: (49) 7032-811-0/Fax: (49) 7032-811-199

OMRON ASIA PACIFIC PTE. LTD.

No. 438A Alexandra Road # 05-05/08 (Lobby 2), Alexandra Technopark, Singapore 119967 Tel: (65) 6835-3011/Fax: (65) 6835-2711

OMRON ELECTRONICS LLC

2895 Greenspoint Parkway, Suite 200 Hoffman Estates, IL 60169 U.S.A. Tel: (1) 847-843-7900/Fax: (1) 847-843-7787

OMRON (CHINA) CO., LTD.

Room 2211, Bank of China Tower, 200 Yin Cheng Zhong Road, PuDong New Area, Shanghai, 200120, China Tel: (86) 21-5037-2222/Fax: (86) 21-5037-2200

Authorized Distributor:

© OMRON Corporation 2012-2016 All Rights Reserved. In the interest of product improvement, specifications are subject to change without notice.

CSM_16_1_0217 Cat. No. E418-E1-06

0816 (0212)