

# Freescale Touch

**Touch Sensing Software - Freescale Touch**

Document Number: FTUG  
1.0.0  
Apr 2015





# Contents

## Chapter 1 Introduction

## Chapter 2 Key Library Elements

<b>2.1</b>	<b>System</b>	<b>5</b>
<b>2.2</b>	<b>Modules</b>	<b>5</b>
2.2.1	Module Types	5
2.2.2	TSI details	5
<b>2.3</b>	<b>Key Detectors</b>	<b>7</b>
2.3.1	Types	7
<b>2.4</b>	<b>Controls</b>	<b>8</b>
<b>2.5</b>	<b>Electrodes</b>	<b>11</b>

## Chapter 3 Directory Structure

## Chapter 4 Configuring the Library

<b>4.1</b>	<b>Configuration Example</b>	<b>15</b>
4.1.1	Key Detectors	15
4.1.2	Electrodes	15
4.1.3	Modules	16
4.1.3.1	TSI module	16
4.1.4	Controls	16
4.1.4.1	Analog slider	16
4.1.4.2	Slider	17

Section number	Title	Page
4.1.4.3	Keypad . . . . .	17
4.1.4.4	Analog rotary . . . . .	17
4.1.4.5	Rotary . . . . .	18
4.1.5	System . . . . .	18

## **Chapter 5 Your First Application**

<b>5.1</b>	<b>Creating the Freescale Touch Application . . . . .</b>	<b>19</b>
5.1.1	Adding Library Files into the Project . . . . .	19
5.1.2	Setting 'include' Search Paths . . . . .	20
5.1.3	Setting 'linker' path . . . . .	22
5.1.4	Application Setup . . . . .	22
5.1.5	The main() Function . . . . .	25

## **Chapter 6 Release Notes**

## **Chapter 7 Freescale Touch User API**

<b>7.1</b>	<b>Overview . . . . .</b>	<b>33</b>
7.1.1	Analog Rotary Control . . . . .	34
7.1.1.1	Overview . . . . .	34
7.1.1.2	Data Structure Documentation . . . . .	35
7.1.1.2.1	struct ft_control_arotary . . . . .	35
7.1.1.3	Typedef Documentation . . . . .	36
7.1.1.3.1	ft_control_arotary_callback . . . . .	36
7.1.1.4	Enumeration Type Documentation . . . . .	36
7.1.1.4.1	ft_control_arotary_event . . . . .	36
7.1.1.5	Variable Documentation . . . . .	36
7.1.1.5.1	ft_control_arotary_interface . . . . .	36
7.1.1.6	Analog Rotary Control API . . . . .	37
7.1.1.6.1	Overview . . . . .	37
7.1.1.6.2	Function Documentation . . . . .	38
7.1.1.6.2.1	ft_control_arotary_get_direction . . . . .	38
7.1.1.6.2.2	ft_control_arotary_get_invalid_position . . . . .	39
7.1.1.6.2.3	ft_control_arotary_get_position . . . . .	40
7.1.1.6.2.4	ft_control_arotary_is_touched . . . . .	40
7.1.1.6.2.5	ft_control_arotary_movement_detected . . . . .	41

Section number	Title	Page
7.1.1.6.2.6	ft_control_arotary_register_callback . . . . .	42
7.1.2	Analog Slider Control . . . . .	44
7.1.2.1	Overview . . . . .	44
7.1.2.2	Data Structure Documentation . . . . .	45
7.1.2.2.1	struct ft_control_aslider . . . . .	45
7.1.2.3	Typedef Documentation . . . . .	46
7.1.2.3.1	ft_control_aslider_callback . . . . .	46
7.1.2.4	Enumeration Type Documentation . . . . .	46
7.1.2.4.1	ft_control_aslider_event . . . . .	46
7.1.2.5	Variable Documentation . . . . .	46
7.1.2.5.1	ft_control_aslider_interface . . . . .	46
7.1.2.6	Analog Slider Control API . . . . .	47
7.1.2.6.1	Overview . . . . .	47
7.1.2.6.2	Function Documentation . . . . .	48
7.1.2.6.2.1	ft_control_aslider_get_direction . . . . .	48
7.1.2.6.2.2	ft_control_aslider_get_invalid_position . . . . .	49
7.1.2.6.2.3	ft_control_aslider_get_position . . . . .	50
7.1.2.6.2.4	ft_control_aslider_is_touched . . . . .	50
7.1.2.6.2.5	ft_control_aslider_movement_detected . . . . .	51
7.1.2.6.2.6	ft_control_aslider_register_callback . . . . .	52
7.1.3	Keypad Control . . . . .	54
7.1.3.1	Overview . . . . .	54
7.1.3.2	Data Structure Documentation . . . . .	55
7.1.3.2.1	struct ft_control_keypad . . . . .	55
7.1.3.3	Typedef Documentation . . . . .	56
7.1.3.3.1	ft_control_keypad_callback . . . . .	56
7.1.3.4	Enumeration Type Documentation . . . . .	56
7.1.3.4.1	ft_control_keypad_event . . . . .	56
7.1.3.5	Variable Documentation . . . . .	57
7.1.3.5.1	ft_control_keypad_interface . . . . .	57
7.1.3.6	Keypad Control API . . . . .	58
7.1.3.6.1	Overview . . . . .	58
7.1.3.6.2	Function Documentation . . . . .	59
7.1.3.6.2.1	ft_control_keypad_get_autorepeat_rate . . . . .	59
7.1.3.6.2.2	ft_control_keypad_is_button_touched . . . . .	60
7.1.3.6.2.3	ft_control_keypad_only_one_key_valid . . . . .	61
7.1.3.6.2.4	ft_control_keypad_register_callback . . . . .	61
7.1.3.6.2.5	ft_control_keypad_set_autorepeat_rate . . . . .	62
7.1.4	Matrix Control . . . . .	64
7.1.4.1	Overview . . . . .	64
7.1.4.2	Matrix Control API . . . . .	65
7.1.5	Rotary Control . . . . .	66
7.1.5.1	Overview . . . . .	66
7.1.5.2	Typedef Documentation . . . . .	67
7.1.5.2.1	ft_control_rotary_callback . . . . .	67

Section number	Title	Page
7.1.5.3	Enumeration Type Documentation . . . . .	67
7.1.5.3.1	ft_control_rotary_event . . . . .	67
7.1.5.4	Variable Documentation . . . . .	67
7.1.5.4.1	ft_control_rotary_interface . . . . .	67
7.1.5.5	Rotary Control API . . . . .	68
7.1.5.5.1	Overview . . . . .	68
7.1.5.5.2	Function Documentation . . . . .	68
7.1.5.5.2.1	ft_control_rotary_get_direction . . . . .	68
7.1.5.5.2.2	ft_control_rotary_get_invalid_position . . . . .	69
7.1.5.5.2.3	ft_control_rotary_get_position . . . . .	70
7.1.5.5.2.4	ft_control_rotary_is_touched . . . . .	70
7.1.5.5.2.5	ft_control_rotary_movement_detected . . . . .	71
7.1.5.5.2.6	ft_control_rotary_register_callback . . . . .	72
7.1.6	Slider control . . . . .	74
7.1.6.1	Overview . . . . .	74
7.1.6.2	Typedef Documentation . . . . .	75
7.1.6.2.1	ft_control_slider_callback . . . . .	75
7.1.6.3	Enumeration Type Documentation . . . . .	75
7.1.6.3.1	ft_control_slider_event . . . . .	75
7.1.6.4	Variable Documentation . . . . .	75
7.1.6.4.1	ft_control_slider_interface . . . . .	75
7.1.6.5	Slider Control API . . . . .	76
7.1.6.5.1	Overview . . . . .	76
7.1.6.5.2	Function Documentation . . . . .	76
7.1.6.5.2.1	ft_control_slider_get_direction . . . . .	76
7.1.6.5.2.2	ft_control_slider_get_invalid_position . . . . .	77
7.1.6.5.2.3	ft_control_slider_get_position . . . . .	78
7.1.6.5.2.4	ft_control_slider_is_touched . . . . .	78
7.1.6.5.2.5	ft_control_slider_movement_detected . . . . .	79
7.1.6.5.2.6	ft_control_slider_register_callback . . . . .	80
<b>7.2</b>	<b>Controls . . . . .</b>	<b>82</b>
7.2.1	Overview . . . . .	82
7.2.2	General API . . . . .	83
7.2.2.1	Overview . . . . .	83
7.2.2.2	Data Structure Documentation . . . . .	83
7.2.2.2.1	union ft_control_params . . . . .	83
7.2.2.2.2	struct ft_control . . . . .	84
7.2.2.3	API Functions . . . . .	86
7.2.2.3.1	Overview . . . . .	86
7.2.2.3.2	Function Documentation . . . . .	86
7.2.2.3.2.1	ft_control_count_electrodes . . . . .	86
7.2.2.3.2.2	ft_control_disable . . . . .	86
7.2.2.3.2.3	ft_control_enable . . . . .	87
7.2.2.3.2.4	ft_control_get_electrode . . . . .	88

<b>Section number</b>	<b>Title</b>	<b>Page</b>
7.2.2.3.2.5	ft_control_get_electrodes_state . . . . .	88
7.2.2.3.2.6	ft_control_get_touch_button . . . . .	89
<b>7.3</b>	<b>Electrodes</b> . . . . .	<b>91</b>
7.3.1	Overview . . . . .	91
7.3.2	Data Structure Documentation . . . . .	92
7.3.2.1	struct ft_electrode_status . . . . .	92
7.3.2.2	struct ft_electrode . . . . .	92
7.3.3	Enumeration Type Documentation . . . . .	94
7.3.3.1	ft_electrode_state . . . . .	94
7.3.4	API Functions . . . . .	95
7.3.4.1	Overview . . . . .	95
7.3.4.2	Function Documentation . . . . .	95
7.3.4.2.1	ft_electrode_disable . . . . .	95
7.3.4.2.2	ft_electrode_enable . . . . .	96
7.3.4.2.3	ft_electrode_get_last_status . . . . .	96
7.3.4.2.4	ft_electrode_get_last_time_stamp . . . . .	97
7.3.4.2.5	ft_electrode_get_raw_signal . . . . .	97
7.3.4.2.6	ft_electrode_get_signal . . . . .	98
7.3.4.2.7	ft_electrode_get_time_offset . . . . .	99
<b>7.4</b>	<b>Filters</b> . . . . .	<b>100</b>
7.4.1	Overview . . . . .	100
7.4.2	Data Structure Documentation . . . . .	100
7.4.2.1	struct ft_filter_fbutt . . . . .	100
7.4.2.2	struct ft_filter_iir . . . . .	101
7.4.2.3	struct ft_filter_dctracker . . . . .	101
7.4.2.4	struct ft_filter_moving_average . . . . .	102
7.4.3	Macro Definition Documentation . . . . .	102
7.4.3.1	FT_FILTER_MOVING_AVERAGE_MAX_ORDER . . . . .	102
7.4.4	Advanced Filtering and Integrating Detection . . . . .	103
7.4.4.1	Overview . . . . .	103
7.4.4.2	Data Structure Documentation . . . . .	103
7.4.4.2.1	struct ft_keydetector_afid_asc . . . . .	103
7.4.4.2.2	struct ft_keydetector_afid . . . . .	104
7.4.4.3	Macro Definition Documentation . . . . .	105
7.4.4.3.1	FT_KEYDETECTOR_AFID_ASC_DEFAULT . . . . .	105
7.4.4.4	Variable Documentation . . . . .	106
7.4.4.4.1	ft_keydetector_afid_interface . . . . .	106
<b>7.5</b>	<b>Key Detectors</b> . . . . .	<b>107</b>
7.5.1	Overview . . . . .	107
7.5.2	GPIO module . . . . .	108
7.5.2.1	Overview . . . . .	108
7.5.2.2	Data Structure Documentation . . . . .	108

Section number	Title	Page
7.5.2.2.1	struct ft_module_gpio_user_interface . . . . .	108
7.5.2.2.1.1	Field Documentation . . . . .	109
7.5.2.2.1.1.1	get_pin_value . . . . .	109
7.5.2.2.1.1.2	init_timer . . . . .	109
7.5.2.2.1.1.3	set_pin_default_state . . . . .	110
7.5.2.2.1.1.4	set_pin_high . . . . .	110
7.5.2.2.1.1.5	set_pin_input . . . . .	110
7.5.2.2.1.1.6	set_pin_low . . . . .	110
7.5.2.2.1.1.7	set_pin_output . . . . .	110
7.5.2.2.1.1.8	start_timer . . . . .	110
7.5.2.2.1.1.9	stop_timer . . . . .	110
7.5.2.2.1.1.10	timer_get_counter . . . . .	110
7.5.2.2.1.1.11	timer_get_overrun . . . . .	110
7.5.2.2.1.1.12	timer_reset_counter . . . . .	110
7.5.2.2.2	struct ft_module_gpio_params . . . . .	110
7.5.2.3	Variable Documentation . . . . .	111
7.5.2.3.1	ft_module_gpio_interface . . . . .	111
7.5.3	GPIO interrupt module . . . . .	112
7.5.3.1	Overview . . . . .	112
7.5.3.2	Data Structure Documentation . . . . .	112
7.5.3.2.1	struct ft_module_gpioint_user_interface . . . . .	112
7.5.3.2.1.1	Field Documentation . . . . .	113
7.5.3.2.1.1.1	clear_pin_interrupt . . . . .	113
7.5.3.2.1.1.2	init_pin . . . . .	113
7.5.3.2.1.1.3	init_timer . . . . .	114
7.5.3.2.1.1.4	set_pin_high . . . . .	114
7.5.3.2.1.1.5	set_pin_input . . . . .	114
7.5.3.2.1.1.6	set_pin_interrupt . . . . .	114
7.5.3.2.1.1.7	set_pin_low . . . . .	114
7.5.3.2.1.1.8	set_pin_output . . . . .	114
7.5.3.2.1.1.9	start_timer . . . . .	114
7.5.3.2.1.1.10	stop_timer . . . . .	114
7.5.3.2.1.1.11	timer_get_counter . . . . .	114
7.5.3.2.1.1.12	timer_reset_counter . . . . .	114
7.5.3.2.2	struct ft_module_gpioint_params . . . . .	114
7.5.3.3	Function Documentation . . . . .	115
7.5.3.3.1	ft_module_gpioint_isr . . . . .	115
7.5.3.3.2	ft_module_gpioint_overflow_isr . . . . .	116
7.5.3.4	Variable Documentation . . . . .	117
7.5.3.4.1	ft_module_gpioint_interface . . . . .	117
7.5.4	TSI module . . . . .	118
7.5.4.1	Overview . . . . .	118
7.5.4.2	Data Structure Documentation . . . . .	118
7.5.4.2.1	struct ft_module_tsi_noise . . . . .	118
7.5.4.2.2	struct ft_module_tsi_params . . . . .	119

Section number	Title	Page
7.5.4.3	Variable Documentation . . . . .	120
7.5.4.3.1	ft_module_tsi_interface . . . . .	120
<b>7.6</b>	<b>Modules . . . . .</b>	<b>121</b>
7.6.1	Overview . . . . .	121
7.6.2	General API . . . . .	122
7.6.2.1	Overview . . . . .	122
7.6.2.2	Data Structure Documentation . . . . .	122
7.6.2.2.1	union ft_module_params . . . . .	122
7.6.2.2.2	struct ft_module . . . . .	124
7.6.2.3	Enumeration Type Documentation . . . . .	126
7.6.2.3.1	ft_module_flags . . . . .	126
7.6.2.3.2	ft_module_mode . . . . .	126
7.6.2.4	API Functions . . . . .	127
7.6.2.4.1	Overview . . . . .	127
7.6.2.4.2	Function Documentation . . . . .	127
7.6.2.4.2.1	ft_module_change_mode . . . . .	127
7.6.2.4.2.2	ft_module_load_configuration . . . . .	128
7.6.2.4.2.3	ft_module recalibrate . . . . .	129
7.6.2.4.2.4	ft_module_save_configuration . . . . .	130
<b>7.7</b>	<b>System . . . . .</b>	<b>131</b>
7.7.1	Overview . . . . .	131
7.7.2	Data Structure Documentation . . . . .	132
7.7.2.1	struct ft_system . . . . .	132
7.7.3	Typedef Documentation . . . . .	133
7.7.3.1	ft_error_callback . . . . .	133
7.7.3.2	ft_system_callback . . . . .	133
7.7.4	Enumeration Type Documentation . . . . .	134
7.7.4.1	ft_system_event . . . . .	134
7.7.5	API Functions . . . . .	135
7.7.5.1	Overview . . . . .	135
7.7.5.2	Function Documentation . . . . .	135
7.7.5.2.1	ft_error_register_callback . . . . .	135
7.7.5.2.2	ft_init . . . . .	136
7.7.5.2.3	ft_mem_get_free_size . . . . .	137
7.7.5.2.4	ft_system_get_time_counter . . . . .	138
7.7.5.2.5	ft_system_register_callback . . . . .	138
7.7.5.2.6	ft_task . . . . .	139
7.7.5.2.7	ft_trigger . . . . .	140
<b>7.8</b>	<b>General Types . . . . .</b>	<b>142</b>
7.8.1	Overview . . . . .	142
7.8.2	Macro Definition Documentation . . . . .	143
7.8.2.1	FT_ASSERT . . . . .	143

Section number	Title	Page
7.8.2.2	FT_DEBUG . . . . .	143
7.8.2.3	FT_FLAGS_SPECIFIC_SHIFT . . . . .	143
7.8.2.4	FT_FLAGS_SYSTEM_SHIFT . . . . .	143
7.8.2.5	FT_FREEMASTER_SUPPORT . . . . .	143
7.8.2.6	NULL . . . . .	143
7.8.3	Enumeration Type Documentation . . . . .	143
7.8.3.1	ft_result . . . . .	143
7.8.4	Analog Rotary Control . . . . .	144
7.8.4.1	Overview . . . . .	144
7.8.4.2	Data Structure Documentation . . . . .	145
7.8.4.2.1	struct ft_control_arotary_temp_data . . . . .	145
7.8.4.2.2	struct ft_control_arotary_data . . . . .	146
7.8.4.3	Macro Definition Documentation . . . . .	147
7.8.4.3.1	FT_AROTARY_INVALID_POSITION_VALUE . . . . .	147
7.8.4.4	Enumeration Type Documentation . . . . .	147
7.8.4.4.1	ft_control_arotary_flags . . . . .	147
7.8.5	Analog Slider Control . . . . .	148
7.8.5.1	Overview . . . . .	148
7.8.5.2	Data Structure Documentation . . . . .	149
7.8.5.2.1	struct ft_control_aslider_data . . . . .	149
7.8.5.2.2	struct ft_control_aslider_temp_data . . . . .	150
7.8.5.3	Macro Definition Documentation . . . . .	150
7.8.5.3.1	FT_ASLIDER_INVALID_POSITION_VALUE . . . . .	150
7.8.5.4	Enumeration Type Documentation . . . . .	151
7.8.5.4.1	ft_control_aslider_flags . . . . .	151
7.8.6	Keypad Control . . . . .	152
7.8.6.1	Overview . . . . .	152
7.8.6.2	Data Structure Documentation . . . . .	153
7.8.6.2.1	struct ft_control_keypad_data . . . . .	153
7.8.6.3	Enumeration Type Documentation . . . . .	155
7.8.6.3.1	ft_control_keypad_flags . . . . .	155
7.8.7	Rotary Control . . . . .	156
7.8.7.1	Overview . . . . .	156
7.8.7.2	Data Structure Documentation . . . . .	157
7.8.7.2.1	struct ft_control_rotary_data . . . . .	157
7.8.7.3	Enumeration Type Documentation . . . . .	158
7.8.7.3.1	ft_control_rotary_flags . . . . .	158
7.8.8	Slider Control . . . . .	159
7.8.8.1	Overview . . . . .	159
7.8.8.2	Data Structure Documentation . . . . .	160
7.8.8.2.1	struct ft_control_slider_data . . . . .	160
7.8.8.3	Enumeration Type Documentation . . . . .	161
7.8.8.3.1	ft_control_slider_flags . . . . .	161
<b>7.9</b>	<b>Controls . . . . .</b>	<b>162</b>

Section number	Title	Page
7.9.1	Overview . . . . .	162
7.9.2	General API . . . . .	163
7.9.2.1	Overview . . . . .	163
7.9.2.2	Data Structure Documentation . . . . .	163
7.9.2.2.1	union ft_control_special_data . . . . .	163
7.9.2.2.2	struct ft_control_data . . . . .	165
7.9.2.2.3	struct ft_control_interface . . . . .	166
7.9.2.2.3.1	Field Documentation . . . . .	167
7.9.2.2.3.1.1	init . . . . .	167
7.9.2.2.3.1.2	name . . . . .	167
7.9.2.2.3.1.3	process . . . . .	167
7.9.2.3	Enumeration Type Documentation . . . . .	167
7.9.2.3.1	ft_control_flags . . . . .	167
7.9.2.4	API Functions . . . . .	168
7.9.2.4.1	Overview . . . . .	168
7.9.2.4.2	Function Documentation . . . . .	168
7.9.2.4.2.1	_ft_control_check_data . . . . .	168
7.9.2.4.2.2	_ft_control_check_edge_electrodes . . . . .	169
7.9.2.4.2.3	_ft_control_check_neighbours_electrodes . . . . .	169
7.9.2.4.2.4	_ft_control_clear_flag . . . . .	169
7.9.2.4.2.5	_ft_control_clear_flag_all_elec . . . . .	170
7.9.2.4.2.6	_ft_control_get_data . . . . .	170
7.9.2.4.2.7	_ft_control_get_electrode . . . . .	172
7.9.2.4.2.8	_ft_control_get_electrodes_state . . . . .	172
7.9.2.4.2.9	_ft_control_get_first_elec_touched . . . . .	174
7.9.2.4.2.10	_ft_control_get_flag . . . . .	174
7.9.2.4.2.11	_ft_control_get_last_elec_touched . . . . .	174
7.9.2.4.2.12	_ft_control_get_touch_count . . . . .	174
7.9.2.4.2.13	_ft_control_init . . . . .	174
7.9.2.4.2.14	_ft_control_overrun . . . . .	176
7.9.2.4.2.15	_ft_control_set_flag . . . . .	177
7.9.2.4.2.16	_ft_control_set_flag_all_elec . . . . .	177
<b>7.10</b>	<b>Electrodes . . . . .</b>	<b>178</b>
7.10.1	Overview . . . . .	178
7.10.2	Data Structure Documentation . . . . .	179
7.10.2.1	union ft_electrode_special_data . . . . .	179
7.10.2.2	struct ft_electrode_data . . . . .	179
7.10.3	Enumeration Type Documentation . . . . .	181
7.10.3.1	ft_electrode_flags . . . . .	181
7.10.4	API Functions . . . . .	182
7.10.4.1	Overview . . . . .	182
7.10.4.2	Function Documentation . . . . .	183
7.10.4.2.1	_ft_electrode_clear_flag . . . . .	183
7.10.4.2.2	_ft_electrode_get_data . . . . .	183

<b>Section number</b>	<b>Title</b>	<b>Page</b>
7.10.4.2.3	<a href="#">_ft_electrode_get_delta</a>	184
7.10.4.2.4	<a href="#">_ft_electrode_get_flag</a>	185
7.10.4.2.5	<a href="#">_ft_electrode_get_index_from_module</a>	185
7.10.4.2.6	<a href="#">_ft_electrode_get_last_status</a>	185
7.10.4.2.7	<a href="#">_ft_electrode_get_last_time_stamp</a>	186
7.10.4.2.8	<a href="#">_ft_electrode_get_raw_signal</a>	187
7.10.4.2.9	<a href="#">_ft_electrode_get_shield</a>	187
7.10.4.2.10	<a href="#">_ft_electrode_get_signal</a>	188
7.10.4.2.11	<a href="#">_ft_electrode_get_status</a>	189
7.10.4.2.12	<a href="#">_ft_electrode_get_time_offset</a>	189
7.10.4.2.13	<a href="#">_ft_electrode_get_time_offset_period</a>	190
7.10.4.2.14	<a href="#">_ft_electrode_get_time_stamp</a>	191
7.10.4.2.15	<a href="#">_ft_electrode_init</a>	191
7.10.4.2.16	<a href="#">_ft_electrode_is_touched</a>	192
7.10.4.2.17	<a href="#">_ft_electrode_normalization_process</a>	193
7.10.4.2.18	<a href="#">_ft_electrode_set_flag</a>	194
7.10.4.2.19	<a href="#">_ft_electrode_set_raw_signal</a>	194
7.10.4.2.20	<a href="#">_ft_electrode_set_signal</a>	195
7.10.4.2.21	<a href="#">_ft_electrode_set_status</a>	195
7.10.4.2.22	<a href="#">_ft_electrode_shielding_process</a>	196
<b>7.11</b>	<b>Filters</b>	<b>198</b>
7.11.1	<a href="#">Overview</a>	198
7.11.2	<a href="#">Data Structure Documentation</a>	198
7.11.2.1	<a href="#">struct ft_filter_fbutt_data</a>	198
7.11.2.2	<a href="#">struct ft_filter_moving_average_data</a>	199
7.11.3	<a href="#">Enumeration Type Documentation</a>	200
7.11.3.1	<a href="#">ft_filter_state</a>	200
7.11.4	<a href="#">API Functions</a>	201
7.11.4.1	<a href="#">Overview</a>	201
7.11.4.2	<a href="#">Function Documentation</a>	201
7.11.4.2.1	<a href="#">_ft_abs_int32</a>	201
7.11.4.2.2	<a href="#">_ft_filter_abs</a>	202
7.11.4.2.3	<a href="#">_ft_filter_deadrange_u</a>	202
7.11.4.2.4	<a href="#">_ft_filter_fbutt_init</a>	203
7.11.4.2.5	<a href="#">_ft_filter_fbutt_process</a>	204
7.11.4.2.6	<a href="#">_ft_filter_iir_process</a>	204
7.11.4.2.7	<a href="#">_ft_filter_is_deadrange_u</a>	205
7.11.4.2.8	<a href="#">_ft_filter_limit_u</a>	205
7.11.4.2.9	<a href="#">_ft_filter_moving_average_init</a>	206
7.11.4.2.10	<a href="#">_ft_filter_moving_average_process</a>	206
7.11.5	<a href="#">Advanced Filtering and Integrating Detection</a>	208
7.11.5.1	<a href="#">Overview</a>	208
7.11.5.2	<a href="#">Data Structure Documentation</a>	208
7.11.5.2.1	<a href="#">struct ft_keydetector_afid_asc_data</a>	208

Section number	Title	Page
7.11.5.2.2	struct ft_keydetector_afid_data . . . . .	209
7.11.5.3	Macro Definition Documentation . . . . .	211
7.11.5.3.1	FT_KEYDETECTOR_AFID_INITIAL_INTEGRATOR_VALUE . . . . .	211
7.11.5.3.2	FT_KEYDETECTOR_AFID_INITIAL_RESET_RELEASE_COUNTER_- _VALUE . . . . .	211
7.11.5.3.3	FT_KEYDETECTOR_AFID_INITIAL_RESET_TOUCH_COUNTER_- _VALUE . . . . .	211
<b>7.12</b>	<b>Key Detectors</b> . . . . .	<b>212</b>
7.12.1	Overview . . . . .	212
7.12.2	Data Structure Documentation . . . . .	212
7.12.2.1	union ft_keydetector_data . . . . .	212
7.12.3	GPIO module . . . . .	214
7.12.3.1	Overview . . . . .	214
7.12.3.2	Data Structure Documentation . . . . .	214
7.12.3.2.1	struct ft_module_gpio_data . . . . .	214
7.12.4	GPIO interrupt module . . . . .	216
7.12.4.1	Overview . . . . .	216
7.12.4.2	Data Structure Documentation . . . . .	216
7.12.4.2.1	struct ft_module_gpoint_data . . . . .	216
7.12.5	TSI module . . . . .	218
7.12.5.1	Overview . . . . .	218
7.12.5.2	Data Structure Documentation . . . . .	218
7.12.5.2.1	struct ft_module_tsi_noise_data . . . . .	218
7.12.5.2.2	struct ft_module_tsi_data . . . . .	219
7.12.5.3	Macro Definition Documentation . . . . .	220
7.12.5.3.1	FT_TSI_NOISE_INITIAL_TOUCH_THRESHOLD . . . . .	220
7.12.5.3.2	FT_TSI_NOISE_TOUCH_RANGE . . . . .	220
7.12.5.4	Enumeration Type Documentation . . . . .	220
7.12.5.4.1	ft_module_tsi_flags . . . . .	220
<b>7.13</b>	<b>Modules</b> . . . . .	<b>221</b>
7.13.1	Overview . . . . .	221
7.13.2	General API . . . . .	222
7.13.2.1	Overview . . . . .	222
7.13.2.2	Data Structure Documentation . . . . .	222
7.13.2.2.1	union ft_module_special_data . . . . .	222
7.13.2.2.2	struct ft_module_data . . . . .	223
7.13.2.2.3	struct ft_module_interface . . . . .	225
7.13.2.2.3.1	Field Documentation . . . . .	226
7.13.2.2.3.1.1	change_mode . . . . .	226
7.13.2.2.3.1.2	electrode_disable . . . . .	226
7.13.2.2.3.1.3	electrode_enable . . . . .	226
7.13.2.2.3.1.4	init . . . . .	226
7.13.2.2.3.1.5	load_configuration . . . . .	226

Section number	Title	Page
7.13.2.2.3.1.6	name . . . . .	226
7.13.2.2.3.1.7	process . . . . .	226
7.13.2.2.3.1.8	recalibrate . . . . .	226
7.13.2.2.3.1.9	save_configuration . . . . .	226
7.13.2.2.3.1.10	trigger . . . . .	226
7.13.2.3	API functions . . . . .	227
7.13.2.3.1	Overview . . . . .	227
7.13.2.3.2	Function Documentation . . . . .	227
7.13.2.3.2.1	_ft_module_clear_flag . . . . .	227
7.13.2.3.2.2	_ft_module_get_data . . . . .	228
7.13.2.3.2.3	_ft_module_get_flag . . . . .	229
7.13.2.3.2.4	_ft_module_get_instance . . . . .	230
7.13.2.3.2.5	_ft_module_get_mode . . . . .	230
7.13.2.3.2.6	_ft_module_init . . . . .	230
7.13.2.3.2.7	_ft_module_process . . . . .	231
7.13.2.3.2.8	_ft_module_set_flag . . . . .	232
7.13.2.3.2.9	_ft_module_set_mode . . . . .	233
7.13.2.3.2.10	_ft_module_trigger . . . . .	234
<b>7.14</b>	<b>FreeMASTER support . . . . .</b>	<b>236</b>
7.14.1	Overview . . . . .	236
7.14.2	API functions . . . . .	237
7.14.2.1	Overview . . . . .	237
7.14.2.2	Function Documentation . . . . .	237
7.14.2.2.1	_ft_freemaster_add_variable . . . . .	237
7.14.2.2.2	_ft_freemaster_init . . . . .	238
<b>7.15</b>	<b>Memory Management . . . . .</b>	<b>239</b>
7.15.1	Overview . . . . .	239
7.15.2	Data Structure Documentation . . . . .	239
7.15.2.1	struct ft_mem . . . . .	239
7.15.3	API functions . . . . .	241
7.15.3.1	Overview . . . . .	241
7.15.3.2	Function Documentation . . . . .	241
7.15.3.2.1	_ft_mem_alloc . . . . .	241
7.15.3.2.2	_ft_mem_deinit . . . . .	242
7.15.3.2.3	_ft_mem_init . . . . .	242
<b>8.1</b>	<b>Overview . . . . .</b>	<b>245</b>
<b>8.2</b>	<b>System . . . . .</b>	<b>247</b>

## Chapter 8 Freescale Touch Private API

<b>8.1</b>	<b>Overview . . . . .</b>	<b>245</b>
<b>8.2</b>	<b>System . . . . .</b>	<b>247</b>

Section number	Title	Page
8.2.1	Overview . . . . .	247
8.2.2	Data Structure Documentation . . . . .	247
8.2.2.1	struct ft_kernel . . . . .	247
8.2.3	Enumeration Type Documentation . . . . .	249
8.2.3.1	ft_system_control_call . . . . .	249
8.2.3.2	ft_system_module_call . . . . .	249
8.2.4	API Functions . . . . .	250
8.2.4.1	Overview . . . . .	250
8.2.4.2	Function Documentation . . . . .	250
8.2.4.2.1	_ft_system_control_function . . . . .	250
8.2.4.2.2	_ft_system_get . . . . .	251
8.2.4.2.3	_ft_system_get_module . . . . .	253
8.2.4.2.4	_ft_system_get_time_offset . . . . .	254
8.2.4.2.5	_ft_system_get_time_offset_from_period . . . . .	255
8.2.4.2.6	_ft_system_get_time_period . . . . .	256
8.2.4.2.7	_ft_system_increment_time_counter . . . . .	257
8.2.4.2.8	_ft_system_init . . . . .	257
8.2.4.2.9	_ft_system_invoke_callback . . . . .	258
8.2.4.2.10	_ft_system_module_function . . . . .	259
8.2.4.2.11	_ft_system_modules_data_ready . . . . .	261
8.2.4.2.12	ft_error . . . . .	261

## Chapter 9 Data Structure Documentation

9.0.5	ft_keydetector_interface Struct Reference . . . . .	263
9.0.5.1	Detailed Description . . . . .	263
9.0.5.2	Field Documentation . . . . .	263
9.0.5.2.1	ft_keydetector_init . . . . .	263
9.0.5.2.2	ft_keydetector_measure . . . . .	264
9.0.5.2.3	ft_keydetector_process . . . . .	264
9.0.5.2.4	name . . . . .	264





## Chapter 1 Introduction

This document describes the Freescale software library for implementing the touch-sensing applications on Freescale MCU platforms. The touch-sensing algorithms contained in the library utilize either the dedicated touch-sensing interface (TSI) module available on most of the Freescale Kinetis MCUs, or the generic-pin I/O module to detect finger touch, movement, or gestures. Please read the license agreement document for terms and conditions, under which you can use the software. **Thank you for choosing the Freescale solution!**




Figure 1: Capacitive Touch Sensing principle

The touch-detection algorithms and operation principles are based on the Freescale TSS library version 3.1 released in 2013, which is still available for download at [www.freescale.com](http://www.freescale.com). However, the code in this Freescale Touch library was completely rewritten to simplify the application coding and to make better use of the 32-bit Freescale MCU features. Unlike the TSS 3.1, the new Freescale Touch (FT) library does not use pre-processor configuration macros, but it uses plain C data types to configure **Electrodes**, **Modules**,

and [Controls](#). The library code is also more suitable for use in RTOS-based multi-tasking applications and in the C++ object-oriented applications.

The Freescale Touch library is provided in both the binary library form and the source code form. When used as a binary library, you must link your code to the library statically, and use the library header files to make use of the [Freescale Touch User API](#). When using the source code form, you can put the source files directly into the application project for easy use and debugging. You can also use the source files to build your own version of a statically-linked library.

In any case, your application code uses the same library API and data types to configure, initialize, and use the touch-sensing algorithms implemented in the library. All the steps needed to successfully use the library are described in this document.

## Further Reading

You can find more details on using the Freescale Touch software library in the following sections:

- [Key Library Elements](#) - Describes the main building blocks of the Freescale Touch library
- [Your First Application](#) - Helps you to create your first Freescale Touch application
- [Configuring the Library](#) - Explains the configuration structures that must be defined in the application
- [Freescale Touch User API](#) - Reference manual describing structures and functions you must use when building the touch-sensing applications Further divided into subsections:
  - [System](#) - The system contains general functionality for the whole FT and basic FT API user interface.
  - [Modules](#) - The hardware interaction system that secures and gets the raw data from hardware, and handles it over key detectors to the electrode structure.
  - [Key Detectors](#) - The algorithms that secure recognition of touch-sensing events (Touch and Release) in input raw data from modules.
  - [Electrodes](#) - The basic data container for the individual electrode data, and some basic electrode API.
  - [Controls](#) - The high-level layer of FT that transforms the captured data into logical controls like keypad, slider, and so on.



## Chapter 2

### Key Library Elements

This section explains the key building blocks of the Freescale Touch Library that are used in the user application.

The Freescale Touch library is based on a layered architecture with data types resembling an object-oriented approach, but still implemented in a plain C language. The basic building blocks are outlined in the figure below. Each of the blocks is further described in the **Reference** section.




Figure 2: Object structure

- **System (System API)** - The general code of the FT, providing basic functionality for user application.
- **Modules (Modules API)** - The modules are designed for hardware interaction and gathering capacitance data.
- **Key Detectors (Key Detectors API)** - The key detectors are designed to recognize the touch / release events in the data measured by modules.

- **Controls** ([Controls API](#)) - The high-level objects representing the so-called “Decoder”, and they are used to create the virtual devices (controls) from the individual electrodes.
- **Electrodes** ([Electrodes API](#)) - The electrode is a basic data container with functionality for general control of individual electrodes.

## 2.1 System

The main object encapsulating lists of other key objects used in the Freescale Touch system, such as the measurement modules and controls. There is always only one active instance of the System object in the application. The System function API covers initialization, global timing, and uniform access to touch detection modules.

## 2.2 Modules

This section describes different [Modules](#) supported by the Freescale Touch library.

The modules are part of the FT code, securing the gathering of raw data from different hardware sources, such as GPIO pins or the Freescale TSI peripheral. The GPIO methods are implemented in two different ways: the first is using the standard polling system, and the second is interrupt-driven. The TSI module describes the hardware configuration and control of elementary functionality of the TSI peripheral; it covers all versions of the TSI peripheral using the generic low-level driver API. The TSI module is designed for processors that have the hardware TSI module version 1, 2 or 4 (for example Kinetis L). The module also handles the NOISE mode supported by TSI v4 (Kinetis L). All the different modules are implemented using the same API function. You do not need to take care about the differences between individual TSI versions. Basically, all modules behave like TSI without any difference.

### 2.2.1 Module Types

The FT library defines objects of modules compound of the following division:

- Modules divided according to hardware used
  - **TSI module** - TSI module. This module gathers physical electrode capacitance data from the TSI peripheral. It is based on the KSDK TSI driver. The TSI module also contains a simple key detector for the noise mode (if it is enabled and running on the TSI v4 peripheral version).  
**Noise** - Special noise mode is a hardware feature of the TSI module version 4. This module is implemented mainly in the Kinetis L family of MCUs.)
  - **GPIO module** - GPIO module. This module gathers physical electrode capacitance data using a simple GPIO toggle-pin-polling method.
  - **GPIO interrupt module** - GPIOINT module. This module gathers physical electrode capacitance data using a simple GPIO toggle pin interrupt-driven method.

### 2.2.2 TSI details

The Touch-Sensing Input (TSI) module provides a capacitive touch-sensing detection with high sensitivity and enhanced robustness. Each TSI pin implements the capacitive measurement of an electrode having

## Modules

individual result registers. The TSI module can be functional in several low-power modes with an ultra-low current adder. Freescale currently provides two versions of TSI modules. The first version of the TSI module is implemented in the Coldfire+ and ARM®Cortex®-M4 MCUs. This TSI module can wake the CPU up in case of a touch event, measure all enabled electrodes in one automatic cycle, and provide automatic triggering inside the module. For more details about the TSI module features, see the arbitrary reference manual of the MCU containing the TSI module inside. Figure 5-1 shows a block diagram of the TSI module.




Figure 2.2.1: TSI peripheral version 1 & 2

The second version of the TSI module is a simplified version of the first generation with some additional features. It is currently implemented in the S08PTxx and ARM®Cortex®-M0+ MCUs. This kind of TSI module measures just one enabled electrode in one measurement cycle, and provides automatic triggering externally, using the RTC or LPTMR timer. For more information about the TSI module features, see the reference manual of the MCU containing the TSI module.




Figure 2.2.2: TSI peripheral version 4

## 2.3 Key Detectors

This section describes different **Key Detectors** supported by the Freescale Touch library. The key detector module determines, whether an electrode has been touched or released, based on the values obtained by the capacitance sensing layer. Along with this detection, the key detector module uses a debounce algorithm that prevents the library from false touches.

### 2.3.1 Types

The FT library defines objects of keydetectors compound of following division. (In the current version of FT (FT 1.0 GA), only one key detector is available, and it is called AFID.)

- **AFID** - The AFID (Advanced Filtering and Integrating Detection) key detector operates using two IIR filters with different depths (one being short / fast, the other being long / slow) and, then, integrating the difference between the two filtered signals. Although this algorithm is more immune to noise, it is not compatible with other noise-cancellation techniques, such as shielding. The AFID key detector can be selected manually in the FT configuration. The key detector also provides automatic sensitivity calibration. The calibration periodically adjusts the level of electrode sensitivity, which is calculated according to the touch-tracking information. Although the sensitivity no longer has to be manually set, the settings are still available for more precise tuning. The standard baseline, which is set according to the low-pass IIR filter, is also calculated for analog decoders and proximity function. A debounce function is implemented in this module to eliminate false detections caused by instantaneous noise.

The main functions of the AFID key detector module are as follows:

## Controls

- Two filters with integration for touch detection
- Electrode detection debouncing
- Baseline generation
- IIR filtering of current capacitance signal
- Proximity detection
- Sensitivity autocalibration
- Electrode status reporting
- Fault reporting




Figure 2.3.1: AFID key detector signal diagram

## 2.4 Controls

This section describes different [Controls](#) supported by the Freescale Touch library.

Decoders provide the highest level of abstraction in the library. In this layer, the information regarding touched and untouched electrodes is interpreted, and it shows the status of control in a behavioral way. Additional functionalities can be provided by the decoders. Note that the decoder-related code exists only once in the memory, which implies that despite the number of rotary controls in the system, only one rotary decoder resides in the memory. Decoders can be described as classes of an object-oriented language, where each control has a decoder associated to it. Therefore, the control becomes an instance of the decoder (an object). However, not all decoders are necessarily instantiated in every system. The decoder types supported by the library are:

- Rotary
- Slider
- Keypad
- Analog rotary

- Analog slider

Types:

- **Analog Slider Control** The analog slider control is similar to the standard slider, but it works with less electrodes, and the calculated position has a higher resolution. For example, a two-electrode analog slider can provide an analog position in the range of 128. The shape of the electrodes must meet the condition that increases and decreases the signal during the finger movement, which needs to be linear. The figure shows an arrangement of electrodes used for a typical analog slider. The analog slider control provides the following callback events:
  - direction change
  - movement
  - touch
  - release



Figure 2.4.1: Analog slider

- **Slider control** The linear slider control is similar to the rotary slider. The same parameters must be reported in both. The figure shows an arrangement of electrodes used for a typical linear slider. Like the rotary slider, the shape of the electrodes can be changed, but their position must remain as shown in the figure. The slider control provides the following callback events:
  - direction change
  - movement
  - touch
  - release



Figure 2.4.2: Slider

- **Keypad Control** Keypad is a basic configuration for the arranged electrodes shown in the figure, because all that matters is to determine, which one of the electrodes has been touched. The Keypad Decoder is the module handling the boundary checking, controlling the events buffer, and reporting

## Controls

of events, depending on the user's configuration. The Keypad Decoder must be used when the application needs the electrodes to behave like keyboard keys. If the user needs to detect movement, another type of decoder must be used. The Keypad decoder is capable of using groups of electrodes, that must be touched simultaneously for reporting the defined key. This allows users to create a control interface with more user inputs than the number of physical electrodes. The slider control provides the following callback events:

- touch
- release




Figure 2.4.3: Keypad

- **Rotary Control** Capacitive sensors provide an opportunity to control a device, such as a potentiometer. To achieve this, you must use a special electrode configuration. The figure shows the electrode configuration needed to implement a rotary slider. The shape of the electrodes can vary, but the configuration must stay the same. In other words, the electrodes intended to form a rotary slider must be placed one after another, forming a circle. The rotary control provides the following callback events:

- direction change
- movement
- touch
- release




Figure 2.4.4: Rotary

- **Analog Rotary Control** The analog rotary control is similar to the standard rotary control, but with less electrodes, and the calculated position has a higher resolution. For example, a four-electrode analog rotary control can provide an analog position in the range of 64. The shape of the electrodes must meet the condition that increases and decreases the signal during the finger movement, which must be linear. The figure shows an arrangement of electrodes used for a typical analog rotary control. The configuration must be the same. In other words, the electrodes intended to form a rotary slider must be placed one after another, forming a circle. The analog rotary control provides the following callback events:

- direction change
- movement
- touch
- release




Figure 2.4.5: Analog rotary

## 2.5 Electrodes

Electrodes are data objects that are used by data acquisition algorithms to store per-electrode data, as well as the resulting signal and touch / timestamp information. Each Electrode provides signal value information. The baseline value and the touch / timestamp buffer contain the time of last few touch and release events. The electrode contains information about the key detector used to detect touches for this physical electrode. This brings the advantage that each electrode has its own key detector settings, independent on the module used. It contains information about the hardware pin, immediate touch status, and time stamps

## Electrodes

of the last few touch or release events. The private electrodes API provide all the functionality needed to handle the private needs of the Freescale Touch Library.

It is you as the application programmer and Freescale Touch Library user who specifies what [Modules](#) and [Controls](#) will be instantiated in the system, and what electrodes will be serviced by each module. See more details about various modules and their [configuration](#) in this document.



## Chapter 3

### Directory Structure

Freescale Touch library is organized into the following files and folders:

- [content of the Freescale Touch Installation Folder]
  - **examples** - Ready-to-use example projects. Don't add files from this folder to a custom application project!
    - \* **frdm\_aslider\_app**
    - \* **twr\_default\_app**
    - \* **twr\_twrpi\_app**
    - \* ...
  - **fremaster** - The main Freescale Touch FreeMASTER application, which is able to show all the library parts in a real live application
    - \* **src** - The FreeMASTER web page source code, including the JavaScript files
  - **ft** - The main Freescale Touch library directory
    - \* **include** - Library header files
    - \* **source** - Library source files
      - **controls** - Source files of the [decoders](#)
      - **electrodes** - Source files of the [electrodes](#)
      - **filters** - Source files of the filtering algorithms
      - **keydetectors** - Source files of the [key detectors](#)
      - **modules** - Source files of the [modules](#)
      - **system** - Source files of the [system](#) base code





## Chapter 4

### Configuring the Library

This section describes the library structures that must be initialized to use the Freescale Touch library in the application. Almost all library configuration parameters are passed to the library API in one of the [System](#), [Modules](#), keydetectors, [Electrodes](#), or [Controls](#) structures. The same structures that are used to keep the configuration data for library initialization are then used in the application code to access their runtime properties.

*For example:* the user initializes the ft\_aslider\_control structure to specify the set of electrodes making up the slider layout, the maximum possible resolution of the slider, and other options. In the application runtime, the code uses a pointer to the same structure to access calculated values such as the finger position.

#### 4.1 Configuration Example

The next sections describe the minimum setup required for each of the library structures.

##### 4.1.1 Key Detectors

Key Detector setup for AFID. Following setup is common in ft\_setup.c

```
/* Key Detectors */

const struct ft_keydetector_afid keydec_afid =
{
    .signal_filter = 1,
    .fast_signal_filter = {
        .cutoff = 6
    },
    .slow_signal_filter = {
        .cutoff = 2
    },
    .base_avrg = {.n2_order = 12},
    .reset_rate = 10,
    .asc = {
        .touch_threshold_fall_rate = 1000,
        .noise_resets_minimum = 256,
        .resets_for_touch = 5,
    },
};
```

##### 4.1.2 Electrodes

Electrode setup. Following setup is common in ft\_setup.c

```
const struct ft_electrode electrode_0 =
{
```

## Configuration Example

```
.pin_input = BOARD_TSI_ELECTRODE_1,
.keydetector_interface = &ft_keydetector_afid_interface,
.keydetector_params.afid = &keydec_afid,
};
```

### 4.1.3 Modules

This object depends on the type of module. The module setup (including the hardware configuration) is shown below.

#### 4.1.3.1 TSI module

For operation with [ft\\_module](#) see the code below.

```
const struct ft_electrode * const module_0_electrodes[] = {&electrode_0, &electrode_1,
    &electrode_2, &electrode_3, NULL};

const tsi_config_t hw_config =
{
    .ps = kTsiElecOscPrescaler_16div,
    .extchrg = kTsiExtOscChargeCurrent_8uA,
    .refchrg = kTsiRefOscChargeCurrent_16uA,
    .nscn = kTsiConsecutiveScansNumber_32time,
    .lpclocks = kTsiLowPowerInterval_100ms,
    .amclocks = kTsiActiveClkSource_BusClock,
    .ampsc = kTsiActiveModePrescaler_8div,
    .lpscnity = kTsiLowPowerInterval_100ms,
    .thresh = 100,
    .thresl = 200,
};

const struct ft_module tsi_module =
{
    .interface = &ft_module_tsi_module_interface,
    .electrodes = &module_0_electrodes[0],
    .config = (void*)&hw_config,
    .instance = 0,
    .module_params = NULL,
};
```

### 4.1.4 Controls

Control setup - see the description below.

#### 4.1.4.1 Analog slider

For operation using the [ft\\_control\\_aslider](#) see the code below.

```
const struct ft_electrode * const control_0_electrodes[] = {&electrode_0, &electrode_1,
    &electrode_2, &electrode_3, NULL};

const struct ft_control_aslider aslider_params =
```

```
{
    .range = 100,
};

const struct ft_control aslider_0 =
{
    .interface = &ft_control_aslider_interface,
    .electrodes = control_0_electrodes,
    .control_params.aslider = &aslider_params,
};
```

#### 4.1.4.2 Slider

For operation using the `ft_control_slider` see the code below.

```
const struct ft_electrode * const control_0_electrodes[] = {&electrode_0, &electrode_1,
    &electrode_2, &electrode_3, NULL};

const struct ft_control slider_0 =
{
    .interface = &ft_control_slider_interface,
    .electrodes = control_0_electrodes,
};
```

#### 4.1.4.3 Keypad

For operation using the `ft_control_keypad` see the code below.

```
const struct ft_electrode * const control_0_electrodes[] = {&electrode_0, &electrode_1,
    &electrode_2, &electrode_3, NULL};

const struct ft_control_keypad keypad_params =
{
    .groups = NULL,
    .groups_size = 0,
};

const struct ft_control keypad_0 =
{
    .interface = &ft_control_keypad_interface,
    .electrodes = control_0_electrodes,
    .control_params.keypad = &keypad_params,
};
```

#### 4.1.4.4 Analog rotary

For operation using the `ft_control_arotary` see the code below.

```
const struct ft_electrode * const control_0_electrodes[] = {&electrode_0, &electrode_1,
    &electrode_2, &electrode_3, NULL};

const struct ft_control_arotary arotary_params =
{
    .range = 100,
};
```

## Configuration Example

```
const struct ft_control arotary_0 =
{
    .interface = &ft_control_arotary_interface,
    .electrodes = control_0_electrodes,
    .control_params.arotary = &arotary_params,
};
```

### 4.1.4.5 Rotary

For operation using the ft\_control\_rotary see the code below.

```
const struct ft_electrode * const control_0_electrodes[] = {&electrode_0, &electrode_1,
    &electrode_2, &electrode_3, NULL};

const struct ft_control rotary_0 =
{
    .interface = &ft_control_rotary_interface,
    .electrodes = control_0_electrodes,
};
```

## 4.1.5 System

The **System** is represented by the [ft\\_system](#) structure. This structure binds together all the other objects, so it must be initialized with the following parameters:

- list of controls
- list of modules (which indirectly provides list of all used electrodes)
- time period and initialization time

```
const struct ft_control * const controls[] = {&aslider_0, NULL};
const struct ft_module * const modules[] = {&tsi_module, NULL};

const struct ft_system system_0 = {
    .controls = &controls[0],
    .modules = &modules[0],
    .time_period = 5,
    .init_time = 50,
};
```



## Chapter 5

### Your First Application

This chapter shows how to integrate the Freescale Touch library into an existing application project. There are several ways of using the Freescale Touch library. This guide presents the simplest option, where all library files are added to the user application project, and compiled together with the application. The application demonstrated in this chapter uses two electrodes and implements a simple [slider](#) control, which is able to detect finger movement within a linear area.

#### 5.1 Creating the Freescale Touch Application

You can use the library in these two ways:

- Put the library source files directly into the application project (*as described below*)
- Compile the library files into a statically-linked library, and use the library in your application project

##### 5.1.1 Adding Library Files into the Project

The library can be easily integrated into your application by adding the FT source files into your project. See the [Directory Structure](#) section to understand the files and folders of the Freescale Touch library. There are two steps to take:

- The "include" search paths of your project must be extended to cover the directories with public header files (the /ft/lib/include folder).
- The source code files must be added into the project (the /ft/lib/source folder and all subfolders). Not all source files are always used in the application, but the linker should take care of optimizing the unused code out of the executable.

The library uses startup code, linker files, and some low-level driver code from the Kinetis SDK. This code is not considered to be part of the Freescale Touch library, but it serves as a basis for example applications. You can reuse the SDK linker files and drivers in your custom application also. However, it is better to get the latest SDK version from the Freescale web site.

The figure below shows the typical Freescale Touch application project in the IAR Embedded Workbench IDE:

## Creating the Freescale Touch Application




Figure 5.1.1: Workspace directory

### 5.1.2 Setting 'include' Search Paths

The figure shows how to set up the search paths in the IAR Embedded Workbench IDE. Only one include path is needed from the Freescale Touch point of view. The pre-processor symbols must be defined to identify the CPU and Board for the SDK low-level code. You can find the valid options in the `fsl_device_registers.h` file, located in the `KSDK/platform/CMSIS/Include/device/` directory.




Figure 5.1.2: Include search path

All search paths: Only the first path is mandatory.

```
$PROJ_DIR$/../../
$PROJ_DIR$/../../../../ft/include
$PROJ_DIR$/../../../../KSDK/boards/twrk60d100m
$PROJ_DIR$/../../../../KSDK/platform/drivers/inc
$PROJ_DIR$/../../../../KSDK/platform/hal/inc
$PROJ_DIR$/../../../../KSDK/platform/CMSIS/Include
$PROJ_DIR$/../../../../KSDK/platform/system/inc
$PROJ_DIR$/../../../../KSDK/platform/osa/inc
$PROJ_DIR$/../../../../KSDK/platform/devices
$PROJ_DIR$/../../../../KSDK/platform/devices/MK60D10/startup
$PROJ_DIR$/../../../../KSDK/platform/devices/MK60D10/include
$PROJ_DIR$/../../../../KSDK/platform/utilities/inc
```

## Creating the Freescale Touch Application

### 5.1.3 Setting 'linker' path

The figure shows how to set up the linker file in the IAR Embedded Workbench IDE. This is the file reused from the Kinetis SDK. You can use your own linker file to have a full control over the linker process.




Figure 5.1.3: Linker search path

### 5.1.4 Application Setup

To define modules, electrodes, controls, and system, you must create initialized instances of the structure types, as described in section [Configuring the Library](#).

The code below shows an example configuration of four electrodes on the TWR K60D100M board.

There are several [key detectors](#) (touch-evaluation algorithms) available in the Freescale Touch library. The electrode structure types must always match the module and algorithm types.

This is an example of the AFID key detector configuration.

```
/* Key Detectors */

const struct ft_keydetector_afid keydec_afid =
{
    .signal_filter = 1,
    .fast_signal_filter = {
        .cutoff = 6
    },
    .slow_signal_filter = {
        .cutoff = 2
    },
    .base_avrg = {.n2_order = 12},
    .reset_rate = 10,
    .asc = {
        .touch_threshold_fall_rate = 1000,
        .noise_resets_minimum = 256,
        .resets_for_touch = 5,
    },
};
```

The electrode structure type must match the hardware module used for the data-measurement algorithm in the application. In this case, it is the `ft_electrode` type. You must define the electrode parameters and `ft_keydetector` interface.

```
/* Electrodes */
const struct ft_electrode electrode_0 =
{
    .pin_input = BOARD_TSI_ELECTRODE_1,
    .keydetector_interface = &ft_keydetector_afid_interface,
    .keydetector_params.afid = &keydec_afid,
};

const struct ft_electrode electrode_1 =
{
    .pin_input = BOARD_TSI_ELECTRODE_2,
    .keydetector_interface = &ft_keydetector_afid_interface,
    .keydetector_params.afid = &keydec_afid,
};

const struct ft_electrode electrode_2 =
{
    .pin_input = BOARD_TSI_ELECTRODE_3,
    .keydetector_interface = &ft_keydetector_afid_interface,
    .keydetector_params.afid = &keydec_afid,
};

const struct ft_electrode electrode_3 =
{
    .pin_input = BOARD_TSI_ELECTRODE_4,
    .keydetector_interface = &ft_keydetector_afid_interface,
    .keydetector_params.afid = &keydec_afid,
};
```

The Kinetis L family of MCUs contains a different TSI module version than the one used in the Kinetis K family of MCUs. Distinguishing the Kinetis L TSI module, we internally refer to it as TSIL. The module must be configured for a proper operation. However, the FT library helps during the application development, and it is not necessary to deal with the TSI module differences. The TSI hardware setup is displayed below.

## Creating the Freescale Touch Application

```
/* Modules */
const struct ft_electrode * const module_0_electrodes[] = {&electrode_0, &electrode_1,
    &electrode_2, &electrode_3, NULL};

const tsi_config_t hw_config =
{
    .ps = kTsiElecOscPrescaler_16div,
    .extchrg = kTsiExtOscChargeCurrent_8uA,
    .refchg = kTsiRefOscChargeCurrent_16uA,
    .nscn = kTsiConsecutiveScansNumber_32time,
    .lpclks = kTsiLowPowerInterval_100ms,
    .amclks = kTsiActiveClkSource_BusClock,
    .ampsc = kTsiActiveModePrescaler_8div,
    .lpscnytv = kTsiLowPowerInterval_100ms,
    .thresh = 100,
    .thresl = 200,
};

const struct ft_module tsi_module =
{
    .interface = &ft_module_tsi_module_interface,
    .electrodes = &module_0_electrodes[0],
    .config = (void*)&hw_config,
    .instance = 0,
    .module_params = NULL,
};
```

Once the modules and electrodes are set up, you can define the [Controls](#). In this case, the control\_0 is the [Analog Slider](#) control.

```
/* Controls */
const struct ft_electrode * const control_0_electrodes[] = {&electrode_0, &electrode_1,
    &electrode_2, &electrode_3, NULL};

const struct ft_control_keypad keypad_params =
{
    .groups = NULL,
    .groups_size = 0,
};

const struct ft_control keypad_0 =
{
    .interface = &ft_control_keypad_interface,
    .electrodes = control_0_electrodes,
    .control_params.keypad = &keypad_params,
};
```

Now we are ready to connect all the pieces together in the [system](#) structure.

```
/* System */
const struct ft_control * const controls[] = {&keypad_0, NULL};
const struct ft_module * const modules[] = {&tsi_module, NULL};

const struct ft_system system_0 = {
    .controls = &controls[0],
    .modules = &modules[0],
    .time_period = 5,
    .init_time = 50,
};
```

### 5.1.5 The main() Function

The minimal application code must look like this:

```
#include <stdio.h>
#include <stdlib.h>
#include "fsl_device_registers.h"
#include "fsl_debug_console.h"
#include "fsl_clock_manager.h"
#include "fsl_interrupt_manager.h"
#include "fsl_pit_driver.h"
#include "fsl_os_abstraction.h"
#include "ft_setup.h"
#include "main.h"
#include "board.h"

static void port_led_init(void);
static void keypad_callback(const struct ft_control *control,
                           enum ft_control_keypad_event event,
                           uint32_t index);

uint8_t ft_memory_pool[2048];

const pit_user_config_t my_pit_config = {
    .isInterruptEnabled = true,
    .periodUs = 5000
};

int main(void)
{
    int32_t result;

    hardware_init();
    port_led_init();

    // Configure TSI pins
    configure_tsi_pins(0u);

    // Initialize the OS abstraction layer
    OSA_Init();

    if ((result = ft_init(&system_0, ft_memory_pool, sizeof(ft_memory_pool))) != FT_SUCCESS)
    {
        switch(result)
        {
            case FT_FAILURE:
                printf("\nCannot initialize the Freescale Touch due to a non-specific error.\n");
                break;
            case FT_OUT_OF_MEMORY:
                printf("\nCannot initialize the Freescale Touch due to not enough memory.\n");
                break;
        }
        while(1); /* add code to handle this error */
    }

    printf("\nThe Freescale Touch has been successfully initialized.\n");

    printf("Unused memory: %d bytes, you can make the memory pool smaller without affecting the
          functionality.\n", (int)ft_mem_get_free_size());

    ft_electrode_enable(&electrode_0);
    ft_electrode_enable(&electrode_1);
    ft_electrode_enable(&electrode_2);
    ft_electrode_enable(&electrode_3);
    ft_control_enable(&keypad_0);
```

## Creating the Freescale Touch Application

```
ft_control_keypad_set_autorepeat_rate(&keypad_0, 100, 1000);
ft_control_keypad_register_callback(&keypad_0, &keypad_callback);

// Run the PIT driver to generate 5 ms events
PIT_DRV_Init(0, false);

// Init PIT channel
PIT_DRV_InitChannel(0, 0, &my_pit_config);

// Start the PIT timer
PIT_DRV_StartTimer(0, 0);

while(1)
{
    ft_task();
}

void PIT_DRV_CallBack(uint32_t channel)
{
    (void)channel;
    ft_trigger();
}

static void port_led_init(void)
{
    /* LED Init */
    LED1_EN;
    LED2_EN;
    LED3_EN;
    LED4_EN;

    LED1_OFF;
    LED2_OFF;
    LED3_OFF;
    LED4_OFF;
}

static void keypad_callback(const struct ft_control *control,
                           enum ft_control_keypad_event event,
                           uint32_t index)
{
    switch(event)
    {
    case FT_KEYPAD_RELEASE:
        printf("Release %d.\n", (int)index);
        switch (index) {
            case 0:
                LED1_OFF;
                break;
            case 1:
                LED2_OFF;
                break;
            case 2:
                LED3_OFF;
                break;
            case 3:
                LED4_OFF;
                break;
            default:
                break;
        }
        break;
    case FT_KEYPAD_TOUCH:
        printf("Touch %d.\n", (int)index);
        switch (index) {
            case 0:
                LED1_ON;
                break;
        }
    }
}
```

```
        break;
    case 1:
        LED2_ON;
        break;
    case 2:
        LED3_ON;
        break;
    case 3:
        LED4_ON;
        break;
    default:
        break;
}
break;

case FT_KEYPAD_AUTOREPEAT:
printf("AutoRepeat %d.\n", (int)index);
switch (index) {
    case 0:
        LED1_TOGGLE;
        break;
    case 1:
        LED2_TOGGLE;
        break;
    case 2:
        LED3_TOGGLE;
        break;
    case 3:
        LED4_TOGGLE;
        break;
    default:
        break;
}
break;
}
```

## Creating the Freescale Touch Application

# Chapter 6

## Release Notes

### Freescale Touch v1.0

#### Overview

These are the release notes for the Freescale Touch software (FT) version 1.0. This is full function library to handle the touch events measured by the FSL TSI module or GPIO methods. It also has the capability to represent the measured results in various controls, such as: Keypad, Rotary, Slider, Analog Slider or Analog Rotary.

#### 1. What is new

This is the first public release, and it brings the following features:

- Supported devices
  - MK60D10
  - MKL25Z4
  - MKL26Z4
  - MKL46Z4
- Supported modules (peripherals / methods)
  - TSI (v2 / v4)
  - GPIO (also in interrupt mode)
- Supported controls
  - Keypad
  - Slider
  - Rotary
  - Analog Slider
  - Analog Rotary
- Supported Development tools
  - IAR 7.4
  - KEIL 5.1
  - KDS 2.0

#### 2. Development tools

The Freescale Touch 1.0 was compiled and tested using the following development tools: -IAR Embedded Workbench for ARM® version 7.40 -MDK-ARM Microcontroller Development Kit (Keil)® 5.11 -KDS Freescale Kinetis Design Studio v2.00

#### 3. Supported development systems

This release supports the following boards and devices:

- MK60D10
  - TWR-K60D100M
- MKL25Z4
  - FRDM-KL25Z
- MKL26Z4
  - FRDM-KL26Z
- MKL46Z4
  - FRDM-KL46Z

## 4. Release contents

This table describes the release contents.

PBSDeliverable	Location
Documentation	{install_dir}/doc/
SW Examples	{install_dir}/sw/examples/
FreeMASTER application	{install_dir}/sw/freemaster/FreescaleTouch.pmp
FT Library source code	{install_dir}/sw/ft/

## 5. Freescale Touch release overview

The FT is intended for use with Freescale's Kinetis MCU product family, based on the ARM Cortex®-M series architectures. The whole library is designed to work with KSDK 1.2.0. The release consists of:

- Documentation - Reference manual
- Example application for supported boards
- FreeMASTER application for FT
- FT library source code

### 5.1 Documentation

The release contains the generated documentation that describes the whole library with block schemes, and the whole API is described either as public, or as all private internal API. The documentation is provided in HTML format.

### 5.2 Example application for supported boards

There is couple of example application that's runs on standard Freescale development boards, that's show all aspects of the FT capabilities. All applications are prepared for all supported Development tools.

### 5.3 FreeMASTER application for FT

The FreeMASTER application is provided for better understanding and tuning of the final values of the key detector settings, and it automatically generates HTML pages based on the current configuration of the embedded application using TSA tables.




Figure 4: FreeMASTER example

### 5.4 Freescale Touch library software

The FT is distributed as a source code to allow you to check the code, and extend it using your own modules / key detectors / controls to meet the specific needs. The code is divided to two main folders:

- Includes - all public include header files - this is only folder that must be added to the preprocessor path for the FT library
- Source - Source code and private header files for the FT library

## 6 Known issues

### 6.1 Project paths

All the project paths are setup during the installation as an absolute path, relative to the KSDK installation. This allows you to have the project installed on the PC in any folder where the FT was installed, but it can cause issues on any other PC.

### 6.2 Low power support

The low power support in the FT is enabled by switching the mode of the FT module into the low-power mode. This functionality does not have any example in the current release package.

### 6.3 Shielding (water drops tolerance)

The current package has implemented the water tolerance in the same way as the TSS software. The implementation is done by shielding the electrode that will compensate for the signal drift caused by water drops. This functionality is not tested yet.

### 6.4 Proximity sensing

This version does not contain any high-level proximity-sensing API. To get started, you can just switch the FT module to the proximity mode.

## 7. Revision history

PBS Revision number	Date	Substantial changes
1.0	04/2015	Initial external release
1.0 Beta	12/2014	Internal release (VIP customers)
1.0 Alpha	10/2014	Internal Initial release




## Chapter 7

# Freescale Touch User API

### 7.1 Overview

The functions documented in this module are the primary functions used in the user application that uses the Freescale Touch library. The user calls the API functions to give run-time for the Freescale Touch measurement and data-processing algorithms. All library callbacks are executed in a context of one of these API calls. Collaboration diagram for Freescale Touch User API:



### Modules

- Controls
- Electrodes
- Filters
- Key Detectors
- Modules
- System
- General Types

## Overview

### 7.1.1 Analog Rotary Control

#### 7.1.1.1 Overview

Analog Rotary enables the detection of jog-dial-like finger movement using three or more electrodes; it is represented by the [ft\\_control](#) structure.

The Analog Rotary Control uses three or more specially-shaped electrodes to enable the calculation of finger position within a circular area. The position algorithm uses the ratio of sibling electrode signals to estimate the finger position with the required precision.

The Analog Rotary works similarly to the "standard" Rotary, but requires less electrodes, while achieving a higher resolution of the calculated position. For example, a four-electrode Analog Rotary can provide the finger position detection in the range of 0-64. The shape of the electrodes needs to be designed specifically to achieve a stable signal with a linear dependence on finger movement.

The Analog Rotary Control provides Position, Direction, and Displacement values. It is able to generate event callbacks when finger Movement, Initial-touch, or Release is detected.

The image below shows a typical four-electrode Analog Rotary electrode placement.




Figure 7.1.1: Analog Rotary Electrodes

Collaboration diagram for Analog Rotary Control:



## Modules

- [Analog Rotary Control API](#)

## Data Structures

- struct `ft_control_arotary`

## Typedefs

- typedef void(\* `ft_control_arotary_callback` )(const struct `ft_control` \*control, enum `ft_control_arotary_event` event, uint32\_t position)

## Enumerations

- enum `ft_control_arotary_event` {  
    `FT_AROTAORY_MOVEMENT`,  
    `FT_AROTAORY_ALL_RELEASE`,  
    `FT_AROTAORY_INITIAL_TOUCH` }

## Variables

- struct `ft_control_interface ft_control_arotary_interface`


### 7.1.1.2 Data Structure Documentation

#### 7.1.1.2.1 struct `ft_control_arotary`

The main structure representing the Analog Rotary Control.

An instance of this data type represents the Analog Rotary Control. You are responsible to initialize all the members before registering the control in the system. This structure can be allocated in ROM.

Collaboration diagram for `ft_control_arotary`:



## Overview

Data Fields

uint8_t	range	Range.
---------	-------	--------

### 7.1.1.3 Typedef Documentation

**7.1.1.3.1 `typedef void(* ft_control_arotary_callback)(const struct ft_control *control, enum ft_control_arotary_event event, uint32_t position)`**

Analog Rotary event callback function pointer type.

### 7.1.1.4 Enumeration Type Documentation

**7.1.1.4.1 `enum ft_control_arotary_event`**

Analog Rotary event types.

Enumerator

***FT\_AROTARY\_MOVEMENT*** Finger movement event.

***FT\_AROTARY\_ALL\_RELEASE*** Release event.

***FT\_AROTARY\_INITIAL\_TOUCH*** Initial-touch event.

### 7.1.1.5 Variable Documentation

**7.1.1.5.1 `struct ft_control_interface ft_control_arotary_interface`**

An interface structure, which contains pointers to the entry points of the Analog Rotary algorithms. A pointer to this structure must be assigned to any instance of the `ft_control` to define the control behavior. Can't be NULL.

### 7.1.1.6 Analog Rotary Control API

#### 7.1.1.6.1 Overview

These functions can be used to set or get the Analog Rotary control properties.

A common example defition of the Analog Rotary control for all source code examples is as follows:

```
* // definition of the electrode array used by the control (more info in electrodes )
* const struct ft_electrode * const control_0_electrodes[] = {&electrode_0, &electrode_1,
*   &electrode_2, &electrode_3, NULL};
*
* // Define additional parameters of the Analog Rotary
* const struct ft_control_arotary my_arotary_params =
* {
*   .range = 255,
* };
*
* // Definition of the Analog Rotary control
* const struct ft_control my_arotary_control =
* {
*   .interface = &ft_control_arotary_interface,
*   .electrodes = control_0_electrodes,
*   .control_params.arotary = &my_arotary_params,
* };
*
*
```

Collaboration diagram for Analog Rotary Control API:



## Functions

- void `ft_control_arotary_register_callback` (const struct `ft_control` \*control, `ft_control_arotary_callback` callback)
   
*Registers the Analog Rotary events handler function.*
- uint32\_t `ft_control_arotary_get_position` (const struct `ft_control` \*control)
   
*Get the Analog Rotary 'Position' value.*
- uint32\_t `ft_control_arotary_is_touched` (const struct `ft_control` \*control)
   
*Get 'Touched' state.*
- uint32\_t `ft_control_arotary_movement_detected` (const struct `ft_control` \*control)
   
*Get 'Movement' flag.*
- uint32\_t `ft_control_arotary_get_direction` (const struct `ft_control` \*control)
   
*Get 'Direction' flag.*
- uint32\_t `ft_control_arotary_get_invalid_position` (const struct `ft_control` \*control)
   
*Returns invalid position flag.*

## Overview

### 7.1.1.6.2 Function Documentation

7.1.1.6.2.1 `uint32_t ft_control_arotary_get_direction( const struct ft_control * control )`

## Parameters


<i>control</i>	Pointer to the control.
----------------	-------------------------

## Returns

- Non-zero value, if a movement towards higher values is detected.
- Returns zero, if a movement towards zero is detected. Example:

```
* uint32_t direction;
* // Get direction of arotary control
* direction = ft_control_arotary_get_direction(&my_arotary_control);
* if(direction)
*     printf("The Analog Rotary direction is left.");
* else
*     printf("The Analog Rotary direction is right.");
*
```

Here is the call graph for this function:



### 7.1.1.6.2.2 `uint32_t ft_control_arotary_get_invalid_position ( const struct ft_control * control )`

## Parameters

<i>control</i>	Pointer to the control.
----------------	-------------------------

## Returns


Non-zero value, if an invalid touch is detected.

This flag is set, if the algorithm detects two or more fingers touching the electrodes, which are not adjacent to each other. Example:

```
* uint32_t invalid_position;
* // Get invalid position of arotary control
* invalid_position = ft_control_arotary_get_invalid_position(&
*     my_arotary_control);
* if(invalid_position)
*     printf("The Analog Rotary control has an invalid position (two fingers touch ?).");
* else
*     printf("The Analog Rotary control has a valid position.");
*
```

## Overview

Here is the call graph for this function:



### 7.1.1.6.2.3 uint32\_t ft\_control\_arotary\_get\_position ( const struct ft\_control \* control )

Parameters

<i>control</i>	Pointer to the control.
----------------	-------------------------

Returns

Position. The returned value is in the range of zero to the maximum value configured in the [ft\\_control](#) structure.

This function retrieves the actual finger position value. Example:

```

* uint32_t position;
* // Get position of arotary control
* position = ft_control_arotary_get_position(&my_arotary_control);
* printf("Position of Analog Rotary control is: %d.", position);
*
  
```

Here is the call graph for this function:



### 7.1.1.6.2.4 uint32\_t ft\_control\_arotary\_is\_touched ( const struct ft\_control \* control )

## Parameters


<i>control</i>	Pointer to the control.
----------------	-------------------------

## Returns

Non-zero value, if the control is currently touched. Example:

```
* uint32_t touched;
* // Get state of arotary control
* touched = ft_control_arotary_is_touched(&my_arotary_control);
* if(touched)
*     printf("The Analog Rotary control is currently touched.");
* else
*     printf("The Analog Rotary control is currently not touched.");
*
```

Here is the call graph for this function:



### 7.1.1.6.2.5 uint32\_t ft\_control\_arotary\_movement\_detected ( const struct ft\_control \* *control* )

## Parameters

<i>control</i>	Pointer to the control.
----------------	-------------------------


## Returns

Non-zero value, if the control currently detects finger movement. Example:

```
* uint32_t movement;
* // Get state of arotary control
* movement = ft_control_arotary_movement_detected(&my_arotary_control);
* if(movement)
*     printf("The Analog Rotary control is currently moving.");
* else
*     printf("The Analog Rotary control is currently not moving.");
*
```

## Overview

Here is the call graph for this function:



### 7.1.1.6.2.6 void **ft\_control\_arotary\_register\_callback** ( const struct **ft\_control** \* *control*, **ft\_control\_arotary\_callback** *callback* )

Parameters

<i>control</i>	Pointer to the control.
<i>callback</i>	Address of function to be invoked.

Returns


none

Register the specified callback function as the Analog Rotary events handler. If the callback parameter is NULL, the callback is disabled. Example:

```

/*
* //Create the callback function for arotary
* static void my_arotary_cb(const struct ft_control *control,
*                           enum ft_control_arotary_event event,
*                           uint32_t position)
* {
*     (void)control;
*     char* event_names[] =
*     {
*         "FT_AROTARY_MOVEMENT",
*         "FT_AROTARY_ALL_RELEASE",
*         "FT_AROTARY_INITIAL_TOUCH",
*     };
*     printf("New analog rotary control event %s on position: %d.", event_names[event], position);
* }
*
* // register the callback function for arotary
* ft_control_arotary_register_callback(&my_arotary_control,
*                                     my_arotary_cb);
* 
```

Here is the call graph for this function:



## Overview

### 7.1.2 Analog Slider Control

#### 7.1.2.1 Overview

Analog Slider enables detection of linear finger movement using two or more electrodes; it is represented by the [ft\\_control\\_aslider](#) structure.

The Analog Slider Control uses two or more specially-shaped electrodes to enable the calculation of finger position within a linear area. The position algorithm uses ratio of electrode signals to estimate finger position with required precision.

The Analog Slider works similarly to the "standard" Slider, but requires less electrodes, while achieving a higher resolution of the calculated position. For example, a two-electrode analog slider can provide finger position detection in the range of 0-127. The shape of the electrodes needs to be designed specifically to achieve a stable signal with a linear dependence on finger movement.

The Analog Slider Control provides Position, Direction, and Displacement values. It is able to generate event callbacks when finger Movement, Initial-touch, or Release is detected.

The figure below shows a typical two-electrode Analog Slider electrode placement.



Figure 7.1.2: Analog Slider Electrodes

Collaboration diagram for Analog Slider Control:



## Modules

- [Analog Slider Control API](#)

## Data Structures

- struct [ft\\_control\\_aslider](#)

## Typedefs

- `typedef void(* ft_control_aslider_callback )(const struct ft_control *control, enum ft_control_aslider_event event, uint32_t position)`

## Enumerations

- `enum ft_control_aslider_event { FT_ASLIDER_MOVEMENT, FT_ASLIDER_ALL_RELEASE, FT_ASLIDER_INITIAL_TOUCH }`

## Variables

- `struct ft_control_interface ft_control_aslider_interface`


### 7.1.2.2 Data Structure Documentation

#### 7.1.2.2.1 struct ft\_control\_aslider

The main structure representing the Analog Slider Control.

An instance of this data type represents the Analog Slider Control. You are responsible to initialize all the members before registering the control in the system. This structure can be allocated in ROM.

Collaboration diagram for `ft_control_aslider`:



#### Data Fields

## Overview

uint8_t	insensitivity	Insensitivity for the callbacks invokes when the position is changed.
uint8_t	range	Maximum range for the ram->position value.

### 7.1.2.3 Typedef Documentation

**7.1.2.3.1 `typedef void(* ft_control_aslider_callback)(const struct ft_control *control, enum ft_control_aslider_event event, uint32_t position)`**

Analog Slider event callback function pointer type.

### 7.1.2.4 Enumeration Type Documentation

**7.1.2.4.1 `enum ft_control_aslider_event`**

Analog Slider event types.

Enumerator

**`FT_ASLIDER_MOVEMENT`** Finger movement event

**`FT_ASLIDER_ALL_RELEASE`** Release event

**`FT_ASLIDER_INITIAL_TOUCH`** Initial-touch event

### 7.1.2.5 Variable Documentation

**7.1.2.5.1 `struct ft_control_interface ft_control_aslider_interface`**

An interface structure, which contains pointers to the entry points of the Analog Slider algorithms. A pointer to this structure must be assigned to any instance of the `ft_control_aslider` to define the control behavior.

## 7.1.2.6 Analog Slider Control API

### 7.1.2.6.1 Overview

These functions can be used to set or get the Analog Slider control properties.

Common example definition of the Analog Slider control for all source code examples is as follows:

```
* // definition of the electrode array used by the control (more info in electrodes )
* const struct ft_electrode * const control_0_electrodes[] = {&electrode_0, &electrode_1,
*     NULL};
*
* // Define additional parameters of Analog Slider
* const struct ft_control_aslider my_aslider_params =
* {
*     .range = 100,
* };
*
* // Definition of the Analog Slider control
* const struct ft_control my_aslider_control =
* {
*     .interface = &ft_control_aslider_control_interface,
*     .electrodes = control_0_electrodes,
*     .control_params.aslider = &my_aslider_params,
* };
*
*
```

Collaboration diagram for Analog Slider Control API:



## Functions

- void `ft_control_aslider_register_callback` (const struct `ft_control` \*control, `ft_control_aslider_callback` callback)
   
*Registers the Analog Slider events handler function.*
- uint32\_t `ft_control_aslider_get_position` (const struct `ft_control` \*control)
   
*Get the Analog Slider 'Position' value.*
- uint32\_t `ft_control_aslider_is_touched` (const struct `ft_control` \*control)
   
*Get 'Touched' state.*
- uint32\_t `ft_control_aslider_movement_detected` (const struct `ft_control` \*control)
   
*Get 'Movement' flag.*
- uint32\_t `ft_control_aslider_get_direction` (const struct `ft_control` \*control)
   
*Get 'Direction' flag.*
- uint32\_t `ft_control_aslider_get_invalid_position` (const struct `ft_control` \*control)
   
*Returns invalid position flag.*

## Overview

### 7.1.2.6.2 Function Documentation

7.1.2.6.2.1 `uint32_t ft_control_aslider_get_direction( const struct ft_control * control )`

## Parameters


<i>control</i>	Pointer to the control.
----------------	-------------------------

## Returns

Non-zero value, when a movement towards higher values is detected. Returns zero when a movement towards zero is detected. Example:

```
* uint32_t direction;
* // Get direction of aslider control
* direction = ft_control_aslider_get_direction(&my_aslider_control);
* if(direction)
*     printf("The Analog Slider direction is left.");
* else
*     printf("The Analog Slider direction is right.");
*
```

Here is the call graph for this function:



### 7.1.2.6.2.2 `uint32_t ft_control_aslider_get_invalid_position ( const struct ft_control * control )`

## Parameters

<i>control</i>	Pointer to the control.
----------------	-------------------------

## Returns

Non-zero value, when an invalid touch is detected.


This function works only in the Analog Slider controls, consisting of at least three electrodes. This flag is set when the algorithm detects two or more fingers touching the electrodes that are not adjacent to each other. Example:

```
* uint32_t invalid_position;
* // Get invalid position of aslider control
* invalid_position = ft_control_aslider_get_invalid_position(&
    my_aslider_control);
```

## Overview

```
* if(invalid_position)
*     printf("The Analog Slider control has an invalid position (two fingers touch ?).");
* else
*     printf("The Analog Slider control has a valid position.");
*
```

Here is the call graph for this function:



### 7.1.2.6.2.3 uint32\_t ft\_control\_aslider\_get\_position ( const struct ft\_control \* control )

Parameters

<i>control</i>	Pointer to the control.
----------------	-------------------------


Returns

Position. The returned value is in the range of zero to maximum value configured in the [ft\\_control-aslider](#) structure.

This function retrieves the actual finger position value. Example:

```
* uint32_t position;
* // Get position of aslider control
* position = ft_control_aslider_get_position(&my_aslider_control);
* printf("Position of analog slider control is: %d.", position);
*
```

Here is the call graph for this function:



### 7.1.2.6.2.4 uint32\_t ft\_control\_aslider\_is\_touched ( const struct ft\_control \* control )

## Parameters


<i>control</i>	Pointer to the control.
----------------	-------------------------

## Returns

Non-zero value, when the control is currently touched. Example:

```
* uint32_t touched;
* // Get state of aslider control
* touched = ft_control_aslider_is_touched(&my_aslider_control);
* if(touched)
*     printf("The Analog Slider control is currently touched.");
* else
*     printf("The Analog Slider control is currently not touched.");
*
```

Here is the call graph for this function:



### 7.1.2.6.2.5 uint32\_t ft\_control\_aslider\_movement\_detected ( const struct ft\_control \* control )

## Parameters

<i>control</i>	Pointer to the control.
----------------	-------------------------


## Returns

Non-zero value, if the control currently detects finger movement. Example:

```
* uint32_t movement;
* // Get state of aslider control
* movement = ft_control_aslider_movement_detected(&my_aslider_control);
* if(movement)
*     printf("The Analog Slider control is currently moving.");
* else
*     printf("The Analog Slider control is currently not moving.");
*
```

## Overview

Here is the call graph for this function:



### 7.1.2.6.2.6 void **ft\_control\_aslider\_register\_callback** ( const struct **ft\_control** \* *control*, **ft\_control\_aslider\_callback** *callback* )

Parameters

<i>control</i>	Pointer to the control.
<i>callback</i>	Address of the function to be invoked.

Returns

none


Register the specified callback function as the Analog Slider events handler. If the callback parameter is NULL, the callback is disabled. Example:

```

/*
* //Create the callback function for aslider
* static void my_aslider_cb(const struct ft_control *control,
*                           enum ft_control_aslider_event event,
*                           uint32_t position)
* {
*   (void)control;
*   char* event_names[] =
*   {
*     "FT_ASIDER_MOVEMENT",
*     "FT_ASIDER_ALL_RELEASE",
*     "FT_ASIDER_INITIAL_TOUCH",
*   };
*   printf("New analog slider control event %s on position: %d.", event_names[event], position);
* }

// register the callback function for aslider movement
ft_control_aslider_register_callback(&my_aslider_control,
                                    my_aslider_cb);
  
```

Here is the call graph for this function:



## Overview

### 7.1.3 Keypad Control

#### 7.1.3.1 Overview

Keypad implements the keyboard-like functionality on top of an array of electrodes; it is represented by the [ft\\_control\\_keypad](#) structure.

The application may use the Electrode API to determine the touch or release states of individual electrodes. The Keypad simplifies this task, and extends this simple scenario by introducing a concept of a "key". The "key" is represented by one or more physical electrodes, therefore the Keypad control enables sharing of one electrode by several keys. Each key is defined by a set of electrodes that all must be touched, in order to report the "key press" event.

The Keypad Control provides the Key status values and is able to generate Key Touch, Auto-repeat, and Release events.

The figures below show simple and grouped Keypad electrode layouts.




Figure 7.1.3: Keypad Electrodes

Collaboration diagram for Keypad Control:



## Modules

- Keypad Control API

## Data Structures

- struct `ft_control_keypad`

## TypeDefs

- `typedef void(* ft_control_keypad_callback )(const struct ft_control *control, enum ft_control_keypad_event event, uint32_t index)`

## Enumerations

- enum `ft_control_keypad_event` {  
    `FT_KEYPAD_RELEASE`,  
    `FT_KEYPAD_TOUCH`,  
    `FT_KEYPAD_AUTOREPEAT` }

## Variables

- struct `ft_control_interface ft_control_keypad_interface`

### 7.1.3.2 Data Structure Documentation


#### 7.1.3.2.1 struct `ft_control_keypad`

The main structure representing the Keypad Control.

An instance of this data type represents the Keypad Control. You must initialize all the members before registering the control in the system. This structure can be allocated in ROM.

## Overview

Collaboration diagram for ft\_control\_keypad:



### Data Fields

uint32_t const *	groups	Pointer to the group definitions. An array of integers, where bits in the integer represents electrodes in a group.
uint8_t	groups_size	Number of groups.

### 7.1.3.3 Typedef Documentation

**7.1.3.3.1 `typedef void(* ft_control_keypad_callback)(const struct ft_control *control, enum ft_control_keypad_event event, uint32_t index)`**

Keypad event callback function pointer type.

### 7.1.3.4 Enumeration Type Documentation

**7.1.3.4.1 `enum ft_control_keypad_event`**

Keypad event types.

Enumerator

*FT\_KEYPAD\_RELEASE* Release event  
*FT\_KEYPAD\_TOUCH* Key-touch event  
*FT\_KEYPAD\_AUTOREPEAT* Auto-repeat event

### 7.1.3.5 Variable Documentation

#### 7.1.3.5.1 `struct ft_control_interface ft_control_keypad_interface`

An interface structure, which contains pointers to the entry points of the Keypad algorithms. A pointer to this structure must be assigned to any instance of the `ft_control_keypad`, to define the control behavior.

## Overview

### 7.1.3.6 Keypad Control API

#### 7.1.3.6.1 Overview

These functions can be used to set or get the Keypad control properties.

A common example defition of the Keypad control for all source code examples is as follows:

```
* // definition of electrode array used by control (more info in electrodes )
* const struct ft_electrode * const control_0_electrodes[] = {&electrode_0, &electrode_1,
*   &electrode_2, &electrode_3, NULL};
*
* const struct ft_control_keypad keypad_params =
* {
*   .groups = NULL,
*   .groups_size = 0,
* };
*
* // Definition of rotary control
* const struct ft_control my_keypad_control =
* {
*   .interface = &ft_control_keypad_control_interface,
*   .electrodes = control_0_electrodes,
*   .control_params.keypad = keypad_params,
* };
*
*
```

Collaboration diagram for Keypad Control API:



## Functions

- void `ft_control_keypad_only_one_key_valid` (const struct `ft_control` \*control, uint32\_t enable)  
*Enable or disable the functionality that only one key press is valid.*
- void `ft_control_keypad_register_callback` (const struct `ft_control` \*control, `ft_control_keypad_callback` callback)  
*Registers the Keypad event handler function.*
- void `ft_control_keypad_set_autorepeat_rate` (const struct `ft_control` \*control, uint32\_t value, uint32\_t start\_value)  
*Set the auto-repeat rate.*
- uint32\_t `ft_control_keypad_get_autorepeat_rate` (const struct `ft_control` \*control)  
*Get the auto-repeat rate.*
- uint32\_t `ft_control_keypad_is_button_touched` (const struct `ft_control` \*control, uint32\_t index)  
*Get the button touch status.*

### 7.1.3.6.2 Function Documentation

7.1.3.6.2.1 `uint32_t ft_control_keypad_get_autorepeat_rate ( const struct ft_control * control )`

## Overview

### Parameters


<i>control</i>	Pointer to the Keypad control.
----------------	--------------------------------

### Returns

The auto-repeat value or 0 when this feature is disabled. Example:

```
*     uint32_t autorepeat_rate;
* //Get autorepeat rate
*     autorepeat_rate = ft_control_keypad_get_autorepeat_rate(&
*         my_keypad_control);
*     printf("Auto-repeat rate of my keypad control is set to : %d.", autorepeat_rate);
*
```

Here is the call graph for this function:



### 7.1.3.6.2.2 uint32\_t ft\_control\_keypad\_is\_button\_touched ( const struct ft\_control \* *control*, uint32\_t *index* )

### Parameters

<i>control</i>	Pointer to the Keypad control.
<i>index</i>	The button's number (index) in the control.


### Returns

1 if the button is touched, 0 otherwise.

Returns the state of the keypad button. In case there are groups defined, the touch state reflects that all electrodes forming one button are touched. Otherwise, a button is in the release state. Example:

```
*     uint32_t touched;
* // Get the state of first key Keypad control
*     touched = ft_control_keypad_is_button_touched(&my_keypad_control, 0);
*     if(touched)
*         printf("The first key of the Keypad control is currently touched.");
*     else
*         printf("The first key of the Keypad control is currently not touched.");
*
```

Here is the call graph for this function:



#### 7.1.3.6.2.3 void ft\_control\_keypad\_only\_one\_key\_valid ( const struct ft\_control \* control, uint32\_t enable )

Parameters

<i>control</i>	Pointer to the control.
<i>enable</i>	enable the only one key pressed is valid.

Returns


none

Enable or Disable the only one key press is valid at once. The behavior is following: Once the feature is enabled the first touched key is valid and all other are ignored since the active electrode is pressed.  
Example:

```

/*
* // switch off the only one key is valid functionality
* ft_control_keypad_only_one_key_valid(&my_keypad_control, 0);
*/
  
```

Here is the call graph for this function:



#### 7.1.3.6.2.4 void ft\_control\_keypad\_register\_callback ( const struct ft\_control \* control, ft\_control\_keypad\_callback callback )

## Overview

Parameters

<i>control</i>	Pointer to the control.
<i>callback</i>	Address of function to be invoked.

Returns

none


Register the specified callback function as the KeyPad event handler. If the callback parameter is NULL, the callback is disabled. Example:

```

/*
* //Create the callback function for keypad
* static void my_keypad_cb(const struct ft_control *control,
*                         enum ft_control_keypad_event event,
*                         uint32_t index)
* {
*     (void)control;
*     char* event_names[] =
*     {
*         "FT_KEYPAD_RELEASE",
*         "FT_KEYPAD_TOUCH",
*         "FT_KEYPAD_AUTOREPEAT",
*     };
*
*     printf("New keypad control event %s on key: %d.", event_names[event], index);
* }
*
* // register the callback function for keypad
* ft_control_keypad_register_touch_callback(&my_keypad_control, my_keypad_touch_cb);
*/

```

Here is the call graph for this function:



### 7.1.3.6.2.5 void **ft\_control\_keypad\_set\_autorepeat\_rate** ( const struct **ft\_control** \* **control**, uint32\_t **value**, uint32\_t **start\_value** )

## Parameters


<i>control</i>	Pointer to the Keypad control.
<i>value</i>	Auto-repeat value. Value 0 disables the auto-repeat feature.
<i>value</i>	Auto-repeat start value. Value 0 disables the auto-repeat start feature.

## Returns

none Example:

```
* //Set autorepeat rate to 100 ticks and start after 1000 ticks
* ft_control_keypad_set_autorepeat_rate(&my_keypad_control, 100, 1000
    );
*
```

Here is the call graph for this function:



## Overview

### 7.1.4 Matrix Control

#### 7.1.4.1 Overview

Matrix enables the detection of... It is currently not yet implemented.

The figure below shows a typical Matrix electrode placement.




Figure 7.1.4: Rotary Electrodes

Collaboration diagram for Matrix Control:



## Modules

- Matrix Control API

#### 7.1.4.2 Matrix Control API

These functions can be used to set or get the Matrix control properties.

A common example definition of the Matrix control for all source code examples is as follows:

\*

Collaboration diagram for Matrix Control API:



## Overview

### 7.1.5 Rotary Control

#### 7.1.5.1 Overview

The Rotary control enables the detection of jog-dial-like finger movement using discrete electrodes; it is represented by the `ft_control_rotary_control` structure.

The Rotary control uses a set of discrete electrodes to enable the calculation of finger position within a circular area. The position algorithm localizes the touched electrode and its sibling electrodes, to estimate the finger position. A Rotary control consisting of N electrodes enables the rotary position to be calculated in  $2N$  steps.

The Rotary control provides Position, Direction, and Displacement values. It is able to generate event callbacks when the finger Movement, Initial-touch, or Release is detected.

The figure below shows a typical Rotary electrode placement.




Figure 7.1.5: Rotary Electrodes

Collaboration diagram for Rotary Control:



## Modules

- [Rotary Control API](#)

## Typedefs

- `typedef void(* ft_control_rotary_callback )(const struct ft_control *control, enum ft_control_rotary_event, uint32_t position)`

## Enumerations

- `enum ft_control_rotary_event { FT_ROTARY_MOVEMENT, FT_ROTARY_ALL_RELEASE, FT_ROTARY_INITIAL_TOUCH }`

## Variables

- `struct ft_control_interface ft_control_rotary_interface`

### 7.1.5.2 Typedef Documentation

#### 7.1.5.2.1 `typedef void(* ft_control_rotary_callback)(const struct ft_control *control, enum ft_control_rotary_event, uint32_t position)`

Rotary event callback function pointer type.

### 7.1.5.3 Enumeration Type Documentation

#### 7.1.5.3.1 `enum ft_control_rotary_event`

Rotary event types.

Enumerator

`FT_ROTARY_MOVEMENT` Finger movement event

`FT_ROTARY_ALL_RELEASE` Release event

`FT_ROTARY_INITIAL_TOUCH` Initial-touch event

### 7.1.5.4 Variable Documentation

#### 7.1.5.4.1 `struct ft_control_interface ft_control_rotary_interface`

The interface structure, which contains pointers to the entry points of the Rotary algorithms. A pointer to this structure must be assigned to any instance of `ft_control_rotary_control` to define the control behavior.

## Overview

### 7.1.5.5 Rotary Control API

#### 7.1.5.5.1 Overview

These functions can be used to set or get the Rotary control properties.

The common example defition of Rotary control for all source code examples is as follows:

```
* // definition of electrode array used by control (more info in electrodes )
* const struct ft_electrode * const control_0_electrodes[] = {&electrode_0, &electrode_1,
*   &electrode_2, &electrode_3, NULL};
*
* // Definition of the Rotary control
* const struct ft_control my_rotary_control =
* {
*   .interface = &ft_control_rotary_interface,
*   .electrodes = control_0_electrodes,
* };
*
```

Collaboration diagram for Rotary Control API:



## Functions

- void `ft_control_rotary_register_callback` (const struct `ft_control` \*control, `ft_control_rotary_callback` callback)
   
*Registers the events handler function.*
- `uint32_t ft_control_rotary_get_position` (const struct `ft_control` \*control)
   
*Get the Rotary 'Position' value.*
- `uint32_t ft_control_rotary_is_touched` (const struct `ft_control` \*control)
   
*Get 'Touched' state.*
- `uint32_t ft_control_rotary_movement_detected` (const struct `ft_control` \*control)
   
*Get 'Movement' flag.*
- `uint32_t ft_control_rotary_get_direction` (const struct `ft_control` \*control)
   
*Get 'Direction' flag.*
- `uint32_t ft_control_rotary_get_invalid_position` (const struct `ft_control` \*control)
   
*Get 'Invalid' flag.*

#### 7.1.5.5.2 Function Documentation

##### 7.1.5.5.2.1 `uint32_t ft_control_rotary_get_direction ( const struct ft_control * control )`

## Parameters


<i>control</i>	Pointer to the control.
----------------	-------------------------

## Returns

Non-zero value, when a movement is detected in a direction towards higher values. Returns zero, when a movement is detected towards zero. Example:

```
* uint32_t direction;
* // Get direction of rotary control
* direction = ft_control_rotary_get_direction(&my_rotary_control);
* if(direction)
*     printf("The Rotary direction is left.");
* else
*     printf("The Rotary direction is right.");
*
```

Here is the call graph for this function:



### 7.1.5.5.2.2 `uint32_t ft_control_rotary_get_invalid_position ( const struct ft_control * control )`

## Parameters

<i>control</i>	Pointer to the control.
----------------	-------------------------


## Returns

Non-zero value when an invalid position was detected, otherwise a zero value. Example:

```
* uint32_t invalid_position;
* // Get invalid position of Rotary control
* invalid_position = ft_control_rotary_get_invalid_position(&
*     my_rotary_control);
* if(invalid_position)
*     printf("The Rotary control has an invalid position (two fingers touch ?).");
* else
*     printf("The Rotary control has a valid position.");
*
```

## Overview

Here is the call graph for this function:



### 7.1.5.5.2.3 uint32\_t ft\_control\_rotary\_get\_position ( const struct ft\_control \* control )

Parameters

<i>control</i>	Pointer to the control.
----------------	-------------------------

Returns


Position. The returned value is in the range of zero to  $2N-1$ , where  $N$  is the number of electrodes assigned to Rotary control.

This function retrieves the actual finger position value. Example:

```

* uint32_t position;
* // Get position of Rotary control
* position = ft_control_rotary_get_position(&my_rotary_control);
* printf("Position of Rotary control is: %d.", position);
*
  
```

Here is the call graph for this function:



### 7.1.5.5.2.4 uint32\_t ft\_control\_rotary\_is\_touched ( const struct ft\_control \* control )

## Parameters


<i>control</i>	Pointer to the control.
----------------	-------------------------

## Returns

Non-zero value, when the control is currently touched. Example:

```
* uint32_t touched;
* // Get state of the Rotary control
* touched = ft_control_rotary_is_touched(&my_rotary_control);
* if(touched)
*     printf("The Rotary control is currently touched.");
* else
*     printf("The Rotary control is currently not touched.");
*
```

Here is the call graph for this function:



### 7.1.5.5.2.5 uint32\_t ft\_control\_rotary\_movement\_detected ( const struct ft\_control \* *control* )

## Parameters

<i>control</i>	Pointer to the control.
----------------	-------------------------


## Returns

Non-zero value, when the control detects finger movement. Example:

```
* uint32_t movement;
* // Get state of rotary control
* movement = ft_control_rotary_movement_detected(&my_rotary_control);
* if(movement)
*     printf("The Rotary control is currently moving.");
* else
*     printf("The Rotary control is currently not moving.");
*
```

## Overview

Here is the call graph for this function:



### 7.1.5.5.2.6 void `ft_control_rotary_register_callback` ( `const struct ft_control * control,` `ft_control_rotary_callback callback` )

Parameters

<code>control</code>	Pointer to the control.
<code>callback</code>	Address of function to be invoked.

Returns

none


Register the specified callback function as the Rotary events handler. Example:

```

/*
* //Create the callback function for arotary
* static void my_rotary_cb(const struct ft_control *control,
*                         enum ft_control_arotary_event event,
*                         uint32_t position)
* {
*     (void)control;
*     char* event_names[] =
*     {
*         "FT_ROTARY_MOVEMENT",
*         "FT_ROTARY_ALL_RELEASE",
*         "FT_ROTARY_INITIAL_TOUCH",
*     };
*     printf("New rotary control event %s on position: %d.", event_names[event], position);
* }
*
* // register the callback function for rotary
* ft_control_rotary_register_callback(&my_rotary_control, my_rotary_cb)
* ;
*

```

Here is the call graph for this function:



## Overview

### 7.1.6 Slider control

#### 7.1.6.1 Overview

Slider control enables the detection of linear finger movement using discrete electrodes; it is represented by the [ft\\_control](#) structure.

The Slider control uses a set of discrete electrodes to enable calculation of the finger position within a linear area. The position algorithm localizes the touched electrode and its sibling electrodes to estimate finger position. A Slider consisting of N electrodes enables the position to be calculated in  $2N-1$  steps.

The Slider control provides Position, Direction, and Displacement values. It is able to generate event callbacks when finger Movement, Initial-touch, or Release is detected.

The image below shows a typical Slider electrode placement.



Figure 7.1.6: Slider Electrodes

Collaboration diagram for Slider control:



## Modules

- [Slider Control API](#)

## TypeDefs

- `typedef void(* ft_control_slider_callback)(const struct ft_control *control, enum ft_control_slider_event, uint32_t position)`

## Enumerations

- `enum ft_control_slider_event { FT_SLIDER_MOVEMENT, FT_SLIDER_ALL_RELEASE, FT_SLIDER_INITIAL_TOUCH }`

## Variables

- `struct ft_control_interface ft_control_slider_interface`

### 7.1.6.2 TypeDef Documentation

#### 7.1.6.2.1 `typedef void(* ft_control_slider_callback)(const struct ft_control *control, enum ft_control_slider_event, uint32_t position)`

Slider event callback function pointer type.

### 7.1.6.3 Enumeration Type Documentation

#### 7.1.6.3.1 `enum ft_control_slider_event`

Slider event types.

Enumerator

`FT_SLIDER_MOVEMENT` Finger movement event.

`FT_SLIDER_ALL_RELEASE` Release event.

`FT_SLIDER_INITIAL_TOUCH` Initial-touch event.

### 7.1.6.4 Variable Documentation

#### 7.1.6.4.1 `struct ft_control_interface ft_control_slider_interface`

An interface structure, which contains pointers to the entry points of Slider algorithms. A pointer to this structure must be assigned to any instance of `ft_control_slider_control` to define the control behavior.

## Overview

### 7.1.6.5 Slider Control API

#### 7.1.6.5.1 Overview

These functions can be used to set or get the Slider control properties.

A common example definition of the Slider control for all source code examples is as follows:

```
* // Definition of the electrode array used by the control (more info in electrodes)
* const struct ft_electrode * const control_0_electrodes[] = {&electrode_0, &electrode_1,
*     NULL};
*
* // Definition of the Slider control
* const struct ft_control my_slider_control =
* {
*     .interface = &ft_control_slider_interface,
*     .electrodes = control_0_electrodes,
* };
*
```

Collaboration diagram for Slider Control API:



## Functions

- void **ft\_control\_slider\_register\_callback** (const struct **ft\_control** \*control, **ft\_control\_slider\_callback** callback)  
*Registers the events handler function.*
- uint32\_t **ft\_control\_slider\_get\_position** (const struct **ft\_control** \*control)  
*Get the Slider 'Position' value.*
- uint32\_t **ft\_control\_slider\_is\_touched** (const struct **ft\_control** \*control)  
*Get 'Touched' state.*
- uint32\_t **ft\_control\_slider\_movement\_detected** (const struct **ft\_control** \*control)  
*Get 'Movement' flag.*
- uint32\_t **ft\_control\_slider\_get\_direction** (const struct **ft\_control** \*control)  
*Get 'Direction' flag.*
- uint32\_t **ft\_control\_slider\_get\_invalid\_position** (const struct **ft\_control** \*control)  
*Get 'Invalid' flag.*

#### 7.1.6.5.2 Function Documentation

##### 7.1.6.5.2.1 uint32\_t ft\_control\_slider\_get\_direction ( const struct ft\_control \* control )

## Parameters


<i>control</i>	Pointer to the control.
----------------	-------------------------

## Returns

Non-zero value, when a movement is detected in a direction towards higher values. Returns zero, when a movement towards zero is detected. Example:

```
* uint32_t direction;
* // Get direction of Slider control
* direction = ft_control_slider_get_direction(&my_slider_control);
* if(direction)
*     printf("The Slider direction is left.");
* else
*     printf("The Slider direction is right.");
*
```

Here is the call graph for this function:



### 7.1.6.5.2.2 `uint32_t ft_control_slider_get_invalid_position ( const struct ft_control * control )`

## Parameters

<i>control</i>	Pointer to the control.
----------------	-------------------------


## Returns

Non-zero value, when an invalid position was detected, otherwise zero. Example:

```
* uint32_t invalid_position;
* // Get invalid position of Slider control
* invalid_position = ft_control_slider_get_invalid_position(&
*     my_slider_control);
* if(invalid_position)
*     printf("The Slider control has an invalid position (two fingers touch ?).");
* else
*     printf("The Slider control has a valid position.");
*
```

## Overview

Here is the call graph for this function:



### 7.1.6.5.2.3 uint32\_t ft\_control\_slider\_get\_position ( const struct ft\_control \* control )

Parameters

<i>control</i>	Pointer to the control.
----------------	-------------------------

Returns


Position. The returned value is in the range of zero to the maximum value configured in the `ft_control` structure.

This function retrieves the actual finger position value. Example:

```

* uint32_t position;
* // Get position of Slider control
* position = ft_control_slider_get_position(&my_slider_control);
* printf("Position of Slider control is: %d.", position);
*
  
```

Here is the call graph for this function:



### 7.1.6.5.2.4 uint32\_t ft\_control\_slider\_is\_touched ( const struct ft\_control \* control )

## Parameters


<i>control</i>	Pointer to the control.
----------------	-------------------------

## Returns

Non-zero value, when the control is currently touched. Example:

```
* uint32_t touched;
* // Get state of Slider control
* touched = ft_control_slider_is_touched(&my_slider_control);
* if(touched)
*     printf("The Slider control is currently touched.");
* else
*     printf("The Slider control is currently not touched.");
*
```

Here is the call graph for this function:



### 7.1.6.5.2.5 uint32\_t ft\_control\_slider\_movement\_detected ( const struct ft\_control \* *control* )

## Parameters

<i>control</i>	Pointer to the control.
----------------	-------------------------


## Returns

Non-zero value, when the control detects finger movement. Example:

```
* uint32_t movement;
* // Get state of Slider control
* movement = ft_control_slider_movement_detected(&my_slider_control);
* if(movement)
*     printf("The Slider control is currently moving.");
* else
*     printf("The Slider control is currently not moving.");
*
```

## Overview

Here is the call graph for this function:



### 7.1.6.5.2.6 void **ft\_control\_slider\_register\_callback** ( const struct **ft\_control** \* *control*, **ft\_control\_slider\_callback** *callback* )

Parameters

<i>control</i>	Pointer to the control.
<i>callback</i>	Address of function to be invoked.

Returns


none

Register the specified callback function as the Slider events handler. Example:

```

/*
* //Create the callback function for aslider
* static void my_slider_cb(const struct ft_control *control,
*                         enum ft_control_aslider_event event,
*                         uint32_t position)
* {
*     (void)control;
*     char* event_names[] =
*     {
*         "FT_SLIDER_MOVEMENT",
*         "FT_SLIDER_ALL_RELEASE",
*         "FT_SLIDER_INITIAL_TOUCH",
*     };
*     printf("New slider control event %s on position: %d.", event_names[event], position);
* }
*
* // register the callback function for slider
* ft_control_slider_register_callback(&my_slider_control, my_slider_cb)
* ;
*/
  
```

Here is the call graph for this function:




## Controls

### 7.2 Controls

#### 7.2.1 Overview

Controls represent the highest level of abstraction in the finger touch evaluation;

Based on the signal and status information coming from the Electrode layer, the controls calculate finger actions like movement, keyboard touch, hold, and so on. Collaboration diagram for Controls:



## Modules

- Analog Rotary Control
- Analog Slider Control
- Keypad Control
- Matrix Control
- Rotary Control
- Slider control
- General API

## 7.2.2 General API

### 7.2.2.1 Overview

General Function definition of controls. Collaboration diagram for General API:



### Modules

- [API Functions](#)

### Data Structures

- union [ft\\_control\\_params](#)
- struct [ft\\_control](#)


### 7.2.2.2 Data Structure Documentation

#### 7.2.2.2.1 union ft\_control\_params

Container, which covers all possible variants of the control parameters. When defining the control setup structure, initialize only one member of this union. Use the member that corresponds to the control type.

## Controls

Collaboration diagram for ft\_control\_params:



### Data Fields


struct <a href="#">ft_-control_arotary</a> *	arotary	
struct <a href="#">ft_-control_aslider</a> *	aslider	
struct <a href="#">ft_-control_keypad</a> *	keypad	

#### 7.2.2.2.2 struct ft\_control

The main structure representing the control instance; this structure is used for all control implementations. The type of the control is specified by the "interface" member, which defines the control behavior. Note that the "control\_params" must correspond to the control type.

This structure can be allocated in ROM.

Collaboration diagram for ft\_control:



## Data Fields

<code>union ft_control_params</code>	<code>control_params</code>	An instance of the control params. Cannot be NULL.
<code>struct ft_electrode *const *</code>	<code>electrodes</code>	List of electrodes. Cannot be NULL.
<code>struct ft_control_interface *</code>	<code>interface</code>	An instance of the control interface. Cannot be NULL.

## Controls

### 7.2.2.3 API Functions

#### 7.2.2.3.1 Overview

General API functions of the controls. Collaboration diagram for API Functions:




## Functions

- void `ft_control_enable` (const struct `ft_control` \*control)  
*Enable control.*
- void `ft_control_disable` (const struct `ft_control` \*control)  
*Disable control.*
- int32\_t `ft_control_get_touch_button` (const struct `ft_control` \*control, uint32\_t index)  
*Get touched electrode.*
- uint32\_t `ft_control_get_electrodes_state` (struct `ft_control` \*control)  
*Get the state of all control electrodes.*
- uint32\_t `ft_control_count_electrodes` (const struct `ft_control` \*control)
- struct `ft_electrode` \* `ft_control_get_electrode` (const struct `ft_control` \*control, uint32\_t index)  
*Return the electrode by index.*

### 7.2.2.3.2 Function Documentation

#### 7.2.2.3.2.1 uint32\_t `ft_control_count_electrodes` ( const struct `ft_control` \* *control* )

Here is the caller graph for this function:



#### 7.2.2.3.2.2 void `ft_control_disable` ( const struct `ft_control` \* *control* )

## Parameters

<i>control</i>	Pointer to the control instance.
----------------	----------------------------------


## Returns

none

Disables the control operation by clearing the FT\_CONTROL\_ENABLE\_FLAG. This is an example of disabling the control in the FT library:

```
* // The FT control my_ft_control_keypad is disabled
* ft_control_disable(&my_ft_control_keypad);
*
```

Here is the call graph for this function:



### 7.2.2.3.2.3 void **ft\_control\_enable** ( const struct **ft\_control** \* *control* )

## Parameters

<i>control</i>	Pointer to the control instance.
----------------	----------------------------------

## Returns


none

Enables the control operation by setting the FT\_CONTROL\_ENABLE\_FLAG. This is an example of enabling the control in the FT library:

```
* // The FT control my_ft_control_keypad is enabled
* ft_control_enable(&my_ft_control_keypad);
*
```

## Controls

Here is the call graph for this function:



### 7.2.2.3.2.4 `struct ft_electrode* ft_control_get_electrode ( const struct ft_control * control, uint32_t index )`

Parameters

<code>control</code>	Pointer to the control.
<code>index</code>	

Returns


Pointer to the electrode instance retrieved from control's electrode list. This is an example of getting the electrode pointer of control by index in the FT library:

```

* // Get the pointer of electrode on index 2 for my_control
* ft_electrode *my_electrode = ft_control_get_electrode(&my_control, 2
    );
*

```

Here is the call graph for this function:



### 7.2.2.3.2.5 `uint32_t ft_control_get_electrodes_state ( struct ft_control * control )`

## Parameters


<i>control</i>	Pointer to the control data.
----------------	------------------------------

## Returns

This function returns a bit-mask value, where each bit represents one control electrode. Logic 1 in the returned value represents a touched electrode.

```
* uint32_t touched_electrode = 0;
* touched_electrode = ft_control_get_electrodes_state(&my_control);
* printf("The electrode state is following: 0x%X in my control.", touched_electrode);
*
```

Here is the call graph for this function:



### 7.2.2.3.2.6 int32\_t ft\_control\_get\_touch\_button ( const struct ft\_control \* *control*, uint32\_t *index* )

## Parameters

<i>control</i>	Pointer to the control.
<i>index</i>	Index of the first electrode to be probed. Use 0 during the first call. Use the last-returned index+1 to get the next touched electrode.

## Returns

Index of the touched electrode, or FT\_FAILURE when no electrode is touched.


Use this function to determine, which control electrodes are currently touched. This is an example of getting the touched electrodes of control in the FT library:

```
* int32_t last_touched_electrode = 0;
* uint32_t electrode_count = ft_control_count_electrodes(&my_control);
* last_touched_electrode = ft_control_get_touch_button(&my_control,
* last_touched_electrode);
* while(last_touched_electrode != FT_FAILURE)
* {
```

## Controls

```
*     printf("The electrode %d in my control is touched", last_touched_electrode);
*     last_touched_electrode = ft_control_get_touch_button(&my_control,
*                                         last_touched_electrode);
* }
*
```

Here is the call graph for this function:



## 7.3 Electrodes

### 7.3.1 Overview

Electrodes are data objects that are used by data-acquisition algorithms to store the per-electrode data, as well as the resulting signal and touch / timestamp information.

Each Electrode provides at minimum the processed and normalized signal value, the baseline value, and touch / timestamp buffer containing the time of last few touch and release events. All such common information are contained in the `ft_electrode` structure type. Also, the electrode contains information about the key detector used to detect touches for this physical electrode (this is a mandatory field in the electrode definition). This has the advantage that each electrode has its own setting of key detector, independent on the module used. It contains information about hardware pin, immediate touch status, and time stamps of the last few touch or release events. Collaboration diagram for Electrodes:



## Modules

- API Functions

## Data Structures

- struct `ft_electrode_status`
- struct `ft_electrode`

## Enumerations

- enum `ft_electrode_state` {  
    `FT_ELECTRODE_STATE_INIT`,  
    `FT_ELECTRODE_STATE_RELEASE`,  
    `FT_ELECTRODE_STATE_TOUCH` }


## Electrodes

### 7.3.2 Data Structure Documentation

#### 7.3.2.1 struct ft\_electrode\_status

Electrode status structure holding one entry in the touch-timestamp buffer. An array of this structure type is a part of each Electrode, and contains last few touch or release events detected on the electrode.

Collaboration diagram for ft\_electrode\_status:



#### Data Fields


uint8_t	state	Electrode's state.
uint32_t	time_stamp	Time stamp.

#### 7.3.2.2 struct ft\_electrode

The main structure representing the Electrode instance. There are all the parameters needed to define the behavior of the Freescale Touch electrode, including its key detector, hardware pins, multiplier / divider to normalize the signal, and the optional shielding electrode.

This structure can be allocated in ROM.

Collaboration diagram for ft\_electrode:



### Data Fields

uint8_t	divider	Divider.
struct <b>ft_keydetector_interface</b> *	keydetector_interface	Pointer to Key Detector interface.

## Electrodes

<code>union ft_keydetector_params</code>	<code>keydetector_params</code>	Pointer to Key Detector params.
<code>uint8_t</code>	<code>multiplier</code>	Multiplier.
<code>uint32_t</code>	<code>pin_input</code>	Input pin.
<code>struct ft_electrode *</code>	<code>shielding_electrode</code>	Shielding electrode.

### 7.3.3 Enumeration Type Documentation

#### 7.3.3.1 enum `ft_electrode_state`

Electrode states.

Enumerator

`FT_ELECTRODE_STATE_INIT` Initial state; Not enough data for the touch-detection algorithm yet.

`FT_ELECTRODE_STATE_RELEASE` Release state; A signal is near to the baseline.

`FT_ELECTRODE_STATE_TOUCH` Touch state; the selected algorithm has decided that a finger is present.

## 7.3.4 API Functions

### 7.3.4.1 Overview

General Function definition of the electrodes. Collaboration diagram for API Functions:



## Functions

- `int32_t ft_electrode_enable (const struct ft_electrode *electrode)`  
*Enable the electrode. The function is used to enable the electrode; it should be used after the FT initialization, because the default state after the startup of the FT is electrode disabled.*
- `int32_t ft_electrode_disable (const struct ft_electrode *electrode)`  
*Disable the electrode.*
- `uint32_t ft_electrode_get_signal (const struct ft_electrode *electrode)`  
*Get the normalized and processed electrode signal.*
- `int32_t ft_electrode_get_last_status (const struct ft_electrode *electrode)`  
*Get the last known electrode status.*
- `uint32_t ft_electrode_get_time_offset (const struct ft_electrode *electrode)`  
*Get the time from the last electrode event.*
- `uint32_t ft_electrode_get_last_time_stamp (const struct ft_electrode *electrode)`  
*Get the last known electrode time stamp.*
- `uint32_t ft_electrode_get_raw_signal (const struct ft_electrode *electrode)`  
*Get the raw electrode signal.*

### 7.3.4.2 Function Documentation

#### 7.3.4.2.1 `int32_t ft_electrode_disable ( const struct ft_electrode * electrode )`

Parameters

<code>electrode</code>	Pointer to the electrode params that identify the electrode.
------------------------	--

## Electrodes

Returns

result of operation **ft\_result**. This is an example of using this function in code:

```
* // Disable electrode_0 that is defined in the setup of FT
* if(ft_electrode_disable(&electrode_0) != FT_SUCCESS)
* {
*     printf("Disable electrode_0 failed.");
* }
*
```

### 7.3.4.2.2 int32\_t ft\_electrode\_enable ( const struct ft\_electrode \* *electrode* )

Parameters

<i>electrode</i>	Pointer to the electrode params that identify the electrode.
------------------	--

Returns

result of operation **ft\_result**. This is an example of using this function in the code:

```
//The electrode that is defined in the setup of FT after the initialization must be enabled.
if (ft_init(&system_0, ft_memory_pool, sizeof(ft_memory_pool)) <
    FT_SUCCESS)
{
    while(1); // add code to handle this error
}
// Enable electrode_0 that is defined in the setup of FT
if(ft_electrode_enable(&electrode_0) != FT_SUCCESS)
{
    printf("Enable electrode_0 failed.");
}
```

### 7.3.4.2.3 int32\_t ft\_electrode\_get\_last\_status ( const struct ft\_electrode \* *electrode* )

Parameters


<i>electrode</i>	Pointer to the electrode data.
------------------	--------------------------------

Returns

Current electrode status.

```
* // Get the latest status of my_electrode
* char * electrode_state_name[3] =
* {
*     "Initialize",
*     "Released",
*     "Touched"
* };
* uint32_t state = ft_electrode_get_last_status(&my_electrode);
* printf("The my_electrode last status is: %s.", electrode_state_name[state]);
*
```

Here is the call graph for this function:



#### 7.3.4.2.4 uint32\_t ft\_electrode\_get\_last\_time\_stamp ( const struct ft\_electrode \* *electrode* )

Parameters

<i>electrode</i>	Pointer to the electrode data.
------------------	--------------------------------


Returns

Current electrode status.

```

* // Get the time stamp of the last change of the electrode status
* uint32_t time = ft_electrode_get_last_time_stamp(&my_electrode);
* printf("The my_electrode last status change was at: %d ms .", time);
*
  
```

Here is the call graph for this function:



#### 7.3.4.2.5 uint32\_t ft\_electrode\_get\_raw\_signal ( const struct ft\_electrode \* *electrode* )

## Electrodes

Parameters

<i>electrode</i>	Pointer to the electrode data.
------------------	--------------------------------


Returns

electrode Signal, as it is measured by the physical module.

The raw signal is used internally by the filtering and normalization algorithms to calculate the real electrode signal value, which is good to be compared with the signals coming from other electrodes.

```
* // Get the current raw signal of my_electrode
* printf("The my_electrode has raw signal: %d.", ft_electrode_get_raw_signal(&
    my_electrode));
*
```

Here is the call graph for this function:



### 7.3.4.2.6 uint32\_t ft\_electrode\_get\_signal ( const struct ft\_electrode \* *electrode* )

Parameters

<i>electrode</i>	Pointer to the electrode data.
------------------	--------------------------------


Returns

electrode signal calculated from the last raw value measured.

The signal value is calculated from the raw electrode capacitance or other physical signal by applying the filtering and normalization algorithms. This signal is used by the "analog" [Controls](#) that estimate the finger position based on the signal value, rather than on a simple touch / release status. This is an example of using this function in the code:

```
* // Get current signal of my_electrode
* printf("The my_electrode has signal: %d.", ft_electrode_get_signal(&my_electrode)
      );
*
```

Here is the call graph for this function:



#### 7.3.4.2.7 `uint32_t ft_electrode_get_time_offset ( const struct ft_electrode * electrode )`

Parameters


<code>electrode</code>	Pointer to the electrode data.
------------------------	--------------------------------

Returns

Time from the last electrode event.

```
* // Get the time offset from the last change of the electrode status
* uint32_t offset = ft_electrode_get_time_offset(&my_electrode);
* printf("The my_electrode last status change has been before: %d ms .", offset);
*
```

Here is the call graph for this function:



## Filters

### 7.4 Filters

#### 7.4.1 Overview

The filters data structure that is used in the Freescale Touch library. Collaboration diagram for Filters:



#### Data Structures

- struct `ft_filter_fbutt`
- struct `ft_filter_iir`
- struct `ft_filter_dctracker`
- struct `ft_filter_moving_average`

#### Macros


- #define `FT_FILTER_MOVING_AVERAGE_MAX_ORDER`

#### 7.4.2 Data Structure Documentation

##### 7.4.2.1 struct `ft_filter_fbutt`

The butterworth filter input parameters.

Collaboration diagram for `ft_filter_fbutt`:



## Data Fields

int32_t	cutoff	The coefficient for the implemented butterworth filter polynomial.
---------	--------	--

#### 7.4.2.2 struct ft\_filter\_iir

The IIR filter input parameters.

Collaboration diagram for ft\_filter\_iir:




## Data Fields

uint8_t	coef1	Scale of the current and previous signals. When the coef is higher, the current signal has less strength.
---------	-------	---

#### 7.4.2.3 struct ft\_filter\_dctracker

The DC tracker filter input parameters.

Collaboration diagram for ft\_filter\_dctracker:



## Filters


Data Fields

uint8_t	rate	Rate of how fast the baseline is updated. The rate should be defined as a modulo of the system period.
---------	------	--

### 7.4.2.4 struct ft\_filter\_moving\_average

The moving average filter input parameters.

Collaboration diagram for ft\_filter\_moving\_average:



Data Fields

int32_t	n2_order	The order $2^n$ moving average filter
---------	----------	---------------------------------------


### 7.4.3 Macro Definition Documentation

#### 7.4.3.1 #define FT\_FILTER\_MOVING\_AVERAGE\_MAX\_ORDER

## 7.4.4 Advanced Filtering and Integrating Detection

### 7.4.4.1 Overview

The AFID (Advanced Filtering and Integrating Detection) key detector is based on using two IIR filters with different depths (one short / fast, the other long / slow) and on integrating the difference between the two filtered signals. The algorithm uses two thresholds: the touch threshold and the release threshold. The touch threshold is defined in the sensitivity register. The release threshold has a twice lower level than the touch threshold. If the integrated signal is higher than the touch threshold, or lower than the release threshold, then the integrated signal is reset. The touch state is reported for the electrode when the first touch reset is detected. The release state is reported when as many release resets are detected as the touch resets were detected during the previous touch state. Collaboration diagram for Advanced Filtering and Integrating Detection:



### Data Structures

- struct [ft\\_keydetector\\_afid\\_asc](#)
- struct [ft\\_keydetector\\_afid](#)

### Macros

- #define [FT\\_KEYDETECTOR\\_AFID\\_ASC\\_DEFAULT](#)

### Variables

- struct [ft\\_keydetector\\_interface](#) [ft\\_keydetector\\_afid\\_interface](#)


### 7.4.4.2 Data Structure Documentation

#### 7.4.4.2.1 struct [ft\\_keydetector\\_afid\\_asc](#)

AFID Automatic Sensitive Calibration structure; This structure is used to define the parameters of evaluating the AFID process flow. You can manage your own setup of parameters, or use the default setting in the [FT\\_KEYDETECTOR\\_AFID\\_ASC\\_DEFAULT](#). This structure must be filled in.

## Filters

Collaboration diagram for ft\_keydetector\_afid\_asc:



### Data Fields


uint32_t	noise_resets_- minimum	Noise Resets Minimum
int16_t	resets_for_- touch	Number of resets required for touch
int16_t	touch_threshold- _fall_rate	Rate of how often the touch threshold can fall

#### 7.4.4.2.2 struct ft\_keydetector\_afid

The main structure representing the AFID key detector. An instance of this data type represents the AFID key detector. Consisting of parameters of filters, the AFID automatic sensitive calibration, and update rate.

You're responsible to initialize all the members before registering the AFID in the module. This structure can be allocated in ROM.

Collaboration diagram for ft\_keydetector\_afid:



## Data Fields

struct <a href="#">ft_keydetector_afid_asc</a>	asc	ASC structure for the AFID detector.
struct <a href="#">ft_filter_moving_average</a>	base_avrg	Settings of the moving avarage filter for the baseline in release state of electrode.
struct <a href="#">ft_filter_fbutt</a>	fast_signal_filter	Signal butterworth signal (fast).
uint16_t	reset_rate	
struct <a href="#">ft_filter_iir</a>	signal_filter	Coficient of the input IIR signal filter, used to supress high frequency noise.
struct <a href="#">ft_filter_fbutt</a>	slow_signal_filter	Baseline butterworth signal (slow).

### 7.4.4.3 Macro Definition Documentation

#### 7.4.4.3.1 #define FT\_KEYDETECTOR\_AFID\_ASC\_DEFAULT

AFID Automatic Sensitive Calibration default ASC settings:

- touch\_threshold\_fall\_rate (default 255)
- noise\_resets\_minimum (default 128)
- resets\_for\_touch (default 6) This default values for AFID ASC definition for example:

```
const struct ft_keydetector_afid keydec =
```

## Filters

```
{  
    .signal_filter = {  
        .cutoff = 8  
    },  
    .baseline_filter = {  
        .cutoff = 4  
    },  
    .reset_rate = 1000,  
    .asc = FT_KEYDETECTOR_AFID_ASC_DEFAULT,  
};
```

### 7.4.4.4 Variable Documentation

#### 7.4.4.4.1 struct ft\_keydetector\_interface ft\_keydetector\_afid\_interface

AFID key detector interface structure.


## 7.5 Key Detectors

### 7.5.1 Overview

Key Detectors represent different types of signal-processing algorithms; the primary purpose of a key detector algorithm is to determine, whether an electrode has been touched or not, calculate the normalized signal, and provide all these information to the [Controls](#) layer. The Controls layer is then able to detect much more complex finger gestures, such as a slider swing or a key press within a multiplexed keypad.

As an input, the Key Detector gets the raw electrode signal value obtained from the data-acquisition algorithm, wrapped by one of the [Modules](#) instance. The output values and intermediate calculated parameters needed by the Key Detector layer are contained within a structure type, derived from the [ft\\_electrode](#) type. See more information in the [Electrodes](#) chapter.

In addition to signal processing, the Key Detector also detects, reports, and acts on fault conditions during the scanning process. Two main fault conditions are reported as electrode short-circuit to supply voltage (capacitance too small), or short-circuit to ground (capacitance too high). Collaboration diagram for Key Detectors:



## Modules

- [Advanced Filtering and Integrating Detection](#)

## Key Detectors

### 7.5.2 GPIO module

#### 7.5.2.1 Overview

GPIO module uses the MCU's General Purpose pins and Timer. Collaboration diagram for GPIO module:



#### Data Structures

- struct `ft_module_gpio_user_interface`
- struct `ft_module_gpio_params`

#### Variables


- struct `ft_module_interface ft_module_gpio_interface`

#### 7.5.2.2 Data Structure Documentation

##### 7.5.2.2.1 struct `ft_module_gpio_user_interface`

Gpio user's interface, which is used by the GPIO modules. All of these functions must be implemented in the application.

Collaboration diagram for ft\_module\_gpio\_user\_interface:



## Data Fields

- `void(* set_pin_output )(uint32_t port, uint32_t pin)`
- `void(* set_pin_input )(uint32_t port, uint32_t pin)`
- `void(* set_pin_low )(uint32_t port, uint32_t pin)`
- `void(* set_pin_high )(uint32_t port, uint32_t pin)`
- `uint32_t(* get_pin_value )(uint32_t port, uint32_t pin)`
- `void(* set_pin_default_state )(uint32_t port, uint32_t pin)`
- `void(* init_timer )(void)`
- `void(* start_timer )(void)`
- `void(* stop_timer )(void)`
- `void(* timer_reset_counter )(void)`
- `uint32_t(* timer_get_counter )(void)`
- `uint32_t(* timer_get_overrun )(void)`

### 7.5.2.2.1.1 Field Documentation

#### 7.5.2.2.1.1.1 `uint32_t(* ft_module_gpio_user_interface::get_pin_value)(uint32_t port, uint32_t pin)`

Get pin value

#### 7.5.2.2.1.1.2 `void(* ft_module_gpio_user_interface::init_timer)(void)`

Init timer

## Key Detectors

**7.5.2.2.1.1.3 void(\* ft\_module\_gpio\_user\_interface::set\_pin\_default\_state)(uint32\_t port, uint32\_t pin)**

Set pin to default state when it's not being measured

**7.5.2.2.1.1.4 void(\* ft\_module\_gpio\_user\_interface::set\_pin\_high)(uint32\_t port, uint32\_t pin)**

Set pin to logic high

**7.5.2.2.1.1.5 void(\* ft\_module\_gpio\_user\_interface::set\_pin\_input)(uint32\_t port, uint32\_t pin)**

Set pin direction to input

**7.5.2.2.1.1.6 void(\* ft\_module\_gpio\_user\_interface::set\_pin\_low)(uint32\_t port, uint32\_t pin)**

Set pin to logic low

**7.5.2.2.1.1.7 void(\* ft\_module\_gpio\_user\_interface::set\_pin\_output)(uint32\_t port, uint32\_t pin)**

Set pin direction to output

**7.5.2.2.1.1.8 void(\* ft\_module\_gpio\_user\_interface::start\_timer)(void)**

Start timer

**7.5.2.2.1.1.9 void(\* ft\_module\_gpio\_user\_interface::stop\_timer)(void)**

Stop timer

**7.5.2.2.1.1.10 uint32\_t(\* ft\_module\_gpio\_user\_interface::timer\_get\_counter)(void)**

Get timer counter

**7.5.2.2.1.1.11 uint32\_t(\* ft\_module\_gpio\_user\_interface::timer\_get\_overrun)(void)**

Get timer overrun


**7.5.2.2.1.1.12 void(\* ft\_module\_gpio\_user\_interface::timer\_reset\_counter)(void)**

Reset timer counter

## 7.5.2.2 struct ft\_module\_gpio\_params

GPIO module, which uses the ??interrupts? port to sample a signal from the running timer counter.

Collaboration diagram for ft\_module\_gpio\_params:



## Data Fields

<code>struct ft_module_ gpio_user_ interface *</code>	<code>user_interface</code>	
---	-----------------------------	--

### 7.5.2.3 Variable Documentation

#### 7.5.2.3.1 struct ft\_module\_interface ft\_module\_gpio\_interface

Can't be NULL.


interface gpio module

## Key Detectors

### 7.5.3 GPIO interrupt module

#### 7.5.3.1 Overview

The GPIO module uses the General Purpose pins and Timer of the MCU. Works on GPIO pins with interrupt. Collaboration diagram for GPIO interrupt module:



## Data Structures

- struct [ft\\_module\\_gpioint\\_user\\_interface](#)
- struct [ft\\_module\\_gpioint\\_params](#)

## Functions

- void [ft\\_module\\_gpioint\\_isr](#)(const struct [ft\\_module](#) \*module)

*This interrupt handler must be invoked from the user's port interrupt ISR. There can be other pins on the same port which can invoke the interrupt; therefore, it is up to the application to decode which pin caused the interrupt. For example, if there's a button on the PTA3 and an electrode on the PTA4, the PORTA ISR handler must decode, whether the interrupt was caused by the PTA3 or PTA4. Invoke the [ft\\_module\\_gpioint\\_isr\(\)](#) only if any of the GPIO modules' electrodes caused an interrupt.*

- void [ft\\_module\\_gpioint\\_overflow\\_isr](#)(const struct [ft\\_module](#) \*module)

*This interrupt handler should be invoked from the user's timer interrupt ISR. It is not mandatory to call this function, but it's designed to avoid, stuck to the Freescale Touch GPIO Interrupt module. It should be called after the user-defined maximal timeout for one measurement.*

## Variables


- struct [ft\\_module\\_interface](#) [ft\\_module\\_gpioint\\_interface](#)

#### 7.5.3.2 Data Structure Documentation

##### 7.5.3.2.1 struct [ft\\_module\\_gpioint\\_user\\_interface](#)

GPIO user's interface, which is used by the GPIO modules. All of these functions must be implemented in the application.

Collaboration diagram for ft\_module\_gpiont\_user\_interface:



## Data Fields

- void(\* **set\_pin\_output** )(uint32\_t port, uint32\_t pin)
- void(\* **set\_pin\_input** )(uint32\_t port, uint32\_t pin)
- void(\* **set\_pin\_low** )(uint32\_t port, uint32\_t pin)
- void(\* **set\_pin\_high** )(uint32\_t port, uint32\_t pin)
- void(\* **init\_pin** )(uint32\_t port, uint32\_t pin)
- void(\* **set\_pin\_interrupt** )(uint32\_t port, uint32\_t pin)
- void(\* **clear\_pin\_interrupt** )(uint32\_t port, uint32\_t pin)
- void(\* **init\_timer** )(void)
- void(\* **start\_timer** )(void)
- void(\* **stop\_timer** )(void)
- void(\* **timer\_reset\_counter** )(void)
- uint32\_t(\* **timer\_get\_counter** )(void)

### 7.5.3.2.1.1 Field Documentation

#### 7.5.3.2.1.1.1 void(\* ft\_module\_gpiont\_user\_interface::clear\_pin\_interrupt)(uint32\_t port, uint32\_t pin)

Disable the pin to generate an interrupt

#### 7.5.3.2.1.1.2 void(\* ft\_module\_gpiont\_user\_interface::init\_pin)(uint32\_t port, uint32\_t pin)

Initialize the pin to a state ready for measurement

## Key Detectors

**7.5.3.2.1.1.3 void(\* ft\_module\_gpoint\_user\_interface::init\_timer)(void)**

Init timer

**7.5.3.2.1.1.4 void(\* ft\_module\_gpoint\_user\_interface::set\_pin\_high)(uint32\_t port, uint32\_t pin)**

Set the pin to logic high

**7.5.3.2.1.1.5 void(\* ft\_module\_gpoint\_user\_interface::set\_pin\_input)(uint32\_t port, uint32\_t pin)**

Set the pin direction to input

**7.5.3.2.1.1.6 void(\* ft\_module\_gpoint\_user\_interface::set\_pin\_interrupt)(uint32\_t port, uint32\_t pin)**

Enable the pin to generate an interrupt

**7.5.3.2.1.1.7 void(\* ft\_module\_gpoint\_user\_interface::set\_pin\_low)(uint32\_t port, uint32\_t pin)**

Set the pin to logic low

**7.5.3.2.1.1.8 void(\* ft\_module\_gpoint\_user\_interface::set\_pin\_output)(uint32\_t port, uint32\_t pin)**

Set the pin direction to output

**7.5.3.2.1.1.9 void(\* ft\_module\_gpoint\_user\_interface::start\_timer)(void)**

Start timer

**7.5.3.2.1.1.10 void(\* ft\_module\_gpoint\_user\_interface::stop\_timer)(void)**

Stop timer

**7.5.3.2.1.1.11 uint32\_t(\* ft\_module\_gpoint\_user\_interface::timer\_get\_counter)(void)**

Get timer counter


**7.5.3.2.1.1.12 void(\* ft\_module\_gpoint\_user\_interface::timer\_reset\_counter)(void)**

Reset timer counter

## 7.5.3.2.2 struct ft\_module\_gpoint\_params

GPIO interrupt module, which uses the port interrupts to sample a signal from the running timer counter.

Collaboration diagram for ft\_module\_gpiont\_params:



#### Data Fields

struct ft_module_- gpiont_user_- interface *	user_interface	
--	----------------	--

#### 7.5.3.3 Function Documentation

##### 7.5.3.3.1 void ft\_module\_gpiont\_isr ( const struct ft\_module \* *module* )

## Key Detectors


## Parameters

<i>module</i>	Pointer to the module that invokes the interrupt; it depends on the user application to handle the right value.
---------------	---

## Returns

None.

Here is the call graph for this function:



**7.5.3.3.2 void ft\_module\_gpoint\_overflow\_isr( const struct ft\_module \* *module* )**


### Parameters

<i>module</i>	Pointer to the module that invokes the interrupt; it depends on the user application to handle the right value.
---------------	---

Returns

None.

Here is the call graph for this function:



#### 7.5.3.4 Variable Documentation

##### 7.5.3.4.1 struct ft\_module\_interface ft\_module\_gpioint\_interface

Can't be NULL.

interface gpio module

## Key Detectors

### 7.5.4 TSI module

#### 7.5.4.1 Overview

The TSI module describes the hardware configuration and control of the elementary functionality of the TSI peripheral; it covers all versions of the TSI peripheral by a generic low-level driver API.

The TSI Basic module is designed for processors that have the hardware TSI module version 1, 2, or 4 (for example Kinetis L).

The module also handles the NOISE mode supported by the TSI v4 (Kinetis L). Collaboration diagram for TSI module:



#### Data Structures

- struct `ft_module_tsi_noise`
- struct `ft_module_tsi_params`

#### Variables

- struct `ft_module_interface ft_module_tsi_interface`


#### 7.5.4.2 Data Structure Documentation

##### 7.5.4.2.1 struct `ft_module_tsi_noise`

The structure represents the Noise detection of the TSI v4 module. An instance of this data type represents the Noise detection of the TSI v4 module. It contains the parameters of Noise filters automatic sensitive calibration.

You must initialize all the members before registering the noise in the module. This structure can be allocated in ROM.

Collaboration diagram for ft\_module\_tsi\_noise:



#### Data Fields

struct <b>ft_filter_iir</b>	noise_filter	
uint8_t	update_rate	


#### 7.5.4.2.2 struct `ft_module_tsi_params`

The main structure representing the Noise detection of the TSI v4 module. An instance of this data type represents the Noise detection of the TSI v4 module. It contains the parameters of the Noise filters automatic sensitive calibration.

You must initialize all the members before registering the Noise in the module. This structure can be allocated in ROM.

## Key Detectors

Collaboration diagram for ft\_module\_tsi\_params:



### Data Fields

struct <a href="#">ft_module_tsi_noise</a>	noise	
---	-------	--

### 7.5.4.3 Variable Documentation

#### 7.5.4.3.1 struct ft\_module\_interface ft\_module\_tsi\_interface

The TSI module interface structure. Can't be NULL.


interface tsi module

## 7.6 Modules

### 7.6.1 Overview

Modules represent the data-acquisition layer in the Freescale Touch system; it is the layer that is tightly coupled with the hardware module available on the Freescale MCU device.

Each Module implements a set of functions contained in the `ft_module_interface` structure. This interface is used by the system to process all modules in a generic way during the data-acquisition or data-processing phases. Collaboration diagram for Modules:



## Modules

- [GPIO module](#)
- [GPIO interrupt module](#)
- [TSI module](#)
- [General API](#)

## Modules

### 7.6.2 General API

#### 7.6.2.1 Overview

General Function definition of the modules. Collaboration diagram for General API:



## Modules

- API Functions

## Data Structures

- union `ft_module_params`
- struct `ft_module`

## Enumerations


- enum `ft_module_mode` {  
    `FT_MODULE_MODE_NORMAL`,  
    `FT_MODULE_MODE_PROXIMITY`,  
    `FT_MODULE_MODE_LOW_POWER` }
- enum `ft_module_flags` {  
    `FT_MODULE_NEW_DATA_FLAG`,  
    `FT_MODULE_TRIGGER_DISABLED_FLAG`,  
    `FT_MODULE_DIGITAL_RESULTS_FLAG` }

### 7.6.2.2 Data Structure Documentation

#### 7.6.2.2.1 union `ft_module_params`

Container that covers all possible variants of the module parameters.

Collaboration diagram for ft\_module\_params:



#### Data Fields

<pre> struct ft_module_gpio_params *</pre>	<code>gpio</code>	Pointer to the GPIO module specific parameters.
--	-------------------	---

## Modules


struct ft_module_- gpioint_params *	gpioint	Pointer to the GPIO interrupt module specific parameters.
struct ft_module_tsi- _params *	tsi	Pointer to the TSI module specific parameters.

### 7.6.2.2.2 struct ft\_module

The main structure representing the Module instance; this structure is used as a base for all module implementations. The type of the module is specified by selecting the right module interface.

This structure can be allocated in ROM.

Collaboration diagram for ft\_module:



## Data Fields

void *	config	A pointer to the hardware configuration. Can't be NULL.
struct ft_electrode *const *	electrodes	A pointer to the list of electrodes. Can't be NULL.

## Modules

<code>uint8_t</code>	<code>instance</code>	An instance of the module.
<code>struct ft_module_&lt;br&gt;interface *</code>	<code>interface</code>	Module interface. Can't be NULL.
<code>union ft_module_&lt;br&gt;params</code>	<code>module_-&lt;br&gt;params</code>	An instance module params. Can't be NULL.

### 7.6.2.3 Enumeration Type Documentation

#### 7.6.2.3.1 enum `ft_module_flags`

Generic flags for Module processing.

Enumerator

**`FT_MODULE_NEW_DATA_FLAG`** The new data is ready to be processed.

**`FT_MODULE_TRIGGER_DISABLED_FLAG`** Disables the trigger for the current module (in fact, the module is disabled).

**`FT_MODULE_DIGITAL_RESULTS_FLAG`** The digital data only flag (only touch / release information - no analog value).

#### 7.6.2.3.2 enum `ft_module_mode`

Module's modes.

Enumerator

**`FT_MODULE_MODE_NORMAL`** The module is in a standard touch measure mode.

**`FT_MODULE_MODE_PROXIMITY`** The module is in a proximity mode.

**`FT_MODULE_MODE_LOW_POWER`** The module is in a low-power mode.

## 7.6.2.4 API Functions

### 7.6.2.4.1 Overview

General API functions of the modules. Collaboration diagram for API Functions:



## Functions

- `uint32_t ft_module_recalibrate (const struct ft_module *module, void *configuration)`  
*Recalibrate the module. The function forces the recalibration process of the module to get optimized parameters.*
- `int32_t ft_module_change_mode (struct ft_module *module, const enum ft_module_mode mode, const struct ft_electrode *electrode)`  
*Changes the module mode of the operation.*
- `int32_t ft_module_load_configuration (struct ft_module *module, const enum ft_module_mode mode, const void *config)`  
*Load module configuration for the selected mode. The function loads the new configuration to the module for the selected mode of operation.*
- `int32_t ft_module_save_configuration (struct ft_module *module, const enum ft_module_mode mode, void *config)`  
*Saves the module configuration for the selected mode. The function saves the configuration from the module for the selected mode of operation into the user storage place.*

### 7.6.2.4.2 Function Documentation

#### 7.6.2.4.2.1 `int32_t ft_module_change_mode ( struct ft_module * module, const enum ft_module_mode mode, const struct ft_electrode * electrode )`

Parameters

<code>module</code>	Pointer to the module.
---------------------	------------------------

## Modules


<i>mode</i>	New requested mode of the module.
<i>electrode</i>	Pointer to the electrode used in special modes (low-power & proximity); only one electrode is enabled in these modes.

Returns

- FT\_SUCCESS if the mode was properly changed
- FT\_FAILURE if the mode cannot be changed This is an example of changing the mode of the module operation in the FT library:

```
if(ft_module_change_mode(&my_ft_module,
    FT_MODULE_MODE_PROXIMITY, &my_proximity_electrode) ==
    FT_FAILURE)
{
    printf("The change of mode for my_ft_module failed.");
}
// The FT successfully changed mode of my_ft_module
```

Here is the call graph for this function:



### 7.6.2.4.2.2 `int32_t ft_module_load_configuration ( struct ft_module * module, const enum ft_module_mode mode, const void * config )`

Parameters


<i>module</i>	Pointer to the module.
<i>mode</i>	Mode of the module.
<i>config</i>	Pointer to the configuration data of the module, the type is dependent on the target module.

Returns

- FT\_SUCCESS if the load operation was properly done
- FT\_FAILURE if the load operation cannot be finished This is an example of loading the configuration data of the module in the FT library:

```
// I want to load new configuration for the TSI module and the proximity mode
if(ft_module_load_configuration(&my_ft_module,
    FT_MODULE_MODE_PROXIMITY, &my_module_tsi_proximity_configuration) ==
    FT_FAILURE)
{
    printf("Loading of new configuration for the my_ft_module failed.");
}
// The FT successfully loaded the new configuration of the my_ft_module.
```

Here is the call graph for this function:



#### 7.6.2.4.2.3 uint32\_t ft\_module\_recalibrate ( const struct ft\_module \* *module*, void \* *configuration* )

Parameters

<i>module</i>	Pointer to the module to be recalibrated.
<i>configuration</i>	Pointer to the module configuration that must be used as a startup configuration for the recalibration.


Returns

The lowest signal measured within the module. // todo is this a good return value? This is an example of recalibrating the module settings of the FT library:

```
// to do
if(ft_module_recalibrate(&my_ft_module, &my_ft_module) ==
    FT_FAILURE)
{
    printf("The change of mode for my_ft_module failed.");
}
// The FT successfully chenge mode of my_ft_module
```

## Modules

Here is the call graph for this function:



### 7.6.2.4.2.4 int32\_t ft\_module\_save\_configuration ( struct ft\_module \* module, const enum ft\_module\_mode mode, void \* config )

Parameters

<i>module</i>	Pointer to the module.
<i>mode</i>	Mode of the module.
<i>config</i>	Pointer to the configuration data variable of the module, where the current configuration should be stored. The type is dependent on the target module.


Returns

- FT\_SUCCESS if the save operation was properly done
- FT\_FAILURE if the save operation cannot be finished This is an example of saving the configuration data of the module in the FT library:

```

// I want to save the configuration of the TSI module and the proximity mode into my variable
// tsi_config_t my_module_tsi_proximity_configuration;
if(ft_module_save_configuration(&my_ft_module,
                               FT_MODULE_MODE_PROXIMITY, &my_module_tsi_proximity_configuration) ==
   FT_FAILURE)
{
    printf("Saving of the current configuration for the my_ft_module failed.");
}
// The FT successfully saved the current configuration of the my_ft_module
  
```

Here is the call graph for this function:




## 7.7 System

### 7.7.1 Overview

The System structure represents the Freescale Touch Library in the user application; it is represented by the [ft\\_system](#) structure, which contains further references to all other application objects like: [Electrodes](#), [Key Detectors](#), [Modules](#), and [Controls](#).

The [ft\\_system](#) structure is allocated and initialized by the user, in order to define library configuration, including low-level electrode hardware channels and high-level control parameters. Just like all other structure types, it is up to the user, whether an instance of this structure is allocated statically in compile-time or dynamically. The examples provided with the Freescale Touch library show the static allocation and initialization of [ft\\_system](#) along with all other related data structures. Collaboration diagram for System:



## Modules

- [API Functions](#)

## Data Structures

- struct [ft\\_system](#)

## TypeDefs

- [typedef void\(\\* ft\\_system\\_callback \)\(uint32\\_t event\)](#)
- [typedef void\(\\* ft\\_error\\_callback \)\(char \\*file\\_name, uint32\\_t line\)](#)

## Enumerations

- enum [ft\\_system\\_event](#) {  
    [FT\\_SYSTEM\\_EVENT\\_OVERRUN](#),  
    [FT\\_SYSTEM\\_EVENT\\_DATA\\_READY](#) }

### 7.7.2 Data Structure Documentation

### 7.7.2.1 struct ft\_system


The main structure representing the Freescale Touch library; The structure contains pointer lists referring to all other objects used in the application, such as [Electrodes](#), [Key Detectors](#), [Modules](#), and [Controls](#).

The `ft_system` structure and all referred structures are allocated and initialized by the user code, in order to define the library configuration. This configuration affects all library layers from the low-level electrode parameters (for example hardware pins and channels) up to the high-level control parameters (for example slider range or keypad multiplexing).

Just like with all other structure types, it is up to the user, whether the instance of this structure is allocated statically in the compile-time, or dynamically. Examples provided with the Freescale Touch library show the static allocation and initialization of the [ft\\_system](#), along with all other related data structures.

This structure can be allocated in ROM.

## Collaboration diagram for ft\_system:



## Data Fields

<code>struct ft_control *const *</code>	<code>controls</code>	A pointer to the list of controls. Can't be NULL.
<code>uint16_t</code>	<code>init_time</code>	Initialization time for the system.
<code>struct ft_module *const *</code>	<code>modules</code>	A pointer to the list of modules. Can't be NULL.
<code>uint16_t</code>	<code>time_period</code>	Defined time period (triggering period). Can't be 0.

### 7.7.3 Typedef Documentation

#### 7.7.3.1 `typedef void(* ft_error_callback)(char *file_name, uint32_t line)`

Error callback function pointer type.

Parameters

<code>file</code>	The name of the file where the error occurs.
<code>line</code>	The line index in the file where the error occurs.

Returns

None.

#### 7.7.3.2 `typedef void(* ft_system_callback)(uint32_t event)`

System event callback function pointer type.

Parameters

<code>event</code>	Event type <code>ft_system_event</code> that caused the callback function call.
--------------------	---

## System

Returns

None.

### 7.7.4 Enumeration Type Documentation

#### 7.7.4.1 enum ft\_system\_event

System callbacks events.

Enumerator

*FT\_SYSTEM\_EVENT\_OVERRUN* Data has been overrun.

*FT\_SYSTEM\_EVENT\_DATA\_READY* New data are available.

## 7.7.5 API Functions

### 7.7.5.1 Overview

General Function definition of the system. Collaboration diagram for API Functions:



## Functions

- void `ft_system_register_callback (ft_system_callback callback)`  
*Register the system callback function.*
- void `ft_error_register_callback (ft_error_callback callback)`  
*Register the system error callback function.*
- uint32\_t `ft_system_get_time_counter (void)`  
*Returns the system time counter.*
- uint32\_t `ft_mem_get_free_size (void)`  
*Returns the free memory size in the FT memory pool.*
- int32\_t `ft_init (const struct ft_system *system, uint8_t *pool, const uint32_t size)`  
*Freescale Touch Library initialization.*
- int32\_t `ft_task (void)`  
*Freescale Touch Main processing entry point.*
- int32\_t `ft_trigger (void)`  
*Main Trigger function to acquire the touch-sensing data.*

### 7.7.5.2 Function Documentation

#### 7.7.5.2.1 void `ft_error_register_callback ( ft_error_callback callback )`

Parameters

<code>callback</code>	Pointer to the callback function, which will receive the error event notifications.
-----------------------	---

Returns

none After this callback finishes, the driver falls to a never ending loop. This is an example of installing and using the parameters of the FT library error handler:

## System

```

* static void my_ft_error_callback(char *file_name, uint32_t line);
*
* // For library debugging only, install the error handler
* ft_error_register_callback(my_ft_error_callback)
*
* // The FT error-handling routine
* static void my_ft_error_callback(char *file_name, uint32_t line)
{
    printf("\nError occurred in the FT library. File: %s, Line: %d.\n", file_name, line);
}
*
*

```

### 7.7.5.2.2 int32\_t ft\_init( const struct ft\_system \* system, uint8\_t \* pool, const uint32\_t size )

#### Parameters

<i>system</i>	Pointer to the FT system parameters structure.
<i>pool</i>	Pointer to the memory pool what will be used for internal FT data.
<i>size</i>	Size of the memory pool handled by the parameter pool (needed size depends on the number of components used in the FT - electrodes, modules, controls, and so on).

#### Returns

- FT\_SUCCESS if library was properly initialized,
- FT\_FAILURE if initialization failed (one of the reasons is not enough memory in the memory pool).

This function validates the Freescale Touch configuration passed within the [ft\\_system](#) structure. After this call, the system structure becomes the main data provider for the application. There are also created and filled-up internal volatile data structures used by the driver. It is the user's responsibility to prepare the configuration of all electrodes, modules, and controls in the system structure before calling this function. The application should not execute any other FT library calls if this function returns FT\_FAILURE. This is an example of the FT library initialization:


```

uint8_t ft_memory_pool[512];

if(ft_init(&my_ft_system_params, ft_memory_pool, sizeof(ft_memory_pool)) ==
   FT_FAILURE)
{
    printf("Initialization of FT failed. There can be a problem with the memory size
          or invalid parameters in component parameter structures.");
}
// The FT is successfully initialized

```

Here is the call graph for this function:



#### 7.7.5.2.3 uint32\_t ft\_mem\_get\_free\_size ( void )

## Returns


size of unused memory in the FT memory pool

This can be used in debugging of the driver to specify the exact size of the Freescale Touch memory pool needed. This is an example of initializing the FT library and checking the final size:

```
*     uint8_t ft_memory_pool[512];
*
*     if(ft_init(&my_ft_system_params, ft_memory_pool, sizeof(ft_memory_pool)) == FT_FAILURE)
*     {
*         printf("Initialization of the FT failed. There may be a problem with the memory size,
* or invalid parameters in the componented parameter structures.");
*     }
* // The FT is successfully initialized
*
*     printf("The unused memory size is: &d Bytes. The memory pool can be reduced
* by this size.", ft_mem_get_free_size());
*
```

## System

Here is the call graph for this function:



### 7.7.5.2.4 uint32\_t ft\_system\_get\_time\_counter( void )


Returns

Time counter value. This is an example of getting the current time of the FT library:

```

* // Printing the current Freescale Touch library time
* printf("The current FT library time is: &d ms since start.\n",
        ft_system_get_time_counter());
*
*
```

Here is the caller graph for this function:



### 7.7.5.2.5 void ft\_system\_register\_callback( ft\_system\_callback callback )

Parameters

---

<i>callback</i>	Pointer to the callback function, which will receive the system event notifications.
-----------------	--

## Returns

none This is an example of installing and using the parameters of the FT library system events handler:

```
* static void my_ft_system_callback(uint32_t event);
*
* // To catch the system events, install the system handler
* ft_system_register_callback(my_ft_system_callback)
*
* // The FT system events handling routine
* static void my_ft_system_callback(uint32_t event)
{
    if(event == FT_SYSTEM_EVENT_OVERRUN)
    {
        printf("\nThe measured data has been overrun. Call more frequently ft_task();");
    }
    else if(event == FT_SYSTEM_EVENT_DATA_READY)
    {
        printf("\nThere is new data in the FT library.");
    }
}
```

### 7.7.5.2.6 int32\_t ft\_task( void )

## Returns

- FT\_SUCCESS when data acquired during the last trigger are now processed
- FT\_FAILURE when no new data are ready

This function should be called by the application as often as possible, in order to process the data acquired during the data trigger. This function should be called at least once per trigger time.


Internally, this function passes the FT\_SYSTEM\_MODULE\_PROCESS and FT\_SYSTEM\_CONTROLLER\_PROCESS command calls to each object configured in [Modules](#) and [Controls](#). This is an example of running a task of the FT library:

```
uint8_t ft_memory_pool[512];

if(ft_init(&my_ft_system_params, ft_memory_pool, sizeof(ft_memory_pool)) ==
   FT_FAILURE)
{
    printf("Initialization of FT failed. There can be problem with memory size
           or invalid parameters in component parameter structures.");
}
// The FT is successfully initialized

// Main never-ending loop of the application
while(1)
{
    if(ft_task() == FT_SUCCESS)
    {
        // New data has been processed
    }
}
```

Here is the call graph for this function:



#### 7.7.5.2.7 int32\_t ft\_trigger( void )


## Returns

- FT\_SUCCESS when the trigger was performed without any errors or warnings.
  - FT\_FAILURE when a problem is detected, such as module not ready, overrun (data loss) error, and so on. Regardless of the error, the trigger is always initiated.

This function should be called by the application periodically in a timer interrupt, or in a task to trigger new data measurement. Depending on the [Modules](#) implementation, this function may take the data immediately, or may only start the hardware sampling with interrupt enabled. This is an example of the FT library triggering:

```
//For example, there is a callback routine from any priodical source (for example 5 ms)
static void Timer_5msCallBack(void)
{
    if(ft_trigger() != FT_SUCCESS)
    {
        // Trigger error
    }
}
```

Here is the call graph for this function:



## General Types

### 7.8 General Types

#### 7.8.1 Overview

The standard types used in the whole Freescale Touch software library. The code is built on the standard library types, such as uint32\_t, int8\_t, and so on, loaded from "stdint.h", and it defines just few additional types needed to run the FT. Collaboration diagram for General Types:



## Macros

- #define **NULL**  
*Standard NULL pointer. There is a definition in the FT, in case that NULL is not defined in the project previously.*
- #define **FT\_FLAGS\_SYSTEM\_SHIFT(x)**
- #define **FT\_FLAGS\_SPECIFIC\_SHIFT(x)**
- #define **FT\_FREEMASTER\_SUPPORT**  
*FT\_FREEMASTER\_SUPPORT enables the support of FreeMASTER for the Freescale Touch project. When it is enabled, the FT starts using / including the freemaster.h file. FT\_DEBUG is enabled by default.*
- #define **FT\_DEBUG**  
*FT\_DEBUG enables the debugging code that caused the assert states in the FT. For the release compilation, this option should be disabled. FT\_DEBUG is enabled by default, which enables the FT ASSERTS.*
- #define **FT\_ASSERT(expr)**

## Enumerations

- enum **ft\_result** {
   
    **FT\_SUCCESS**,
   
    **FT\_FAILURE**,
   
    **FT\_OUT\_OF\_MEMORY**,
   
    **FT\_SCAN\_IN\_PROGRESS**,
   
    **FT\_NOT\_SUPPORTED**,
   
    **FT\_INVALID\_RESULT** }

*The Freescale Touch result of most operations / API. The standard API function returns the result of the finished operation if needed, and it can have the following values.*

## 7.8.2 Macro Definition Documentation

7.8.2.1 `#define FT_ASSERT( expr )`

7.8.2.2 `#define FT_DEBUG`

7.8.2.3 `#define FT_FLAGS_SPECIFIC_SHIFT( x )`

7.8.2.4 `#define FT_FLAGS_SYSTEM_SHIFT( x )`

Generic flags for FT processing.

7.8.2.5 `#define FT_FREEMASTER_SUPPORT`

7.8.2.6 `#define NULL`

## 7.8.3 Enumeration Type Documentation

7.8.3.1 `enum ft_result`

Enumerator

***FT\_SUCCESS*** Successful result - Everything is alright.

***FT\_FAILURE*** Something is wrong, unspecified error.

***FT\_OUT\_OF\_MEMORY*** The FT does not have enough memory.

***FT\_SCAN\_IN\_PROGRESS*** The scan is currently in progress.

***FT\_NOT\_SUPPORTED*** The feature is not supported.

***FT\_INVALID\_RESULT*** The function ends with an invalid result.

## General Types

### 7.8.4 Analog Rotary Control

#### 7.8.4.1 Overview

Analog Rotary enables the detection of jog-dial-like finger movement using three or more electrodes; it is represented by the `ft_control` structure.

An Analog Rotary Control uses three or more specially-shaped electrodes to enable the calculation of finger position within a circular area. The position algorithm uses a ratio of sibling electrode signals to estimate the finger position with required precision.

The Analog Rotary works similarly to the "standard" Rotary, but requires less number of electrodes, while achieving a higher resolution of the calculated position. For example, a four-electrode analog rotary can provide finger position detection in the range of 0-64. The shape of the electrodes needs to be designed specifically to achieve stable signal with a linear dependence on the finger movement.

The Analog Rotary Control provides Position, Direction, and Displacement values. It is able to generate event callbacks when finger Movement, Initial-touch, or Release is detected.

The image below shows a typical four-electrode Analog Rotary electrode placement.




Figure 7.8.1: Analog Rotary Electrodes

Collaboration diagram for Analog Rotary Control:



## Data Structures

- struct `ft_control_arotary_temp_data`
- struct `ft_control_arotary_data`

## Macros

- #define FT\_AROTARY\_INVALID\_POSITION\_VALUE

## Enumerations


- enum ft\_control\_arotary\_flags {  
    FT\_AROTARY\_INVALID\_POSITION\_FLAG,  
    FT\_AROTARY\_DIRECTION\_FLAG,  
    FT\_AROTARY\_MOVEMENT\_FLAG,  
    FT\_AROTARY\_TOUCH\_FLAG }

### 7.8.4.2 Data Structure Documentation

#### 7.8.4.2.1 struct ft\_control\_arotary\_temp\_data

Analog Rotary help structure to handle temporary values

Collaboration diagram for ft\_control\_arotary\_temp\_data:



#### Data Fields

uint32_t	active_el_ix	Index of electrode of first active electrode.
uint32_t	first_delta	Value of first delta (signal - baseline).

## General Types


uint32_t	range	Value of first delta (signal - baseline).
----------	-------	---

### 7.8.4.2.2 struct ft\_control\_arotary\_data

Analog Rotary RAM structure used to store volatile parameters of the control.

You need to allocate this structure and put a pointer into the `ft_control` structure when it is being registered in the system.

Collaboration diagram for `ft_control_arotary_data`:



## Data Fields

<code>ft_control_arotary_callback</code>	callback	Analog Rotary callback handler.
uint8_t	position	Position.

### 7.8.4.3 Macro Definition Documentation

#### 7.8.4.3.1 #define FT\_AROTARY\_INVALID\_POSITION\_VALUE

Value that is used to mark an invalid position of the Analog Rotary.

### 7.8.4.4 Enumeration Type Documentation

#### 7.8.4.4.1 enum ft\_control\_arotary\_flags

Analog Rotary flags.

Enumerator

***FT\_AROTARY\_INVALID\_POSITION\_FLAG*** Analog Rotary invalid position flag.

***FT\_AROTARY\_DIRECTION\_FLAG*** Analog Rotary direction flag.

***FT\_AROTARY\_MOVEMENT\_FLAG*** Analog Rotary movement flag.

***FT\_AROTARY\_TOUCH\_FLAG*** Analog Rotary touch flag.

## General Types

### 7.8.5 Analog Slider Control

#### 7.8.5.1 Overview

Analog Slider enables the detection of linear finger movement using two or more electrodes; it is represented by the [ft\\_control\\_aslider](#) structure.

An Analog Slider Control uses two or more specially-shaped electrodes to enable the calculation of finger position within a linear area. The position algorithm uses a ratio of electrode signals to estimate the finger position with required precision.

The Analog Slider works similarly to the "standard" Slider, but requires less electrodes, while achieving a higher resolution of the calculated position. For example, a two-electrode analog slider can provide finger position detection in the range of 0-127. The shape of the electrodes needs to be designed specifically to achieve stable signal with a linear dependance on finger movement.

The Analog Slider Control provides Position, Direction, and Displacement values. It is able to generate event callbacks when finger Movement, Initial-touch, or Release is detected.

The image below shows a typical two-electrode Analog Slider electrode placement.



Figure 7.8.2: Analog Slider Electrodes

Collaboration diagram for Analog Slider Control:



## Data Structures

- struct [ft\\_control\\_aslider\\_data](#)
- struct [ft\\_control\\_aslider\\_temp\\_data](#)

## Macros

- #define [FT\\_ASPLIER\\_INVALID\\_POSITION\\_VALUE](#)

## Enumerations

- enum `ft_control_aslider_flags` {
 `FT_ASIDER_INVALID_POSITION_FLAG`,
 `FT_ASIDER_DIRECTION_FLAG`,
 `FT_ASIDER_MOVEMENT_FLAG`,
 `FT_ASIDER_TOUCH_FLAG` }


### 7.8.5.2 Data Structure Documentation

#### 7.8.5.2.1 struct `ft_control_aslider_data`

Analog Slider RAM structure used to store volatile parameters of the control.

You need to allocate this structure and put a pointer into the `ft_control_aslider` structure when it is being registered in the system.

Collaboration diagram for `ft_control_aslider_data`:



## General Types


Data Fields

<code>ft_control_aslider_callback</code>	callback	Analog Slider callback handler.
<code>uint8_t</code>	position	Position.

### 7.8.5.2.2 struct ft\_control\_aslider\_temp\_data

Analog Slider help structure to handle temporary values

Collaboration diagram for `ft_control_aslider_temp_data`:



Data Fields

<code>uint32_t</code>	<code>active_el_ix</code>	Index of electrode of first active electrode.
<code>uint32_t</code>	<code>first_delta</code>	Value of first delta (signal - baseline).
<code>uint32_t</code>	<code>range</code>	Value of first delta (signal - baseline).

### 7.8.5.3 Macro Definition Documentation

#### 7.8.5.3.1 #define FT\_ASPLIER\_INVALID\_POSITION\_VALUE

Value that is used to mark an invalid position of analog slider.

## 7.8.5.4 Enumeration Type Documentation

### 7.8.5.4.1 enum ft\_control\_aslider\_flags

Analog Slider flags.

Enumerator

***FT\_ASLIDER\_INVALID\_POSITION\_FLAG*** Analog Slider invalid position flag.

***FT\_ASLIDER\_DIRECTION\_FLAG*** Analog Slider direction flag.

***FT\_ASLIDER\_MOVEMENT\_FLAG*** Analog Slider movement flag.

***FT\_ASLIDER\_TOUCH\_FLAG*** Analog Slider touch flag.

## General Types

### 7.8.6 Keypad Control

#### 7.8.6.1 Overview

Keypad implements the keyboard-like functionality on top of an array of electrodes; it is represented by the [ft\\_control\\_keypad](#) structure.

An application may use the Electrode API to determine the touch or release states of individual electrodes. The Keypad simplifies this task and it extends this simple scenario by introducing a concept of a "key". The "key" is represented by one or more physical electrodes, so the Keypad control enables one electrode to be shared by several keys. Each key is defined by a set of electrodes that all need to be touched in order to report the "key press" event.

The Keypad Control provides Key status values and is able to generate the Key Touch, Auto-repeat, and Release events.

The images below show simple and grouped keypad electrode layouts.




Figure 7.8.3: Keypad Electrodes

Collaboration diagram for Keypad Control:



## Data Structures

- struct `ft_control_keypad_data`

## Enumerations

- enum `ft_control_keypad_flags` { `FT_KEYPAD_ONLY_ONE_KEY_FLAG` }

### 7.8.6.2 Data Structure Documentation


#### 7.8.6.2.1 struct `ft_control_keypad_data`

The Keypad RAM structure used to store volatile parameters of the control.

You must allocate this structure and put a pointer into the `ft_control_keypad` structure when it is being registered in the system.

## General Types

Collaboration diagram for ft\_control\_keypad\_data:



### Data Fields

uint16_t	autorepeat_rate	Autorepeat rate.
<b>ft_control_keypad_callback</b>	callback	Keypad callback handler.
int32_t	last_electrode	Last touched electrode index.
uint32_t	last_key_state	Last state of keypad keys.
uint32_t	last_state	Last state of keypad electrodes.

uint32_t	repeat_time	Time of next autorepeat event.
uint32_t	start_-autorepeat_rate	Start Autorepeat rate.

### 7.8.6.3 Enumeration Type Documentation

#### 7.8.6.3.1 enum ft\_control\_keypad\_flags

Keypad flags.

Enumerator

***FT\_KEYPAD\_ONLY\_ONE\_KEY\_FLAG*** Keypad only one key is valid flag.

## General Types

### 7.8.7 Rotary Control

#### 7.8.7.1 Overview

Rotary enables the detection of jog-dial-like finger movement using discrete electrodes; it is represented by the `ft_control_rotary_control` structure.

The Rotary Control uses a set of discrete electrodes to enable the calculation of finger position within a circular area. The position algorithm localizes the touched electrode and its sibling electrodes to estimate the finger position. The Rotary consisting of N electrodes enables the rotary position to be calculated in  $2N$  steps.

The Rotary Control provides Position, Direction, and Displacement values. It is able to generate event callbacks when finger Movement, Initial-touch, or Release is detected.

The image below shows a typical Rotary electrode placement.




Figure 7.8.4: Rotary Electrodes

Collaboration diagram for Rotary Control:



## Data Structures

- struct `ft_control_rotary_data`

## Enumerations

- enum `ft_control_rotary_flags` {
 `FT_ROTARY_INVALID_POSITION_FLAG`,
 `FT_ROTARY_DIRECTION_FLAG`,
 `FT_ROTARY_MOVEMENT_FLAG`,
 `FT_ROTARY_TOUCH_FLAG` }


### 7.8.7.2 Data Structure Documentation

#### 7.8.7.2.1 struct `ft_control_rotary_data`

Rotary RAM structure used to store volatile parameters of the control.

You must allocate this structure and put a pointer into the `ft_control_rotary_control` structure when it is being registered in the system.

Collaboration diagram for `ft_control_rotary_data`:



## General Types

Data Fields

<code>ft_control_- rotary_callback</code>	callback	Callback handler.
<code>uint8_t</code>	position	Position.

### 7.8.7.3 Enumeration Type Documentation

#### 7.8.7.3.1 enum `ft_control_rotary_flags`

Rotary flags.

Enumerator

`FT_ROTARY_INVALID_POSITION_FLAG` Rotary invalid position flag.

`FT_ROTARY_DIRECTION_FLAG` Rotary direction flag.

`FT_ROTARY_MOVEMENT_FLAG` Rotary movement flag.

`FT_ROTARY_TOUCH_FLAG` Rotary touch flag.

## 7.8.8 Slider Control

### 7.8.8.1 Overview

Slider control enables the detection of a linear finger movement using discrete electrodes; it is represented by the [ft\\_control](#) structure.

The Slider Control uses a set of discrete electrodes to enable the calculation of finger position within a linear area. The position algorithm localizes the touched electrode and its sibling electrodes to estimate the finger position. The Slider consisting of N electrodes enables the position to be calculated in  $2N-1$  steps.

The Slider Control provides Position, Direction, and Displacement values. It is able to generate event callbacks when finger Movement, Initial-touch, or Release is detected.

The image below shows a typical Slider electrode placement.



Figure 7.8.5: Slider Electrodes

Collaboration diagram for Slider Control:



## Data Structures

- struct [ft\\_control\\_slider\\_data](#)

## General Types

### Enumerations

- enum `ft_control_slider_flags` {
 `FT_SLIDER_INVALID_POSITION_FLAG`,
 `FT_SLIDER_DIRECTION_FLAG`,
 `FT_SLIDER_MOVEMENT_FLAG`,
 `FT_SLIDER_TOUCH_FLAG` }


### 7.8.8.2 Data Structure Documentation

#### 7.8.8.2.1 struct `ft_control_slider_data`

Slider RAM structure used to store volatile parameters of the control.

You must allocate this structure and put a pointer into the `ft_control_slider_control` structure when it is being registered in the system.

Collaboration diagram for `ft_control_slider_data`:



## Data Fields

<a href="#"><code>ft_control_slider_callback</code></a>	callback	Slider Callback handler.
<code>uint8_t</code>	position	Position.

### 7.8.8.3 Enumeration Type Documentation

#### 7.8.8.3.1 enum `ft_control_slider_flags`

Slider flags.

Enumerator

`FT_SLIDER_INVALID_POSITION_FLAG` Slider invalid position flag.

`FT_SLIDER_DIRECTION_FLAG` Slider direction flag.

`FT_SLIDER_MOVEMENT_FLAG` Slider movement flag.

`FT_SLIDER_TOUCH_FLAG` Slider touch flag.


## Controls

### 7.9 Controls

#### 7.9.1 Overview

Controls represent the highest level of abstraction in the finger touch evaluation; the generic control object used as a base for other "derived" control types is represented by the `ft_control` structure.

Based on the signal and status information coming from the Electrode layer, the controls calculate finger actions like movement, keyboard touch, hold and so on. Collaboration diagram for Controls:



## Modules

- Analog Rotary Control
- Analog Slider Control
- Keypad Control
- Rotary Control
- Slider Control
- General API

## 7.9.2 General API

### 7.9.2.1 Overview

General Function definition of controls. Collaboration diagram for General API:



## Modules

- [API Functions](#)

## Data Structures

- union [ft\\_control\\_special\\_data](#)
- struct [ft\\_control\\_data](#)
- struct [ft\\_control\\_interface](#)

## Enumerations

- enum [ft\\_control\\_flags](#) {  
    [FT\\_CONTROL\\_NEW\\_DATA\\_FLAG](#),  
    [FT\\_CONTROL\\_EN\\_FLAG](#) }


### 7.9.2.2 Data Structure Documentation

#### 7.9.2.2.1 union ft\_control\_special\_data

The pointer to the special data of the control. Each control type has its own type of the data structure, and the pointers to these special data structures are handled by this union, to keep the clearance of the types.

## Controls

Collaboration diagram for ft\_control\_special\_data:



## Data Fields

struct <b>ft_control_arotary_data</b> *	arotary	Pointer to the Analog Rotary control special data.
---	---------	--


<code>struct ft_control_aslider_data *</code>	<code>aslider</code>	Pointer to the Analog Slider control special data.
<code>void *</code>	<code>general</code>	Just one point of view on this union for a general sanity check.
<code>struct ft_control_keypad_data *</code>	<code>keypad</code>	Pointer to the Keypad control special data.
<code>struct ft_control_rotary_data *</code>	<code>rotary</code>	Pointer to the Rotary control special data.
<code>struct ft_control_slider_data *</code>	<code>slider</code>	Pointer to the Slider control special data.

#### 7.9.2.2.2 struct `ft_control_data`

The Control RAM structure used to store volatile parameters, flags, and other data to enable a generic behavior of the Control. You must allocate this structure and put a pointer into the `ft_control` structure when the control is being registered in the system.

## Controls

## Collaboration diagram for ft\_control\_data:




## Data Fields

<pre>union ft_control_ special_data</pre>	data	The pointer to the control data structure.
<pre>struct ft_- electrode_data **</pre>	electrodes	List of electrodes. Can't be NULL.
<pre>uint8_t</pre>	electrodes_size	Number of electrodes.
<pre>uint32_t</pre>	flags	Flags.
<pre>struct ft_control *</pre>	rom	The pointer to user control parameter structure.

### **7.9.2.2.3 struct ft\_control\_interface**

Control interface structure; each control uses this structure to register the entry points to its algorithms. This approach enables a kind-of polymorphism in the touch System. All controls are processed in the same way from the System layer, regardless of the specific implementation. Each control type defines one static constant structure of this type to register its own initialization and processing functions.

Collaboration diagram for ft\_control\_interface:



## Data Fields

- int32\_t(\* **init** )(struct **ft\_control\_data** \*control)
- int32\_t(\* **process** )(struct **ft\_control\_data** \*control)
- const char \* **name**

### 7.9.2.2.3.1 Field Documentation

#### 7.9.2.2.3.1.1 int32\_t(\* ft\_control\_interface::init)(struct ft\_control\_data \*control)

The address of init function.

#### 7.9.2.2.3.1.2 const char\* ft\_control\_interface::name

The name of the variable of this type, used for FreeMASTER support purposes.

#### 7.9.2.2.3.1.3 int32\_t(\* ft\_control\_interface::process)(struct ft\_control\_data \*control)

The address of process function.

## 7.9.2.3 Enumeration Type Documentation

### 7.9.2.3.1 enum ft\_control\_flags

Controls flags which can be set / cleared.

Enumerator

**FT\_CONTROL\_NEW\_DATA\_FLAG** Indication flag that the control has new data.

**FT\_CONTROL\_EN\_FLAG** Control Enable flag.

## Controls

### 7.9.2.4 API Functions

#### 7.9.2.4.1 Overview

The functions in this category can be used to manipulate the Control objects. Collaboration diagram for API Functions:



## Functions

- struct `ft_control_data * _ft_control_get_data` (const struct `ft_control *control`)  
*Get control data structure pointer.*
- struct `ft_control_data * _ft_control_init` (const struct `ft_control *control`)  
*Initialize the control object.*
- `int32_t _ft_control_check_data` (const struct `ft_control_data *control`)  
*Validate control data.*
- `uint32_t _ft_control_get_electrodes_state` (struct `ft_control_data *control`)  
*Get the state of all control electrodes.*
- void `_ft_control_set_flag_all_elec` (struct `ft_control_data *control`, `uint32_t flags`)
- void `_ft_control_clear_flag_all_elec` (struct `ft_control_data *control`, `uint32_t flag`)
- `uint32_t _ft_control_get_first_elec_touched` (`uint32_t current_state`)
- `uint32_t _ft_control_get_last_elec_touched` (`uint32_t current_state`)
- `uint32_t _ft_control_get_touch_count` (`uint32_t current_state`)
- `int32_t _ft_control_check_neighbours_electrodes` (struct `ft_control_data *control`, `uint32_t first`, `uint32_t second`, `uint32_t overrun`)
- `int32_t _ft_control_check_edge_electrodes` (struct `ft_control_data *control`, `uint32_t electrode_ix`)
- static void `_ft_control_set_flag` (struct `ft_control_data *control`, `uint32_t flags`)
- static void `_ft_control_clear_flag` (struct `ft_control_data *control`, `uint32_t flags`)
- static `uint32_t _ft_control_get_flag` (const struct `ft_control_data *control`, `uint32_t flags`)
- static `int32_t _ft_control_overrun` (struct `ft_control_data *control`)
- static struct `ft_electrode * _ft_control_get_electrode` (const struct `ft_control_data *control`, `uint32_t index`)

#### 7.9.2.4.2 Function Documentation

##### 7.9.2.4.2.1 `int32_t _ft_control_check_data ( const struct ft_control_data * control )`

## Parameters


<i>control</i>	Pointer to the control data.
----------------	------------------------------

## Returns

Status code.

Checking, whether the control data structure is sane; the interface, ram, and electrodes array should not be NULL.

Here is the caller graph for this function:




**7.9.2.4.2.2 int32\_t \_ft\_control\_check\_edge\_electrodes ( struct ft\_control\_data \* *control*, uint32\_t *electrode\_ix* )**

**7.9.2.4.2.3 int32\_t \_ft\_control\_check\_neighbours\_electrodes ( struct ft\_control\_data \* *control*, uint32\_t *first*, uint32\_t *second*, uint32\_t *overrun* )**

**7.9.2.4.2.4 static void \_ft\_control\_clear\_flag ( struct ft\_control\_data \* *control*, uint32\_t *flags* ) [inline], [static]**


Here is the caller graph for this function:



## Controls

### 7.9.2.4.2.5 void \_ft\_control\_clear\_flag\_all\_elec ( struct ft\_control\_data \* control, uint32\_t flag )

Here is the call graph for this function:



### 7.9.2.4.2.6 struct ft\_control\_data\* \_ft\_control\_get\_data ( const struct ft\_control \* control )


Parameters

<i>control</i>	Pointer to the control user parameter structure.
----------------	--


Returns

Pointer to the data control structure that is represented by the handled user parameter structure pointer.

Here is the call graph for this function:



Here is the caller graph for this function:



## Controls

7.9.2.4.2.7 **static struct ft\_electrode\* \_ft\_control\_get\_electrode ( const struct ft\_control\_data \* control, uint32\_t index ) [static]**

7.9.2.4.2.8 **uint32\_t \_ft\_control\_get\_electrodes\_state ( struct ft\_control\_data \* control )**


## Parameters

<i>control</i>	Pointer to the control data.
----------------	------------------------------


## Returns

This function returns a bit-mask value where each bit represents one control electrode. Logic 1 in the returned value represents a touched electrode.

Here is the call graph for this function:



Here is the caller graph for this function:




## Controls

**7.9.2.4.2.9 uint32\_t \_ft\_control\_get\_first\_elec\_touched ( uint32\_t *current\_state* )**

**7.9.2.4.2.10 static uint32\_t \_ft\_control\_get\_flag ( const struct ft\_control\_data \* *control*, uint32\_t *flags* ) [inline], [static]**

Here is the caller graph for this function:



**7.9.2.4.2.11 uint32\_t \_ft\_control\_get\_last\_elec\_touched ( uint32\_t *current\_state* )**

**7.9.2.4.2.12 uint32\_t \_ft\_control\_get\_touch\_count ( uint32\_t *current\_state* )**

**7.9.2.4.2.13 struct ft\_control\_data\* \_ft\_control\_init ( const struct ft\_control \* *control* )**

## Parameters


<i>control</i>	Pointer to the control.
----------------	-------------------------

## Returns


Pointer to create the control data structure. In case of a fail it returns NULL.

The function creates and initializes the control data structure, including the special data of the selected control (keypad, rotary, and so on).

Here is the call graph for this function:




Here is the caller graph for this function:




## Controls

7.9.2.4.2.14 `static int32_t _ft_control_overrun ( struct ft_control_data * control ) [inline], [static]`

Here is the call graph for this function:




Here is the caller graph for this function:




7.9.2.4.2.15 `static void _ft_control_set_flag ( struct ft_control_data * control, uint32_t flags ) [inline], [static]`

Here is the caller graph for this function:



7.9.2.4.2.16 `void _ft_control_set_flag_all_elec ( struct ft_control_data * control, uint32_t flags )`

Here is the call graph for this function:



## Electrodes

### 7.10 Electrodes

#### 7.10.1 Overview

Electrodes are data objects which are used by data acquisition algorithms to store per-electrode data as well as resulting signal and touch / time stamp information.

Each Electrode provides at minimum the processed and normalized signal value, the baseline value, and touch / timestamp buffer containing the time of last few touch and release events. All such common information are contained in the `ft_electrode` structure type. Also, the electrode contains information about the key detector used to detect touches for this physical electrode (this is mandatory). This brings the advantage that each electrode has its own setting of the key detector independent on the module used. It contains information about hardware pin, immediate touch status, and time stamps of the last few touch or release events.

The private electrodes API provides all the functionality needed to handle the private needs of the Freescale Touch library. Collaboration diagram for Electrodes:



## Modules

- API Functions

## Data Structures

- union `ft_electrode_special_data`
- struct `ft_electrode_data`

## Enumerations


- enum `ft_electrode_flags` {
   
    `FT_ELECTRODE_LOCK_BASELINE_REQ_FLAG`,
   
    `FT_ELECTRODE_LOCK_BASELINE_FLAG`,
   
    `FT_ELECTRODE_DIGITAL_RESULT_ONLY_FLAG` }

## 7.10.2 Data Structure Documentation

### 7.10.2.1 union ft\_electrode\_special\_data

The pointer to the special data of the electrode. Each module has its own types handled by this union to keep clearance of the types.

Collaboration diagram for ft\_electrode\_special\_data:



#### Data Fields


struct <b>ft_module_tsi_noise_data</b> *	tsi_noise	Pointer to the TSI noise mode data for the TSI module.
--	-----------	--

### 7.10.2.2 struct ft\_electrode\_data

Electrode RAM structure used to store volatile parameters, flags, and other data, to enable a generic behavior of the Electrode. You must allocate this structure and put a pointer into the [ft\\_electrode](#) structure, when the electrode is being configured and registered in the module and control.

## Electrodes

## Collaboration diagram for ft\_electrode\_data:



## Data Fields

<code>uint16_t</code>	<code>baseline</code>	Baseline.
<code>uint32_t</code>	<code>flags</code>	Flags.
<code>union ft_keydetector_data</code>	<code>keydetector_data</code>	Pointer to the key detector data structure.
<code>struct ft_module_data *</code>	<code>module_data</code>	Pointer to the owner module data.
<code>uint16_t</code>	<code>raw_signal</code>	Raw data to be handled in the task process.
<code>struct ft_electrode *</code>	<code>rom</code>	Pointer to the electrode user parameters.

<code>struct ft_electrode_data *</code>	<code>shielding_electrode</code>	Pointer to a shielding electrode (if it is used).
<code>uint16_t</code>	<code>signal</code>	Processed signal.
<code>union ft_electrode_special_data</code>	<code>special_data</code>	Pointer to the special data (for example noise mode data for the TSI).
<code>struct ft_electrode_status</code>	<code>status[FT_ELECTRODE_STATUS_HISTORY_COUNT]</code>	Statuses.
<code>uint8_t</code>	<code>status_index</code>	Status index.

### 7.10.3 Enumeration Type Documentation

#### 7.10.3.1 enum ft\_electrode\_flags

Electrodes flags which can be set/cleared.

Enumerator

**`FT_ELECTRODE_LOCK_BASELINE_REQ_FLAG`** This flag signals that the electrode's baseline should be locked (can't be updated).

**`FT_ELECTRODE_LOCK_BASELINE_FLAG`** This flag signals that the electrode's baseline is locked (cannot be updated).

**`FT_ELECTRODE_DIGITAL_RESULT_ONLY_FLAG`** This flag signals that the electrode's event does not have analog infomation (cannot be used for analog controls).

## Electrodes

### 7.10.4 API Functions

#### 7.10.4.1 Overview

The functions in this category can be used to manipulate the Electrode objects. Collaboration diagram for API Functions:



## Functions

- struct `ft_electrode_data * _ft_electrode_get_data` (const struct `ft_electrode` \*electrode)  
*Get electrode data structure pointer.*
- `int32_t _ft_electrode_get_index_from_module` (const struct `ft_module` \*module, const struct `ft_electrode` \*electrode)  
*Get the electrode index in the module electrode array structure pointer.*
- struct `ft_electrode_data * _ft_electrode_init` (struct `ft_module_data` \*module, const struct `ft_electrode` \*electrode)  
*Initialize an electrode object.*
- `uint32_t _ft_electrode_shielding_process` (struct `ft_electrode_data` \*electrode, `uint32_t` signal)  
*Process shielding if it is enabled, otherwise it returns the same value.*
- `uint32_t _ft_electrode_normalization_process` (const struct `ft_electrode_data` \*electrode, `uint32_t` signal)  
*Scale signal.*
- `void _ft_electrode_set_signal` (struct `ft_electrode_data` \*electrode, `uint32_t` signal)  
*Set the signal for the electrode.*
- `void _ft_electrode_set_raw_signal` (struct `ft_electrode_data` \*electrode, `uint32_t` signal)  
*Set the raw signal for the electrode.*
- `void _ft_electrode_set_status` (struct `ft_electrode_data` \*electrode, `int32_t` state)  
*Set the status of the electrode.*
- `static void _ft_electrode_set_flag` (struct `ft_electrode_data` \*electrode, `uint32_t` flags)
- `static void _ft_electrode_clear_flag` (struct `ft_electrode_data` \*electrode, `uint32_t` flags)
- `static uint32_t _ft_electrode_get_flag` (struct `ft_electrode_data` \*electrode, `uint32_t` flags)
- `uint32_t _ft_electrode_get_time_offset_period` (const struct `ft_electrode_data` \*electrode, `uint32_t` event\_period)  
*Determine, whether the specified time (or its multiples) has elapsed since the last electrode event.*
- `int32_t _ft_electrode_get_last_status` (const struct `ft_electrode_data` \*electrode)  
*Get the last known electrode status.*
- `uint32_t _ft_electrode_get_time_offset` (const struct `ft_electrode_data` \*electrode)  
*Get the time since the last electrode event.*
- `uint32_t _ft_electrode_get_signal` (const struct `ft_electrode_data` \*electrode)


*Get the normalized and processed electrode signal.*

- `int32_t _ft_electrode_get_status (const struct ft_electrode_data *electrode, uint32_t index)`  
*Get the electrode status by specifying the history buffer index.*
- `uint32_t _ft_electrode_get_last_time_stamp (const struct ft_electrode_data *electrode)`  
*Get the last known electrode time-stamp.*
- `uint32_t _ft_electrode_get_time_stamp (const struct ft_electrode_data *electrode, uint32_t index)`  
*Get the electrode status time-stamp by specifying the history buffer index.*
- `uint32_t _ft_electrode_get_raw_signal (const struct ft_electrode_data *electrode)`  
*Get the raw electrode signal.*
- `int32_t _ft_electrode_get_delta (const struct ft_electrode_data *electrode)`  
*Return difference between the signal and its baseline.*
- `uint32_t _ft_electrode_is_touched (const struct ft_electrode_data *electrode)`  
*Get the state of the electrode.*
- `struct ft_electrode * _ft_electrode_get_shield (const struct ft_electrode *electrode)`  
*Get the shielding electrode.*

#### 7.10.4.2 Function Documentation

##### 7.10.4.2.1 `static void _ft_electrode_clear_flag ( struct ft_electrode_data * electrode, uint32_t flags ) [inline], [static]`

Here is the caller graph for this function:



##### 7.10.4.2.2 `struct ft_electrode_data* _ft_electrode_get_data ( const struct ft_electrode * electrode )`

Parameters


<code>electrode</code>	Pointer to the electrode user parameter structure.
------------------------	--

Returns


The pointer to the data electrode structure that is represented by the handled user parameter structure pointer.

## Electrodes

Here is the call graph for this function:



Here is the caller graph for this function:



### 7.10.4.2.3 int32\_t \_ft\_electrode\_get\_delta ( const struct ft\_electrode\_data \* electrode )

Parameters

<code>electrode</code>	Pointer to the electrode data.
------------------------	--------------------------------

Returns

Immediate delta value between the processed signal and its baseline (idle) value.

Here is the call graph for this function:



**7.10.4.2.4 static uint32\_t \_ft\_electrode\_get\_flag ( struct ft\_electrode\_data \* *electrode*, uint32\_t *flags* ) [inline], [static]**

**7.10.4.2.5 int32\_t \_ft\_electrode\_get\_index\_from\_module ( const struct ft\_module \* *module*, const struct ft\_electrode \* *electrode* )**


Parameters

<i>electrode</i>	Pointer to the electrode user parameter structure.
------------------	--

Returns

The index to the electrode structure array, in case that the electrode is not available it returns -1.

Here is the caller graph for this function:



**7.10.4.2.6 int32\_t \_ft\_electrode\_get\_last\_status ( const struct ft\_electrode\_data \* *electrode* )**

## Electrodes


Parameters

<i>electrode</i>	Pointer to the electrode data.
------------------	--------------------------------

Returns

Current electrode status.

Here is the caller graph for this function:



### 7.10.4.2.7 `uint32_t _ft_electrode_get_last_time_stamp ( const struct ft_electrode_data * electrode )`


Parameters

<i>electrode</i>	Pointer to the electrode data.
------------------	--------------------------------

Returns

Current electrode status.

Here is the caller graph for this function:



#### 7.10.4.2.8 uint32\_t \_ft\_electrode\_get\_raw\_signal ( const struct ft\_electrode\_data \* *electrode* )

Parameters


<i>electrode</i>	Pointer to the electrode data.
------------------	--------------------------------

Returns

Electrode signal, as it is measured by the physical module.

The raw signal is used internally by the filtering and normalization algorithms to calculate the real electrode signal value, which is good to be compared with the signals coming from other electrodes.

Here is the caller graph for this function:



#### 7.10.4.2.9 struct ft\_electrode\* \_ft\_electrode\_get\_shield ( const struct ft\_electrode \* *electrode* )

## Electrodes


Parameters

<i>electrode</i>	Pointer to the electrode.
------------------	---------------------------

Returns

Pointer to the shielding electrode, if available.

Here is the caller graph for this function:



### 7.10.4.2.10 `uint32_t _ft_electrode_get_signal ( const struct ft_electrode_data * electrode )`

Parameters


<i>electrode</i>	Pointer to the electrode data.
------------------	--------------------------------

## Returns

Signal calculated from the last raw value measured.

The signal value is calculated from the raw electrode capacitance or other physical signal by applying the filtering and normalization algorithms. This signal is used by "analog" [Controls](#), which estimate the finger position based on the signal value, rather than on a simple touch / release status.

Here is the caller graph for this function:



### **7.10.4.2.11 int32\_t `_ft_electrode_get_status` ( `const struct ft_electrode_data * electrode`, `uint32_t index` )**

## Parameters

<i>electrode</i>	Pointer to the electrode data.
<i>index</i>	Index of the required status.

## Returns

- status within the `ft_electrode_state`, if the index is within the range
- `FT_FAILURE` if the index is out of range.

### **7.10.4.2.12 uint32\_t `_ft_electrode_get_time_offset` ( `const struct ft_electrode_data * electrode` )**

## Electrodes


Parameters

<i>electrode</i>	Pointer to the electrode data.
------------------	--------------------------------


Returns

Time elapsed since the last electrode event.

Here is the call graph for this function:



Here is the caller graph for this function:



**7.10.4.2.13 `uint32_t _ft_electrode_get_time_offset_period ( const struct ft_electrode_data * electrode, uint32_t event_period )`**

## Parameters


<i>electrode</i>	Pointer to the electrode data.
<i>event_period</i>	Number of time periods that should elapse since the last electrode event.

## Returns

zero if the specified number of time periods has elapsed, or any whole multiple of this number has elapsed since the last electrode event.

This function can be used to determine the multiples of specified time interval since the electrode event has been detected.

Here is the call graph for this function:



#### 7.10.4.2.14 uint32\_t \_ft\_electrode\_get\_time\_stamp ( const struct ft\_electrode\_data \* *electrode*, uint32\_t *index* )

## Parameters

<i>electrode</i>	Pointer to the electrode data.
<i>index</i>	Index of the required status.

## Returns

- non-zero value (valid time stamp)
- 0 - index out of range

#### 7.10.4.2.15 struct ft\_electrode\_data\* \_ft\_electrode\_init ( struct ft\_module\_data \* *module*, const struct ft\_electrode \* *electrode* )

## Electrodes

Parameters


<i>module</i>	Pointer to the module data.
<i>electrode</i>	Pointer to the electrode.

Returns

Pointer to the newly-created electrode data structure. (In case of a fail, it returns NULL).

This function creates the electrode data, and resets the electrode's status and status index.

Here is the call graph for this function:



### 7.10.4.2.16 uint32\_t \_ft\_electrode\_is\_touched ( const struct ft\_electrode\_data \* *electrode* )


Parameters

<i>electrode</i>	Pointer to the electrode data.
------------------	--------------------------------

Returns

Non-zero if the current electrode status is "touched"; zero otherwise.

Here is the caller graph for this function:



7.10.4.2.17 **uint32\_t \_ft\_electrode\_normalization\_process ( const struct ft\_electrode\_data \*  
electrode, uint32\_t signal )**

## Electrodes

Parameters

<i>electrode</i>	A pointer to the electrode data.
<i>signal</i>	


Returns

*signal*

Normalize the signal to working values. Values from [ft\\_electrode](#) divider or multiplier normalize the measured signal.

**7.10.4.2.18 static void \_ft\_electrode\_set\_flag ( struct ft\_electrode\_data \* *electrode*, uint32\_t *flags* ) [inline], [static]**

Here is the caller graph for this function:



**7.10.4.2.19 void \_ft\_electrode\_set\_raw\_signal ( struct ft\_electrode\_data \* *electrode*, uint32\_t *signal* )**


Parameters

<i>electrode</i>	Pointer to the electrode data.
<i>signal</i>	

Returns

none

Here is the caller graph for this function:



#### 7.10.4.2.20 void \_ft\_electrode\_set\_signal ( struct ft\_electrode\_data \* electrode, uint32\_t signal )

Parameters

<i>electrode</i>	A pointer to the electrode.
<i>signal</i>	

Returns

none

#### 7.10.4.2.21 void \_ft\_electrode\_set\_status ( struct ft\_electrode\_data \* electrode, int32\_t state )

Parameters

<i>electrode</i>	A pointer to the electrode data.
<i>state</i>	ft_electrode_state


Returns

none

This function sets the state of the electrode, and assigns a time stamp from the system to the electrode.

## Electrodes

Here is the call graph for this function:



Here is the caller graph for this function:



### 7.10.4.2.22 uint32\_t \_ft\_electrode\_shielding\_process ( struct ft\_electrode\_data \* *electrode*, uint32\_t *signal* )

Parameters

<i>electrode</i>	A pointer to the electrode data.
<i>signal</i>	Current signal value.

Returns

signal value.

The signal is subtracted by the baseline, and incremented by the signal. If the signal is greater than 0, it returns the signal value other than 0.

Here is the call graph for this function:



## Filters

### 7.11 Filters

#### 7.11.1 Overview

The filters data structure that is used in the Freescale Touch library. Collaboration diagram for Filters:



## Modules

- [API Functions](#)

## Data Structures

- [struct ft\\_filter\\_fbutt\\_data](#)
- [struct ft\\_filter\\_moving\\_average\\_data](#)

## Enumerations


- [enum ft\\_filter\\_state {  
 FT\\_FILTER\\_STATE\\_INIT,  
 FT\\_FILTER\\_STATE\\_RUN }](#)

### 7.11.2 Data Structure Documentation

#### 7.11.2.1 [struct ft\\_filter\\_fbutt\\_data](#)

The butterworth filter context data.

Collaboration diagram for ft\_filter\_fbutt\_data:




Data Fields

int32_t	coeficient	
int16_t	x	The previous input value.
int32_t	y	The last result of the filter.

#### 7.11.2.2 struct ft\_filter\_moving\_average\_data

The moving average filter context data.

Collaboration diagram for ft\_filter\_moving\_average\_data:



## Filters

Data Fields

int32_t	sum	The sum of the filter data
---------	-----	----------------------------

### 7.11.3 Enumeration Type Documentation

#### 7.11.3.1 enum ft\_filter\_state

The filter state definition.

Enumerator

*FT\_FILTER\_STATE\_INIT* The filter is initialized.

*FT\_FILTER\_STATE\_RUN* The filter is running correctly.

## 7.11.4 API Functions

### 7.11.4.1 Overview

General Private Function definition of filters. Collaboration diagram for API Functions:



## Functions

- `uint32_t _ft_abs_int32 (int32_t lsrc)`  
*Gets the absolute value.*
- `void _ft_filter_fbutt_init (const struct ft_filter_fbutt *rom, struct ft_filter_fbutt_data *ram, uint32_t signal)`  
*Initialize the ButterWorth filter for the first use.*
- `uint16_t _ft_filter_fbutt_process (struct ft_filter_fbutt_data *ram, uint16_t signal)`  
*Process signal fbutt filter.*
- `uint32_t _ft_filter_iir_process (const struct ft_filter_iir *rom, uint32_t signal, uint32_t previous_signal)`  
*Process signal IIR filter.*
- `int32_t _ft_filter_moving_average_init (const struct ft_filter_moving_average *rom, struct ft_filter_moving_average_data *ram, uint16_t value)`  
*This function initialize moving average filter.*
- `uint32_t _ft_filter_moving_average_process (const struct ft_filter_moving_average *rom, struct ft_filter_moving_average_data *ram, uint16_t value)`  
*This function compute moving average filter.*
- `uint16_t _ft_filter_abs (int16_t value)`  
*This function compute absolute value (16-bit version).*
- `uint16_t _ft_filter_limit_u (int32_t value, uint16_t limit_l, uint16_t limit_h)`  
*This function limit the input value in allowd range (16-bit version).*
- `uint16_t _ft_filter_deadrange_u (uint16_t value, uint16_t base, uint16_t range)`  
*This function make dead range for input value out of the allowed range (16-bit version).*
- `int32_t _ft_filter_is_deadrange_u (uint16_t value, uint16_t base, uint16_t range)`  
*This function checks if input value is inside of the deadband range (16-bit version).*

### 7.11.4.2 Function Documentation

#### 7.11.4.2.1 `uint32_t _ft_abs_int32 ( int32_t lsrc )`

## Filters

Parameters

<i>lsrc</i>	Input signed 32-bit number.
-------------	-----------------------------

Returns

Unsigned 32-bit absolute value of the input number.

### 7.11.4.2.2 `uint16_t _ft_filter_abs ( int16_t value )`

Parameters

<i>value</i>	Input signed value.
--------------	---------------------

Returns

Absolute unsigned value of input.

### 7.11.4.2.3 `uint16_t _ft_filter_deadrange_u ( uint16_t value, uint16_t base, uint16_t range )`


Parameters

<i>value</i>	Input value.
<i>base</i>	Base value of deadband range.
<i>range</i>	Range of the deadband range (one half).

Returns

Result value out of the deadband range.

Here is the call graph for this function:



7.11.4.2.4 `void _ft_filter_fbutt_init( const struct ft_filter_fbutt *rom, struct ft_filter_fbutt_data *ram, uint32_t signal )`

## Filters

Parameters

<i>rom</i>	Pointer to the <a href="#">ft_filter_fbutt</a> structure.
<i>ram</i>	Pointer to the <a href="#">ft_filter_fbutt_data</a> .
<i>signal</i>	Input signal.

Returns

none

Here is the call graph for this function:



### 7.11.4.2.5 uint16\_t \_ft\_filter\_fbutt\_process ( struct ft\_filter\_fbutt\_data \* ram, uint16\_t signal )

Parameters

<i>ram</i>	Pointer to the <a href="#">ft_filter_fbutt_data</a> structure.
<i>signal</i>	Input signal.

Returns

Filtered signal.

Returns signal equal

### 7.11.4.2.6 uint32\_t \_ft\_filter\_iir\_process ( const struct ft\_filter\_iir \* rom, uint32\_t signal, uint32\_t previous\_signal )

Parameters

<i>rom</i>	Pointer to <a href="#">ft_filter_iir</a>
<i>signal</i>	Current signal.
<i>previous_signal</i>	Previous signal

Returns

*signal*

Process the signal, using the following equation:  $y(n) = (1 / (\text{coef} + 1)) * \text{current signal} + (\text{coef} / (\text{coef} + 1)) * \text{previous\_signal}$

#### **7.11.4.2.7 int32\_t \_ft\_filter\_is\_deadrange\_u ( uint16\_t value, uint16\_t base, uint16\_t range )**


Parameters

<i>value</i>	Input value.
<i>base</i>	Base value of deadband range.
<i>range</i>	Range of the deadband range (one half).

Returns

Result TRUE - value is in deadband range. FALSE - value is out of deadband range.

Here is the caller graph for this function:



#### **7.11.4.2.8 uint16\_t \_ft\_filter\_limit\_u ( int32\_t value, uint16\_t limit\_l, uint16\_t limit\_h )**

## Filters

Parameters

<i>value</i>	Input value.
<i>limit_l</i>	Limitation low range border.
<i>limit_H</i>	Limitation high range border.

Returns

Result value.

Here is the caller graph for this function:



### 7.11.4.2.9 int32\_t \_ft\_filter\_moving\_average\_init ( const struct ft\_filter\_moving\_average \* rom, struct ft\_filter\_moving\_average\_data \* ram, uint16\_t value )

Parameters

<i>rom</i>	Pointer to <a href="#">ft_filter_moving_average</a> structure.
<i>ram</i>	Pointer to <a href="#">ft_filter_moving_average_data</a> structure.
<i>value</i>	Input initial value.

Returns

result of operation (0 - OK, otherwise - FALSE).

### 7.11.4.2.10 uint32\_t \_ft\_filter\_moving\_average\_process ( const struct ft\_filter\_moving\_average \* rom, struct ft\_filter\_moving\_average\_data \* ram, uint16\_t value )

## Parameters

<i>rom</i>	Pointer to <a href="#">ft_filter_moving_average</a> structure.
<i>ram</i>	Pointer to <a href="#">ft_filter_moving_average_data</a> structure.
<i>value</i>	Input new value.

## Returns

Current value of the moving average filter.

## Filters

### 7.11.5 Advanced Filtering and Integrating Detection

#### 7.11.5.1 Overview

The AFID (Advanced Filtering and Integrating Detection) key detector is based on using two IIR filters with different depths (one short / fast, the other long / slow) and on integrating the difference between the two filtered signals. The algorithm uses two thresholds; the touch threshold and the release threshold. The touch threshold is defined in the sensitivity register. The release threshold has twice the lower level than the touch threshold. If the integrated signal is higher than the touch threshold, or lower than the release threshold, then the integrated signal is reset. The Touch state is reported for the electrode when the first touch reset is detected. The Release state is reported, when as many release resets as the touch resets were detected during the previous touch state. Collaboration diagram for Advanced Filtering and Integrating Detection:



#### Data Structures

- struct `ft_keydetector_afid_asc_data`
- struct `ft_keydetector_afid_data`

#### Macros


- #define `FT_KEYDETECTOR_AFID_INITIAL_INTEGRATOR_VALUE`
- #define `FT_KEYDETECTOR_AFID_INITIAL_RESET_TOUCH_COUNTER_VALUE`
- #define `FT_KEYDETECTOR_AFID_INITIAL_RESET_RELEASE_COUNTER_VALUE`

#### 7.11.5.2 Data Structure Documentation

##### 7.11.5.2.1 struct `ft_keydetector_afid_asc_data`

AFID Automatic Sensitive Calibration RAM structure; This structure is used for internal algorithms to store the data while evaluating the AFID. Contains data of the calculating result and auxiliary variables. This structure only manages and uses the internal methods.

Collaboration diagram for ft\_keydetector\_afid\_asc\_data:



Data Fields

int32_t	max_resets
---------	------------


#### 7.11.5.2.2 struct ft\_keydetector\_afid\_data

AFID Ram structure; This structure is used for internal algorithms to store the data while evaluating the AFID. Contains the data of the calculating result and auxiliary variables.

This structure only manages and uses the internal methods.

## Filters

Collaboration diagram for ft\_keydetector\_afid\_data:



## Data Fields

struct <b>ft_keydetector_afid_asc_data</b>	asc	Storage of ASC (Automatic sensitive calibration) data for AFID
struct <b>ft_filter_moving_average_data</b>	base_avrg	Base line moving average filter data.
struct <b>ft_filter_fbutt_data</b>	fast_signal_filter	Signal fast butterworth filter data storage.
uint8_t	filter_state	State of filter.
int32_t	integration_value	Current value of internal integrator.

uint32_t	release_reset_counter	Count of release events resets.
uint16_t	slow_signal	Slow signal value.
struct ft_filter_fbutt_data	slow_signal_filter	Signal slow butterworth filter data storage.
uint32_t	touch_reset_counter	Count of touch resets.
uint32_t	touch_threshold	Current threshold value for integrator resets.

### 7.11.5.3 Macro Definition Documentation

#### 7.11.5.3.1 #define FT\_KEYDETECTOR\_AFID\_INITIAL\_INTEGRATOR\_VALUE

The initial integration value of the AFID.

#### 7.11.5.3.2 #define FT\_KEYDETECTOR\_AFID\_INITIAL\_RESET\_RELEASE\_COUNTER\_VALUE

The reset threshold value of the AFID.

#### 7.11.5.3.3 #define FT\_KEYDETECTOR\_AFID\_INITIAL\_RESET\_TOUCH\_COUNTER\_VALUE

The initial reset counter value of the AFID.

## Key Detectors

### 7.12 Key Detectors

#### 7.12.1 Overview

The key detector module determines, whether an electrode has been touched or released, based on the values obtained by the capacitive sensing layer. Along with this detection, the key detector module uses a debounce algorithm that prevents the library from false touches. The key detector also detects, reports, and acts on fault conditions during the scanning process. Two main fault conditions are identified according to the electrode short-circuited either to the supply voltage or to the ground. The same conditions can be caused by a small capacitance (equal to a short circuit to supply voltage) or by a big capacitance (equals to a short circuit to the ground). Collaboration diagram for Key Detectors:



## Modules

- Advanced Filtering and Integrating Detection

## Data Structures


- union [ft\\_keydetector\\_data](#)

### 7.12.2 Data Structure Documentation

#### 7.12.2.1 union ft\_keydetector\_data

The key detector optional run-time data.

Collaboration diagram for ft\_keydetector\_data:



#### Data Fields

struct ft_keydetector_afid_data *	afid	AFID electrode run-time data
---	------	------------------------------

## Key Detectors

### 7.12.3 GPIO module

#### 7.12.3.1 Overview

The GPIO module describes the hardware configuration and control of the elementary functionality of the method that is using standard GPIO pins of the MCU.

The GPIO method is designed for all general processors that have a GPIO module. Collaboration diagram for GPIO module:



#### Data Structures


- struct [ft\\_module\\_gpio\\_data](#)

#### 7.12.3.2 Data Structure Documentation

##### 7.12.3.2.1 struct ft\_module\_gpio\_data

GPIO module's RAM. This structure contains

Collaboration diagram for `ft_module_gpio_data`:



## Data Fields

uint32_t	pen	PEN - enablement of all modules electrodes
----------	-----	--

## Key Detectors

### 7.12.4 GPIO interrupt module

#### 7.12.4.1 Overview

The GPIO interrupt module describes the hardware configuration and control of the elementary functionality of the method that is using standard GPIO pins of the MCU with the GPIO and timer interrupts.

The GPIO interrupt method is designed for all general processors that have a GPIO module with interrupt capability. Collaboration diagram for GPIO interrupt module:



## Data Structures


- struct `ft_module_gpioint_data`

### 7.12.4.2 Data Structure Documentation

#### 7.12.4.2.1 struct `ft_module_gpioint_data`

GPIO interrupt module's RAM. This structure contains

Collaboration diagram for `ft_module_gpioint_data`:



## Data Fields

uint8_t	measured_pin	The currently measured pin
uint32_t	pen	PEN - enablement of all modules' electrodes
uint8_t	scan_status	Module's scanning status - see enum ft_gpio_scan_states

## Key Detectors

### 7.12.5 TSI module

#### 7.12.5.1 Overview

The TSI module describes the hardware configuration and control of elementary functionality of the TSI peripheral, it covers all versions of the TSI peripheral by a generic low-level driver API.

The TSI module is designed for processors that have a hardware TSI module with version 1, 2, or 4 (for example Kinetis L).

The module also handles the NOISE mode supported by TSI v4 (Kinetis L). Collaboration diagram for TSI module:



## Data Structures

- struct `ft_module_tsi_noise_data`
- struct `ft_module_tsi_data`

## Macros

- #define `FT_TSI_NOISE_INITIAL_TOUCH_THRESHOLD`
- #define `FT_TSI_NOISE_TOUCH_RANGE`

## Enumerations

- enum `ft_module_tsi_flags` {
 `FT_MODULE_IN_NOISE_MODE_FLAG`,
 `FT_MODULE_HAS_NOISE_MODE_FLAG`,
 `FT_MODULE_NOISE_MODE_REQ_FLAG` }


### 7.12.5.2 Data Structure Documentation

#### 7.12.5.2.1 struct `ft_module_tsi_noise_data`

Noise data structure; This structure is used for internal algorithms to store data while evaluating the noise. Contains data of calculating the result and auxiliary variables.

This structure manages and uses internal methods only.

Collaboration diagram for ft\_module\_tsi\_noise\_data:




#### Data Fields

enum <a href="#">ft_filter_state</a>	filter_state	Noise filter state.
uint8_t	noise	Noise current value.
uint8_t	touch_- threshold	Noise touch threshold run-time value.

#### 7.12.5.2.2 struct ft\_module\_tsi\_data

Collaboration diagram for ft\_module\_tsi\_data:



## Key Detectors

Data Fields

tsi_state_t	tsi_state	
-------------	-----------	--

### 7.12.5.3 Macro Definition Documentation

#### 7.12.5.3.1 `#define FT_TSI_NOISE_INITIAL_TOUCH_THRESHOLD`

The TSI module noise mode initial touch threshold value.

#### 7.12.5.3.2 `#define FT_TSI_NOISE_TOUCH_RANGE`

The TSI module noise mode touch range value.

### 7.12.5.4 Enumeration Type Documentation

#### 7.12.5.4.1 `enum ft_module_tsi_flags`

The TSI module's noise mode flags definition.

Enumerator

**`FT_MODULE_IN_NOISE_MODE_FLAG`** This flag signalises that the module is currently in the noise mode.

**`FT_MODULE_HAS_NOISE_MODE_FLAG`** This flag signalises that the module can be switched to the noise mode (TSI v4).


**`FT_MODULE_NOISE_MODE_REQ_FLAG`** This flag signalises that the module wants to switch to the noise mode.

## 7.13 Modules

### 7.13.1 Overview

Modules represent the data-acquisition layer in the Freescale Touch system, it is the layer that is tightly coupled to hardware module available on the Freescale MCU device.

Each Module implements a set of private functions contained in the [ft\\_modules\\_prv.h](#) file. Collaboration diagram for Modules:



## Modules

- [GPIO module](#)
- [GPIO interrupt module](#)
- [TSI module](#)
- [General API](#)

## Modules

### 7.13.2 General API

#### 7.13.2.1 Overview

General API and definition over all modules. Collaboration diagram for General API:



## Modules

- API functions

## Data Structures


- union `ft_module_special_data`
- struct `ft_module_data`
- struct `ft_module_interface`

### 7.13.2.2 Data Structure Documentation

#### 7.13.2.2.1 union `ft_module_special_data`

The module optional run-time data.

Collaboration diagram for ft\_module\_special\_data:



#### Data Fields


<code>struct ft_module_gpio_data *</code>	<code>gpio</code>	GPIO module run-time data
<code>struct ft_module_gpiont_data *</code>	<code>gpiont</code>	GPIO interrupt module run-time data
<code>struct ft_module_tsi_data *</code>	<code>tsi</code>	TSI module run-time data

#### 7.13.2.2.2 struct ft\_module\_data

Module RAM structure used to store volatile parameters, flags, and other data to enable a generic behavior of the Module. This is the main internal structure for a module in the FT library. A list of pointers to the electrode RAM data structure is created.

# Modules

## Collaboration diagram for ft\_module\_data:



## Data Fields

<code>enum ft_module_mode</code>	<code>active_mode</code>	Active mode of the module.
<code>struct ft_electrode_data **</code>	<code>electrodes</code>	Pointer to the list of electrodes. Can't be NULL.
<code>uint8_t</code>	<code>electrodes_cnt</code>	Electrode's count.
<code>uint32_t</code>	<code>flags</code>	Module's symptoms.
<code>struct ft_module *</code>	<code>rom</code>	Pointer to the module parameters defined by the user.
<code>union ft_module_special_data</code>	<code>special_data</code>	Pointer to the special data (for example run-time data for the GPIO).

### 7.13.2.2.3 struct ft\_module\_interface

Module interface structure; each module uses this structure to register the entry points to its algorithms. This approach enables a kind-of polymorphism in the touch System. All modules are processed the same way from the System layer, regardless of the specific implementation. Each module type defines one static constant structure of this type to register its own initialization, triggering, processing functions, and functions for enabling or disabling of electrodes, low power, and proximity.

Collaboration diagram for ft\_module\_interface:

ft_module_interface
+ init + trigger + process + recalibrate + electrode_enable + electrode_disable + change_mode + load_configuration + save_configuration + name

#### Data Fields

- int32\_t(\* init )(struct **ft\_module\_data** \*module)
- int32\_t(\* trigger )(struct **ft\_module\_data** \*module)
- int32\_t(\* process )(struct **ft\_module\_data** \*module)
- int32\_t(\* recalibrate )(struct **ft\_module\_data** \*module, void \*configuration)
- int32\_t(\* electrode\_enable )(struct **ft\_module\_data** \*module, const uint32\_t elec\_index)
- int32\_t(\* electrode\_disable )(struct **ft\_module\_data** \*module, const uint32\_t elec\_index)
- int32\_t(\* change\_mode )(struct **ft\_module\_data** \*module, const enum **ft\_module\_mode** mode, const struct **ft\_electrode** \*electrode)
- int32\_t(\* load\_configuration )(struct **ft\_module\_data** \*module, const enum **ft\_module\_mode** mode, const void \*config)
- int32\_t(\* save\_configuration )(struct **ft\_module\_data** \*module, const enum **ft\_module\_mode** mode, void \*config)
- const char \* **name**

## Modules

### 7.13.2.2.3.1 Field Documentation

**7.13.2.2.3.1.1 int32\_t(\* ft\_module\_interface::change\_mode)(struct ft\_module\_data \*module, const enum ft\_module\_mode mode, const struct ft\_electrode \*electrode)**

Change the the mode of the module.

**7.13.2.2.3.1.2 int32\_t(\* ft\_module\_interface::electrode\_disable)(struct ft\_module\_data \*module, const uint32\_t elec\_index)**

Disable the module electrode in hardware.

**7.13.2.2.3.1.3 int32\_t(\* ft\_module\_interface::electrode\_enable)(struct ft\_module\_data \*module, const uint32\_t elec\_index)**

Enable the module electrode in hardware.

**7.13.2.2.3.1.4 int32\_t(\* ft\_module\_interface::init)(struct ft\_module\_data \*module)**

The initialization of the module.

**7.13.2.2.3.1.5 int32\_t(\* ft\_module\_interface::load\_configuration)(struct ft\_module\_data \*module, const enum ft\_module\_mode mode, const void \*config)**

Load the configuration for the selected mode.

**7.13.2.2.3.1.6 const char\* ft\_module\_interface::name**

A name of the variable of this type, used for FreeMASTER support purposes.

**7.13.2.2.3.1.7 int32\_t(\* ft\_module\_interface::process)(struct ft\_module\_data \*module)**

Process the read data from the trigger event.

**7.13.2.2.3.1.8 int32\_t(\* ft\_module\_interface::recalibrate)(struct ft\_module\_data \*module, void \*configuration)**

Force recalibration of the module in the current mode.

**7.13.2.2.3.1.9 int32\_t(\* ft\_module\_interface::save\_configuration)(struct ft\_module\_data \*module, const enum ft\_module\_mode mode, void \*config)**

Save the configuration of the selected mode.

**7.13.2.2.3.1.10 int32\_t(\* ft\_module\_interface::trigger)(struct ft\_module\_data \*module)**

Send a trigger event into the module to perform hardware reading of the touches.

### 7.13.2.3 API functions

#### 7.13.2.3.1 Overview

General Private Function definition of the modules. Collaboration diagram for API functions:



#### Functions

- struct `ft_module_data * _ft_module_get_data` (const struct `ft_module *module`)  
*Get the module data structure pointer.*
- struct `ft_module_data * _ft_module_init` (const struct `ft_module *module`)  
*Init module.*
- int32\_t `_ft_module_trigger` (struct `ft_module_data *module`)  
*Trigger the start of measure event of the module.*
- int32\_t `_ft_module_process` (struct `ft_module_data *module`)  
*Process the module.*
- static void `_ft_module_set_flag` (struct `ft_module_data *module`, uint32\_t `flags`)  
*Set the flag of the module.*
- static void `_ft_module_clear_flag` (struct `ft_module_data *module`, uint32\_t `flags`)  
*Reset the flag of the module.*
- static uint32\_t `_ft_module_get_flag` (struct `ft_module_data *module`, uint32\_t `flags`)  
*Return the flag of the module.*
- static uint32\_t `_ft_module_get_instance` (const struct `ft_module_data *module`)  
*Return the instance of the module.*
- static void `_ft_module_set_mode` (struct `ft_module_data *module`, uint32\_t `mode`)  
*Set the module's mode.*
- static uint32\_t `_ft_module_get_mode` (struct `ft_module_data *module`)  
*Get the module's mode.*

#### 7.13.2.3.2 Function Documentation

##### 7.13.2.3.2.1 static void `_ft_module_clear_flag` ( `struct ft_module_data * module`, `uint32_t flags` ) [inline], [static]

## Modules


Parameters

<i>module</i>	Pointer to the FT module.
<i>flags</i>	The flags to be cleared.

Returns

void

Here is the caller graph for this function:



### 7.13.2.3.2.2 struct ft\_module\_data\* \_ft\_module\_get\_data ( const struct ft\_module \* *module* )

Parameters

<i>module</i>	Pointer to the module user parameter structure.
---------------	---


Returns

Pointer to the data module structure that is represented by the handled user parameter structure pointer.

Here is the call graph for this function:



Here is the caller graph for this function:



**7.13.2.3.2.3 `static uint32_t _ft_module_get_flag ( struct ft_module_data * module, uint32_t flags ) [inline], [static]`**

Parameters


<i>module</i>	Pointer to the FT module.
<i>flags</i>	The flags to be tested

## Modules

Returns

Non-zero if any of the tested flags are set. This is bit-wise AND of the control flags and the flags parameter.

Here is the caller graph for this function:



**7.13.2.3.2.4 static uint32\_t \_ft\_module\_get\_instance ( const struct ft\_module\_data \* *module* ) [inline], [static]**

Parameters

<i>module</i>	Pointer to the FT module.
---------------	---------------------------

Returns

instance

**7.13.2.3.2.5 static uint32\_t \_ft\_module\_get\_mode ( struct ft\_module\_data \* *module* ) [inline], [static]**

Parameters

<i>module</i>	Pointer to the FT module_data.
---------------	--------------------------------

Returns

mode.

**7.13.2.3.2.6 struct ft\_module\_data\* \_ft\_module\_init ( const struct ft\_module \* *module* )**


Parameters

<i>module</i>	Pointer to the module to be initialized.
---------------	--


Returns

The result of the operation.

Here is the call graph for this function:



Here is the caller graph for this function:



#### 7.13.2.3.2.7 int32\_t \_ft\_module\_process ( struct ft\_module\_data \* *module* )

## Modules


Parameters

<i>module</i>	Pointer to the module to be processed.
---------------	--


Returns

The result of the operation.

Here is the call graph for this function:



Here is the caller graph for this function:



**7.13.2.3.2.8 static void `_ft_module_set_flag` ( `struct ft_module_data * module`, `uint32_t flags` )**  
`[inline], [static]`


Parameters

<i>module</i>	Pointer to the FT module.
<i>flags</i>	The flags to be set.

Returns

void

Here is the caller graph for this function:



#### 7.13.2.3.2.9 static void \_ft\_module\_set\_mode ( struct ft\_module\_data \* *module*, uint32\_t *mode* ) [inline], [static]


Parameters

<i>module</i>	Pointer to the FT module.
<i>mode</i>	

Returns

None.

Here is the caller graph for this function:



## Modules

7.13.2.3.2.10 `int32_t _ft_module_trigger( struct ft_module_data * module )`


## Parameters

<i>module</i>	Pointer to the module to be triggered.
---------------	--


## Returns

The result of the operation.

Here is the call graph for this function:



Here is the caller graph for this function:



## FreeMASTER support

### 7.14 FreeMASTER support

#### 7.14.1 Overview

Collaboration diagram for FreeMASTER support:



## Modules

- API functions

## 7.14.2 API functions

### 7.14.2.1 Overview

General Private Function definition of the FreeMASTER support. Collaboration diagram for API functions:



## Functions

- int32\_t `_ft_freemaster_init` (void)  
*Initialized the Freescale touch FreeMASTER support system.*
- int32\_t `_ft_freemaster_add_variable` (const char \**name*, const char \**type\_name*, void \**address*, uint32\_t *size*)  
*This function adds a dynamic variable into the FreeMASTER TSA table.*

### 7.14.2.2 Function Documentation

#### 7.14.2.2.1 int32\_t `_ft_freemaster_add_variable` ( const char \* *name*, const char \* *type\_name*, void \* *address*, uint32\_t *size* )

Parameters


<i>name</i>	- pointer to the string with the name of the variable
<i>type_name</i>	- pointer to the string with the name of the variable type
<i>address</i>	- address of the variable
<i>size</i>	- size of the variable

## FreeMASTER support

Returns

The result of the operation.

Here is the caller graph for this function:




### 7.14.2.2.2 int32\_t \_ft\_freemaster\_init ( void )

Returns

The result of operation.


Here is the caller graph for this function:



## 7.15 Memory Management

### 7.15.1 Overview

Collaboration diagram for Memory Management:



## Modules

- API functions

## Data Structures


- struct `ft_mem`

### 7.15.2 Data Structure Documentation

#### 7.15.2.1 struct `ft_mem`

This structure contains the memory pool for all RAM data of the Freescale touch volatile data structures. This structure can be allocated in RAM.

Collaboration diagram for `ft_mem`:



## Memory Management

### Data Fields

<code>uint8_t *</code>	<code>free_pointer</code>	Pointer to the last free position in the memory pool.
<code>uint8_t *</code>	<code>pool</code>	Pointer to the allocated memory pool for the Freescale touch.
<code>uint32_t</code>	<code>pool_size</code>	Size of the allocated memory pool for the Freescale touch.

### 7.15.3 API functions

#### 7.15.3.1 Overview

General Private Function definition of the memory support. Collaboration diagram for API functions:



## Functions

- int32\_t `_ft_mem_init` (uint8\_t \*pool, const uint32\_t size)  
*Initialized the Freescale touch memory management system.*
- void \* `_ft_mem_alloc` (const uint32\_t size)  
*Allocation of memory from the memory pool.*
- int32\_t `_ft_mem_deinit` (void)  
*Deinitialized the Freescale touch memory management system.*

#### 7.15.3.2 Function Documentation

##### 7.15.3.2.1 void\* `_ft_mem_alloc` ( const uint32\_t size )

Parameters

<code>size</code>	- size of the memory block to allocate.
-------------------	---

Returns


The pointer to the new allocated block, NULL in case there is not enough space in the pool.

Here is the call graph for this function:



## Memory Management

Here is the caller graph for this function:



### 7.15.3.2.2 int32\_t \_ft\_mem\_deinit ( void )

Returns

The result of the operation.

Here is the call graph for this function:



### 7.15.3.2.3 int32\_t \_ft\_mem\_init ( uint8\_t \* pool, const uint32\_t size )

Parameters

<i>pool</i>	- pointer to the allocated memory place to be used by the system (the size must be aligned by 4).
<i>size</i>	- size of the memory pool handled by the pool parameter.

Returns

The result of the operation.

Here is the call graph for this function:



Here is the caller graph for this function:



## Memory Management




## Chapter 8

### Freescale Touch Private API

#### 8.1 Overview

The functions documented in this module are the private ones used by the library itself. All the API here is just documented and not designed to be used by the user. Collaboration diagram for Freescale Touch Private API:



#### Modules

- Controls
- Electrodes
- Filters
- Key Detectors
- Modules
- FreeMASTER support
- Memory Management

## Overview

- System

## 8.2 System

### 8.2.1 Overview

/

The system private API and definitions. Collaboration diagram for System:



## Modules

- API Functions

## Data Structures

- struct `ft_kernel`

## Enumerations

- enum `ft_system_module_call` {  
    `FT_SYSTEM_MODULE_INIT`,  
    `FT_SYSTEM_MODULE_TRIGGER`,  
    `FT_SYSTEM_MODULE_PROCESS`,  
    `FT_SYSTEM_MODULE_CHECK_DATA` }
- enum `ft_system_control_call` {  
    `FT_SYSTEM_CONTROL_INIT`,  
    `FT_SYSTEM_CONTROL_PROCESS`,  
    `FT_SYSTEM_CONTROL_OVERRUN`,  
    `FT_SYSTEM_CONTROL_DATA_READY` }


### 8.2.2 Data Structure Documentation

#### 8.2.2.1 struct `ft_kernel`

System RAM structure used to store volatile parameters, counter, and system callback functions. This is the only statically placed RAM variable in the whole Freescale Touch library.

## System

Collaboration diagram for ft\_kernel:



## Data Fields

<b>ft_system_callback</b>	callback	System event handler.
struct <b>ft_control_data</b> **	controls	Pointer to the list of controls. Can't be NULL.
uint8_t	controls_cnt	Count of the controls.
struct <b>ft_mem</b>	memory	System Memory handler
struct <b>ft_module_data</b> **	modules	Pointer to the list of modules. Can't be NULL.

uint8_t	modules_cnt	Count of the modules.
struct <a href="#">ft_system</a> *	rom	Pointer to the system parameters.
uint32_t	time_counter	Time counter.

## 8.2.3 Enumeration Type Documentation

### 8.2.3.1 enum ft\_system\_control\_call

Internal Controls function call identifier

Enumerator

***FT\_SYSTEM\_CONTROL\_INIT*** Do control initialization.

***FT\_SYSTEM\_CONTROL\_PROCESS*** Process the new data of control.

***FT\_SYSTEM\_CONTROL\_OVERRUN*** Control data are overrun.

***FT\_SYSTEM\_CONTROL\_DATA\_READY*** Control data are ready.

### 8.2.3.2 enum ft\_system\_module\_call

Internal Module function call identifier

Enumerator

***FT\_SYSTEM\_MODULE\_INIT*** Do module initialization.

***FT\_SYSTEM\_MODULE\_TRIGGER*** Send trigger event to module.

***FT\_SYSTEM\_MODULE\_PROCESS*** Do process data in the module.

***FT\_SYSTEM\_MODULE\_CHECK\_DATA*** Check the module data.

## System

### 8.2.4 API Functions

#### 8.2.4.1 Overview

General Private Function definition of system. Collaboration diagram for API Functions:



## Functions

- struct `ft_kernel * _ft_system_get` (void)  
*Obtain a pointer to the system.*
- void `_ft_system_increment_time_counter` (void)  
*Increments the system counter.*
- uint32\_t `_ft_system_get_time_period` (void)  
*Get time period.*
- uint32\_t `_ft_system_get_time_offset` (uint32\_t event\_stamp)  
*Elapsed time based on the event stamp.*
- uint32\_t `_ft_system_get_time_offset_from_period` (uint32\_t event\_period)  
*Time offset by a defined period.*
- int32\_t `_ft_system_module_function` (uint32\_t option)  
*Invoke the module function based on the option parameter.*
- int32\_t `_ft_system_control_function` (uint32\_t option)  
*Invoke the control function based on the option parameter.*
- int32\_t `_ft_system_init` (const struct `ft_system` \*system)  
*Initialize system.*
- void `_ft_system_invoke_callback` (uint32\_t event)  
*System callback invocation.*
- void `_ft_system_modules_data_ready` (void)  
*Function used internally to detect, whether new `Modules` data are available and to set the same flag for the controls. This function also invokes the control callbacks.*
- struct `ft_module * _ft_system_get_module` (uint32\_t interface\_address, uint32\_t instance)  
*Find the n-th instance of a module of a specified type.*
- void `ft_error` (char \*file\_name, uint32\_t line)  
*The FT error function that is invoked from FT asserts.*

#### 8.2.4.2 Function Documentation

##### 8.2.4.2.1 int32\_t \_ft\_system\_control\_function ( uint32\_t option )


Parameters

<i>option</i>	One of the options from ft_system_control_call enum
---------------	---


Returns

- FT\_SUCCESS if the control's action was carried out successfully,
- FT\_FAILURE if the control's action failed.

Here is the call graph for this function:



Here is the caller graph for this function:




#### 8.2.4.2.2 struct ft\_kernel\* \_ft\_system\_get ( void )

## System

Returns

A pointer to the system kernel structure.

Here is the caller graph for this function:



**8.2.4.2.3 struct ft\_module\* \_ft\_system\_get\_module ( uint32\_t *interface\_address*, uint32\_t *instance* )**

## System

Parameters

<i>interface_address</i>	Address to the module's interface (uniquely identifies module type).
<i>instance</i>	Zero-based module instance index.

Returns

- valid pointer to module.
- NULL if the module was not found

### 8.2.4.2.4 `uint32_t _ft_system_get_time_offset( uint32_t event_stamp )`


Parameters

<i>event_stamp</i>	Time stamp.
--------------------	-------------


Returns

Elapsed time from the defined event stamp.

Here is the call graph for this function:



Here is the caller graph for this function:



**8.2.4.2.5 uint32\_t \_ft\_system\_get\_time\_offset\_from\_period ( uint32\_t event\_period )**

## System

Parameters


<i>event_period</i>	Defined event period.
---------------------	-----------------------

Returns

0 if event\_period period modulo current counter is equal to 0 positive number otherwise.

This function is used to find out if an event can be invoked in its defined period.

Here is the call graph for this function:




### 8.2.4.2.6 uint32\_t \_ft\_system\_get\_time\_period ( void )

Returns

Time period.

Here is the caller graph for this function:




#### 8.2.4.2.7 void \_ft\_system\_increment\_time\_counter( void )

Returns

None.

Here is the caller graph for this function:



#### 8.2.4.2.8 int32\_t \_ft\_system\_init( const struct ft\_system \* system )


Parameters

<i>system</i>	Pointer to the user system parameters structure.
---------------	--

Returns

- FT\_SUCCESS if the system data are set correctly,
- FT\_FAILURE if the system data check failed.

Here is the call graph for this function:



## System

Here is the caller graph for this function:



### 8.2.4.2.9 void \_ft\_system\_invoke\_callback ( uint32\_t event )

Parameters

event	Callback event.
-------	-----------------


Returns

None.

Here is the call graph for this function:



Here is the caller graph for this function:



**8.2.4.2.10 int32\_t \_ft\_system\_module\_function( uint32\_t *option* )**

## System


Parameters

<i>option</i>	One of the options from the ft_system_module_call enum
---------------	--


Returns

- FT\_SUCCESS if the module's action was carried out successfully,
- FT\_FAILURE if the module's action failed.

Here is the call graph for this function:



Here is the caller graph for this function:




#### 8.2.4.2.11 void \_ft\_system\_modules\_data\_ready( void )


Returns

None.

Here is the call graph for this function:



Here is the caller graph for this function:



#### 8.2.4.2.12 void ft\_error( char \* file\_name, uint32\_t line )

## System


Parameters

<i>file_name</i>	Pointer to the file name.
<i>line</i>	Number of the line which was asserted.

Returns

none

Here is the call graph for this function:






## Chapter 9

### Data Structure Documentation

#### 9.0.5 ft\_keydetector\_interface Struct Reference

```
#include <ft_keydetectors.h>
```

Collaboration diagram for ft\_keydetector\_interface:



#### Data Fields

- int32\_t(\* `ft_keydetector_init` )(struct `ft_electrode_data` \*electrode)
- void(\* `ft_keydetector_process` )(struct `ft_electrode_data` \*electrode)
- void(\* `ft_keydetector_measure` )(struct `ft_electrode_data` \*electrode, uint32\_t signal)
- const char \* `name`

#### 9.0.5.1 Detailed Description

The key detector interface structure represents the Freescale Touch library Key Detector algorithm interface. The context data of the key detectors are stored in the [Electrodes](#) application objects.

#### 9.0.5.2 Field Documentation

##### 9.0.5.2.1 int32\_t(\* ft\_keydetector\_interface::ft\_keydetector\_init)(struct ft\_electrode\_data \*electrode)

Key Detector initialization function pointer

**9.0.5.2.2 void(\* ft\_keydetector\_interface::ft\_keydetector\_measure)(struct ft\_electrode\_data \*electrode, uint32\_t signal)**

Key Detector measure function pointer

**9.0.5.2.3 void(\* ft\_keydetector\_interface::ft\_keydetector\_process)(struct ft\_electrode\_data \*electrode)**

Key Detector process function pointer

**9.0.5.2.4 const char\* ft\_keydetector\_interface::name**

A name of the variable of this type, used for FreeMASTER support purposes.



**How to Reach Us:**

**Home Page:**

[freescale.com](http://freescale.com)

**Web Support:**

[freescale.com/support](http://freescale.com/support)

Information in this document is provided solely to enable system and software implementers to use Freescale products. There are no express or implied copyright licenses granted hereunder to design or fabricate any integrated circuits based on the information in this document.

Freescale reserves the right to make changes without further notice to any products herein. Freescale makes no warranty, representation, or guarantee regarding the suitability of its products for any particular purpose, nor does Freescale assume any liability arising out of the application or use of any product or circuit, and specifically disclaims any and all liability, including without limitation consequential or incidental damages. "Typical" parameters that may be provided in Freescale data sheets and/or specifications can and do vary in different applications, and actual performance may vary over time. All operating parameters, including "typicals," must be validated for each customer application by customer's technical experts. Freescale does not convey any license under its patent rights nor the rights of others. Freescale sells products pursuant to standard terms and conditions of sale, which can be found at the following address:  
[freescale.com/SalesTermsandConditions](http://freescale.com/SalesTermsandConditions).

Freescale, the Freescale logo, Kinetis, Processor Expert are trademarks of Freescale Semiconductor, Inc., Reg. U.S. Pat. & Tm. Off. Tower is a trademark of Freescale Semiconductor, Inc. All other product or service names are the property of their respective owners. ARM, ARM Powered logo, and Cortex are registered trademarks of ARM Limited (or its subsidiaries) in the EU and/or elsewhere. All rights reserved.

© 2014 Freescale Semiconductor, Inc.

