

APV77.2

entrelec®

184 -186, rue Léon-Blum
69627 Villeurbanne Cedex
France
Tél. 72 35 35 35
Télex 380 542 F
Fax : 72 33 79 54

ISO 9001

certificat
1993/110a

EC DECLARATION OF CONFORMITY

V. Réf.

N. Réf.

We,

ENTRELEC SA - 184-186, rue Léon-Blum - 69627 VILLEURBANNE Cedex - FRANCE
represented by Mr D. LANDREAU, technical manager,

declare that ENTRELEC terminal blocks and their accessoires according to the list of
the catalogue " terminal blocks ",

Provided that they are installed, maintained and used in application for which it was,
in accordance with " professional practices ", relevant installation standards and
manufacturer's instructions,

complies with the provisions of Council Directive(s) :

- n°73/23/EC of 19 february 1973 (electrical equipment designed for used within
certain voltage limits). Modified by directive n°93/68/EC of 22 july 1993;

- n°89/336/EC of 3 may 1989 (electromagnetic compatibility) modified by
n°92/31/EC of 28 april 1992 and n°93/68/EC of 22 july 1993.

and can be incorpored by professionals into equipments in accordance with other
directives.

This compliance is demonstrated by a conformity with the following harmonized
standards or other normative documents :

- EN 60947-1 of 10 october 1991: low-voltage switchgear and controlgear; part 1:
general rules;

- EN 60947-7-1 of 10 october 1991: low-voltage switchgear and controlgear;
part 7 : ancillary equipment; section 1 : terminal blocks for copper conductors.

Year of affixing "CE" marking : 1996

Villeurbanne, le

D. LANDREAU
Technical Manager